

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Tallowood School (5459)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Castle Hill</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>The Hills</b>

5459 - Tallowood School  
Site Plan (06717)













1:944

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Withdrawal - S - (14.92 SQM)	● Student Space (6)	
B00A - R0004 - Movement - (179.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - S - (59.67 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0006 - Practical Activities - S - 2hb - (95.51 SQM)	● Student Space (44)	
B00A - R0008 - Home Base - S - (59.87 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0009 - Withdrawal - S - (8.99 SQM)	● Student Space (4)	
B00A - R0011 - Staff Room Annexe - (25.65 SQM)	● Office (6)	
B00A - R0012 - Movement - (46.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Deputy Principal - (13.6 SQM)	● Office (3)	
B00A - R0015 - Sick Bay - (10.56 SQM)	● Student Space (4)	
B00A - R0016 - Clerical Office - (22.57 SQM)	● Office (5)	
B00A - R0017 - Entry Vestibule - (29.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (23.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Duplicating Workroom - (12.34 SQM)	● Office (3)	
B00A - R0020 - Principal - (17.76 SQM)	● Office (4)	
B00A - R0021 - Interview - (15.89 SQM)	● Office (3)	
B00A - R0027 - Staff Room - (47.98 SQM)	● Office (11)	
B00A - R0028 - Staff Kitchen - (10.84 SQM)	● Office (2)	
B00A - R0029 - Withdrawal - S - (8.96 SQM)	● Student Space (4)	
B00A - R0031 - Home Base - S - (60.89 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0036 - Home Base - S - (61.11 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0001 - Movement - (225.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Withdrawal - S - (14.87 SQM)	● Student Space (6)	
B00B - R0005 - Home Base - S - (61.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0010 - Home Base - S - (61.18 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0011 - Withdrawal - S - (8.93 SQM)	● Student Space (4)	
B00B - R0014 - Withdrawal - S - (8.91 SQM)	● Student Space (4)	
B00B - R0015 - Home Base - S - (59.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0022 - Special Programs Room - (32.44 SQM)	● Student Space (15)	
B00B - R0026 - Reading Area - (93.53 SQM)	● Student Space (43)	
B00B - R0027 - Special Programs Room - (32.68 SQM)	● Student Space (15)	
B00B - R0031 - Practical Activities - S - 2hb - (51.41 SQM)	● Student Space (23)	
B00B - R0033 - Home Base - S - (58.37 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0035 - Withdrawal - S - (8.96 SQM)	● Student Space (4)	
B00B - R0036 - Withdrawal - S - (8.94 SQM)	● Student Space (4)	
B00B - R0038 - Home Base - S - (59.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0039 - Practical Activities - S - 2hb - (96.04 SQM)	● Student Space (44)	
B00B - R0040 - Distribution Board - (0.45 SQM)	Not Applicable	
B00B - R0041 - Home Base - S - (60 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0001 - Movement - (83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Withdrawal - S - (14.77 SQM)	● Student Space (6)	
B00C - R0007 - Home Base - S - (60.9 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0012 - Home Base - S - (61.11 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0013 - Withdrawal - S - (8.92 SQM)	● Student Space (4)	
B00C - R0016 - Withdrawal - S - (8.94 SQM)	● Student Space (4)	
B00C - R0017 - Home Base - S - (59.78 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0018 - Practical Activities - S - 2hb - (95.69 SQM)	● Student Space (44)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0019 - Home Base - S - (59.62 SQM) - Teaching Space: 1	 Student Space (27)	
B00D - R0001 - Movement - (43.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (43.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Communal Space - (185.63 SQM)	 Student Space (86)	
B00D - R0009 - Movement - (16.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (33.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Hydrotherapy - Pool - (175.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (8.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (17.51 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Clerical Office - (14.03 SQM)	 Office (3)	
B00E - R0012 - Movement - (10.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Practical Activities - (24.57 SQM)	 Student Space (11)	
B00F - R0007 - Practical Activities - (10.03 SQM)	 Student Space (4)	
B00F - R0011 - Practical Activities - (5.87 SQM)	 Student Space (2)	
B00F - R0015 - Movement - (33.14 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Practical Activities - Pre - (75 SQM)	 Student Space (34)	
B00F - R0018 - Practical Activities - (74.2 SQM)	 Student Space (34)	
B00F - R0025 - Practical Activities - Pre - (6 SQM)	 Student Space (2)	
B00F - R0028 - Practical Activities - (75.05 SQM)	 Student Space (34)	
B00F - R0030 - Movement - (16.31 SQM)	Not Applicable	Circulation or storage space.