


VENTILATION AUDIT REPORT

SCHOOL:	Tamworth High School (8139)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Tamworth
LOCAL GOVERNMENT AREA:	Tamworth

8139 - Tamworth High School
Site Plan (12614)



1:999

Printed: 22-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (51.78 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0002 - General Learning Space - (52.06 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0003 - General Learning Space - (52.29 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0004 - Special Learning Space - (39.01 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R0007 - Ancillary Staff - (13.02 SQM)	Office (3)	
B00A - R0008 - Interview/Office - Type 1 - (12.87 SQM)	Office (3)	
B00A - R0010 - Staff Study - (25.45 SQM)	Office (6)	
B00A - R0011 - General Learning Space - (88.29 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0012 - Senior Study - (28.42 SQM)	Office (7)	
B00A - R0014 - General Learning Space - (51.77 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0015 - Movement - (142.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (7.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (7.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Staff Study - (30.41 SQM)	Office (7)	
B00A - R1002 - Staff Study - (21.49 SQM)	Office (5)	
B00A - R1003 - General Learning Space - (52.57 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1004 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1005 - General Learning Space - (39.29 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1008 - Staff Study - (26.43 SQM)	Office (6)	
B00A - R1010 - General Learning Space - (52.5 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1011 - General Learning Space - (52.07 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1017 - Computer Learning Space - (65.68 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1018 - Movement - (151.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - General Learning Space - (52.43 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0002 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0003 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0006 - Staff Study - (9.79 SQM)	Office (2)	
B00B - R0009 - Administration - Clerical - (19.36 SQM)	Office (4)	
B00B - R0011 - Administration - Clerical - (15.81 SQM)	Office (3)	
B00B - R0015 - General Learning Space - (52.14 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0016 - Movement - (171.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (15.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Movement - (13.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Staff Study - (47.7 SQM)	Office (11)	
B00B - R0023 - Commonroom - (16.15 SQM)	Office (4)	
B00B - R0024 - Entry - (17.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Deputy Principal Office - (13.38 SQM)	Office (3)	
B00B - R0026 - Deputy Principal Office - (11.4 SQM)	Office (2)	
B00B - R0027 - Interview/Office - Type 1 - (8.11 SQM)	Office (2)	
B00B - R1003 - Senior Seminar - (39.02 SQM)	Office (9)	
B00B - R1006 - General Learning Space - (52.64 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1007 - General Learning Space - (52.5 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1013 - General Learning Space - (66.5 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1014 - Movement - (161.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Darkroom Space - (22.39 SQM)	Office (5)	
B00B - R1016 - Stage - (21.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R1017 - General Learning Space - (51.93 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1018 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1019 - Staff Lounge - (20.1 SQM)	Office (5)	
B00C - R0001 - Movement - (13.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (170.7 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Staff Study - (9.64 SQM)	Office (2)	
B00C - R0006 - Interview/Office - Type 1 - (6.95 SQM)	Office (1)	
B00C - R0008 - General Learning Space - (51.93 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0009 - General Learning Space - (52.07 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0010 - General Learning Space - (52 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0011 - General Learning Space - (52.14 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0012 - Study Space - (7.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Study Space - (19.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Seminar - (34.99 SQM)	Office (8)	
B00C - R0015 - General Learning Space - (51.71 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0017 - Leading Teacher - (15.94 SQM)	Office (3)	
B00C - R0020 - Movement - (7.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (9.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Special Learning Space - (45.22 SQM) - Teaching Space: 1	Student Space (20)	
B00C - R1001 - Ancillary Staff - (22.33 SQM)	Office (5)	
B00C - R1002 - Computer Learning Space - (38.85 SQM) - Teaching Space: 1	Student Space (18)	
B00C - R1003 - Art Learning Space - (52.28 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1004 - Art Learning Space - (44.06 SQM) - Teaching Space: 1	Student Space (20)	
B00C - R1006 - Art Learning Space - (52.5 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1007 - Music Learning Space - (65.42 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1013 - General Learning Space - (52.52 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1014 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1017 - Movement - (138.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Staff Study - (39.44 SQM)	Office (9)	
B00D - R0008 - Laboratory L.S. - (53.81 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0017 - Movement - (20.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Preparation - Science - (38.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Staff Kitchen - (26.4 SQM)	Office (6)	
B00D - R0021 - Laboratory L.S. - (88.78 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0022 - Laboratory L.S. - (89.79 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0023 - Laboratory L.S. - (90.89 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0025 - Movement - (141.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Movement - (11.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R1006 - General Learning Space - (39.19 SQM) - Teaching Space: 1	Student Space (18)	
B00D - R1009 - Computer Learning Space - (54.33 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R1011 - Preparation - (48.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R1013 - Movement - (132.47 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Movement - (18.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R1015 - Laboratory L.S. - (92.07 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R1016 - Laboratory L.S. - (95.23 SQM) - Teaching Space: 1	Student Space (44)	
B00D - R1017 - Laboratory L.S. - (91.8 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0001 - Multi-Purpose Space - (477.97 SQM)	Student Space (221)	
B00E - R0003 - Movement - (11.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Movement - (6.74 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (24.76 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0002 - Commonroom - (79.27 SQM)	Office (19)	
B00H - R0001 - General Learning Space - (64.75 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0003 - Ancillary Staff - (20.76 SQM)	Office (5)	
B00H - R0004 - Food Technology L.S. - (65.55 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0007 - Special Learning Space - (70.23 SQM) - Teaching Space: 1	Student Space (32)	
B00H - R0011 - Music Learning Space - (65.41 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0013 - Staff Study - (26.01 SQM)	Office (6)	
B00H - R0014 - Staff Study - (25.81 SQM)	Office (6)	
B00H - R0016 - Food Technology L.S. - (65.19 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0017 - Food/Research Space - (12.5 SQM)	Not Applicable	Circulation or storage space.
B00H - R0020 - General Learning Space - (51.78 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0021 - Clinic - Boys - (12.66 SQM)	Office (3)	
B00H - R0023 - Clinic - Girls - (17.98 SQM)	Office (4)	
B00H - R0025 - Staff Study - (25.6 SQM)	Office (6)	
B00H - R0028 - Leading Teacher - (11.02 SQM)	Office (2)	
B00H - R0029 - Ancillary Staff - (7.8 SQM)	Office (1)	
B00H - R0030 - Movement - (144.11 SQM)	Not Applicable	Circulation or storage space.
B00H - R0034 - Outdoor Learning Area - (27.46 SQM)	Not Applicable	Circulation or storage space.
B00H - R1001 - General Learning Space - (65.77 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R1005 - General Learning Space - (65.65 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R1006 - Art Learning Space - (65.41 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R1010 - Art Learning Space - (65.92 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R1011 - Staff Study - (39.23 SQM)	Office (9)	
B00H - R1012 - Staff Study - (52.5 SQM)	Office (13)	
B00H - R1015 - General Learning Space - (65.51 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R1017 - Seminar - (21.46 SQM)	Office (5)	
B00H - R1018 - General Learning Space - (65.14 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R1019 - Movement - (141.93 SQM)	Not Applicable	Circulation or storage space.
B00H - R1020 - Staff Kitchen - (112.84 SQM)	Office (28)	
B00H - R1021 - Commonroom - (21.42 SQM)	Office (5)	
B00I - R0002 - General Assistants - (42.11 SQM)	Office (10)	
B00I - R0003 - General Assistants - (19.65 SQM)	Office (4)	
B00K - R0001 - General Learning Space - (83.13 SQM) - Teaching Space: 1	Student Space (38)	
B00L - R0001 - Audio Visual Workroom - (47.59 SQM)	Student Space (22)	
B00L - R0003 - Main Area - (196.73 SQM)	Not Applicable	Circulation or storage space.
B00L - R1003 - Movement - (35.68 SQM)	Not Applicable	Circulation or storage space.
B00L - R1005 - Workroom - (45.95 SQM)	Office (11)	
B00L - R1007 - Movement - (49.6 SQM)	Not Applicable	Circulation or storage space.
B00L - R2001 - Senior Study - (15.23 SQM)	Office (3)	
B00L - R2002 - Senior Seminar - (15.55 SQM)	Office (3)	
B00L - R2003 - Staff Study - (15.63 SQM)	Office (3)	
B00L - R2004 - Senior Study - (15.55 SQM)	Office (3)	
B00L - R2005 - Senior Study - (15.31 SQM)	Office (3)	
B00L - R2006 - Main Area - (112.12 SQM)	Not Applicable	Circulation or storage space.
B00L - R3002 - Main Area - (101.92 SQM)	Not Applicable	Circulation or storage space.
B00T - R0001 - Design L.S. - (79.27 SQM) - Teaching Space: 1	Student Space (36)	
B00T - R0004 - Materials Technology L.S. - (87.32 SQM) - Teaching Space: 1	Student Space (40)	
B00T - R0005 - Wood Technology Bay - (23.94 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00T - R0006 - Materials Technology L.S. - (77.32 SQM) - Teaching Space: 1	● Student Space (35)	
B00T - R0009 - Metal Technology Bay - (30.75 SQM)	Not Applicable	Circulation or storage space.
B00T - R0012 - Staff Study - (32.28 SQM)	● Office (8)	
B00T - R0015 - Materials Technology L.S. - (77.03 SQM) - Teaching Space: 1	● Student Space (35)	
B00T - R0023 - Workshop Area - (68.37 SQM)	● Student Space (31)	
B00T - R0024 - Workshop Area - (84.49 SQM)	● Student Space (39)	
B00T - R0025 - Movement - (71.05 SQM)	Not Applicable	Circulation or storage space.
B00U - R0002 - Outdoor Workshop - (80.09 SQM)	Not Applicable	Circulation or storage space.
B0AD - R0003 - Isolation Space - (28.99 SQM)	● Office (7)	
B0AD - R0004 - Administration - Clerical - (44.45 SQM)	● Office (11)	
B0AD - R0006 - Principal Office - (19.93 SQM)	● Office (4)	
B0AD - R0007 - Interview/Office - Type 1 - (13.25 SQM)	● Office (3)	
B0AD - R0008 - Interview/Office - Type 1 - (13.12 SQM)	● Office (3)	
B0AD - R0009 - Staff Study - (16.45 SQM)	● Office (4)	
B0AD - R0012 - Ancillary Staff - (13.74 SQM)	● Office (3)	
B0AD - R0014 - Public Entry - (63.33 SQM)	Not Applicable	Circulation or storage space.
B0AD - R0016 - Student Canteen - (16.89 SQM)	Not Applicable	Circulation or storage space.
B0AD - R0020 - Movement - (50.11 SQM)	Not Applicable	Circulation or storage space.
B0AD - R0021 - Movement - (18.66 SQM)	Not Applicable	Circulation or storage space.
B0AD - R0022 - Public Reception - (8.7 SQM)	Not Applicable	Circulation or storage space.
B0AD - R0023 - Movement - (36.76 SQM)	Not Applicable	Circulation or storage space.
B0CA - R0006 - Movement - (476.65 SQM)	Not Applicable	Circulation or storage space.
B0CA - R0013 - Staff Study - (8.04 SQM)	● Office (2)	
B0CA - R0015 - Student Canteen - (63.78 SQM)	Not Applicable	Circulation or storage space.
B0CA - R0025 - Staff Lounge - (16.89 SQM)	● Office (4)	