


VENTILATION AUDIT REPORT

SCHOOL:	Tamworth Public School (3157)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Tamworth
LOCAL GOVERNMENT AREA:	Tamworth

3157 - Tamworth Public School
Site Plan (11530)



1:1,455

Printed: 10-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (13.01 SQM)	Office (3)	
B00A - R0002 - Staff Room Annexe - (10.32 SQM)	Office (2)	
B00A - R0004 - Home Base - (70.12 SQM) - Teaching Space: 1	Student Space (32)	
B00A - R0005 - Movement - (5.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Entry Vestibule - (22.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (5.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Principal - (19.85 SQM)	Office (4)	
B00A - R0016 - Deputy Principal - (14.06 SQM)	Office (3)	
B00A - R0017 - Movement - (59.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Home Base - (45.07 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0023 - Home Base - (45.07 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0024 - Staff Room Annexe - (11.09 SQM)	Office (2)	
B00A - R0025 - Home Base - (45.07 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0026 - Home Base - (45.4 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0027 - Home Base - (45.4 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0028 - Movement - (71.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Movement - (36.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Movement - (15.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Home Base - (46.55 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0037 - Home Base - (47.89 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0038 - Movement - (30.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Staff Room - (22.17 SQM)	Office (5)	
B00A - R0040 - Principal - (17.08 SQM)	Office (4)	
B00A - R0041 - Clerical Office - (42.21 SQM)	Office (10)	
B00A - R0042 - Sick Bay - (8.07 SQM)	Student Space (3)	
B00A - R0043 - Movement - (23.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Home Base - (58.81 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0047 - Movement - (22.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - Staff Room - (87.77 SQM)	Office (21)	
B00A - R0057 - Staff Kitchen - (14 SQM)	Office (3)	
B00A - R0059 - Clerical/Printing - (10.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0060 - Study Annexe - (29.36 SQM)	Office (7)	
B00A - R1001 - Home Base - (54.45 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1002 - Staff Room Annexe - (24.48 SQM)	Office (6)	
B00A - R1003 - Movement - (19.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Staff Room Annexe - (33.85 SQM)	Office (8)	
B00A - R9012 - Movement - (30.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R9015 - Movement - (22.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R9016 - Movement - (24.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R9017 - Practical Activities - 1hb - (45.95 SQM)	Student Space (21)	
B00A - R9018 - Home Base - M - (45.96 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0001 - Staff Room Annexe - (19.53 SQM)	Office (4)	
B00B - R0002 - Duplicating Workroom - (9.38 SQM)	Office (2)	
B00B - R0004 - Home Base - M - (40.1 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R0005 - Practical Activities - M - 1hb - (12.19 SQM)	Student Space (5)	
B00B - R0006 - Home Base - (35.1 SQM) - Teaching Space: 1	Student Space (16)	
B00B - R0007 - Practical Activities - 1hb - (11.2 SQM)	Student Space (5)	
B00B - R0008 - Home Base - (35.1 SQM) - Teaching Space: 1	Student Space (16)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0009 - Practical Activities - 1hb - (11.19 SQM)	● Student Space (5)	
B00B - R0010 - Movement - (7.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Staff Room Annexe - (18.6 SQM)	● Office (4)	
B00B - R0012 - Communal Space - (138.7 SQM)	● Student Space (64)	
B00B - R0016 - Practical Activities - 1hb - (14.43 SQM)	● Student Space (6)	
B00B - R0017 - Home Base - (32.3 SQM) - Teaching Space: 1	● Student Space (14)	
B00B - R0018 - Practical Activities - 1hb - (14.44 SQM)	● Student Space (6)	
B00B - R0019 - Home Base - (32.3 SQM) - Teaching Space: 1	● Student Space (14)	
B00B - R0020 - Movement - (56.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (56.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Special Programs Room - (42.72 SQM)	● Student Space (19)	
B00C - R0007 - Reading Area - (219.26 SQM)	● Student Space (101)	
B00C - R0008 - Movement - (14.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (14.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (62.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (49.86 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0004 - Home Base - (157.35 SQM) - Teaching Space: 1	● Student Space (73)	
B00D - R0005 - Home Base - (51.17 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0006 - Home Base - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0010 - Movement - (6.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Movement - (22.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Home Base - (107.23 SQM) - Teaching Space: 1	● Student Space (49)	
B00D - R0013 - Movement - (20.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Special Programs Room - (50.67 SQM)	● Student Space (23)	
B00E - R0003 - Movement - (15.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Canteen - (30.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Withdrawal Space - 1hb - (20.65 SQM)	● Student Space (9)	
B00F - R0005 - Home Base - (47.23 SQM) - Teaching Space: 1	● Student Space (21)	
B00F - R0006 - Home Base - (47.24 SQM) - Teaching Space: 1	● Student Space (21)	
B00F - R0007 - Home Base - (47.74 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R0008 - Home Base - (47.74 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R0012 - Movement - (79.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Staff Room Annexe - (15.67 SQM)	● Office (3)	
B00F - R1001 - Movement - (85.4 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Home Base - (48.26 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R1003 - Home Base - (48.07 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R1004 - Home Base - (48.62 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R1005 - Home Base - (48.62 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R1006 - Staff Room Annexe - (23.07 SQM)	● Office (5)	
B00G - R0001 - Staff Room Annexe - (50.77 SQM)	● Office (12)	
B00G - R0002 - Staff Kitchen - (25.22 SQM)	● Office (6)	
B00G - R0007 - Staff Room - (64.26 SQM)	● Office (16)	
B00H - R0003 - Movement - (7.23 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Communal Space - (361.49 SQM)	● Student Space (167)	
B00O - R0002 - Clerical Office - (13.24 SQM)	● Office (3)	
B00O - R0004 - Staff Kitchen - (20.21 SQM)	● Office (5)	
B00O - R0005 - Movement - (17.09 SQM)	Not Applicable	Circulation or storage space.
B00O - R0020 - Movement - (11.06 SQM)	Not Applicable	Circulation or storage space.
B00O - R0021 - Outdoor Learning Area - (257.82 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Home Base - (69 SQM) - Teaching Space: 1	● Student Space (32)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0002 - Home Base - (63.58 SQM) - Teaching Space: 1	● Student Space (29)	
B00P - R0006 - Withdrawal Space - 1hb - (9.23 SQM)	● Student Space (4)	
B00P - R0007 - Withdrawal Space - 1hb - (9.16 SQM)	● Student Space (4)	
B00P - R0009 - Practical Activities - 2hb - (66.91 SQM)	● Student Space (31)	
B00P - R0010 - Presentation Area - (61.23 SQM)	Not Applicable	Circulation or storage space.
B00P - R0013 - Outdoor Learning Area - (163.19 SQM)	Not Applicable	Circulation or storage space.
B00P - R1001 - Home Base X3 - (155.79 SQM) - Teaching Space: 3	● Student Space (72)	
B00P - R1002 - Practical Activities - 3hb - (65.11 SQM)	● Student Space (30)	
B00P - R1006 - Staff Room Annexe - (6.73 SQM)	● Office (1)	
B00P - R1007 - Withdrawal Space - 2hb - (18.6 SQM)	● Student Space (8)	
B00P - R1009 - Presentation Area - (56.52 SQM)	Not Applicable	Circulation or storage space.
B00P - R1010 - Home Base - (42.31 SQM) - Teaching Space: 1	● Student Space (19)	
B00P - R1013 - Withdrawal Space - 2hb - (16.2 SQM)	● Student Space (7)	
B00P - R1016 - Outdoor Learning Area - (120.86 SQM)	Not Applicable	Circulation or storage space.
NS 100 14346 - NS 100 14346 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
OS 602 10783 - OS 602 10783 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13712 - OS 602 13712 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14237 - OS 602 14237 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 11614 - OS 603 11614 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 12663 - OS 603 12663 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	