


VENTILATION AUDIT REPORT

SCHOOL:	Tamworth South Public School (3882)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Tamworth
LOCAL GOVERNMENT AREA:	Tamworth

3882 - Tamworth South Public School
Site Plan (13114)




Printed: 23-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (71.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Deputy Principal - (12.79 SQM)	Office (3)	
B00A - R0004 - Sick Bay - (8.27 SQM)	Student Space (3)	
B00A - R0006 - Entry Vestibule - (33.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Principal - (20.57 SQM)	Office (5)	
B00A - R0011 - Clerical Office/Workroom - (27.52 SQM)	Office (6)	
B00A - R0013 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0015 - Practical Activities - 1hb - (19.02 SQM)	Student Space (8)	
B00A - R0016 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0018 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0020 - Practical Activities - 1hb - (9.1 SQM)	Student Space (4)	
B00B - R0010 - Reading Area - (210.38 SQM)	Student Space (97)	
B00B - R0013 - Movement - (7.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Special Programs Room - (43.9 SQM)	Student Space (20)	
B00C - R0002 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0003 - Home Base - (53.67 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0004 - Practical Activities - 1hb - (27.35 SQM)	Student Space (12)	
B00C - R0005 - Clerical Office/Workroom - (22.43 SQM)	Office (5)	
B00C - R0006 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0007 - Practical Activities - 1hb - (24.06 SQM)	Student Space (11)	
B00C - R0008 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0009 - Practical Activities - 1hb - (17.23 SQM)	Student Space (7)	
B00C - R0012 - Movement - (9.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Home Base - (53.67 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0014 - Practical Activities - 1hb - (16.66 SQM)	Student Space (7)	
B00C - R0015 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0016 - Practical Activities - 1hb - (17.81 SQM)	Student Space (8)	
B00D - R0004 - Staff Room - (44.19 SQM)	Office (11)	
B00D - R0005 - Movement - (19.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Staff Room Annexe - (44.26 SQM)	Office (11)	
B00D - R0008 - Practical Activities - 1hb - (17.74 SQM)	Student Space (8)	
B00D - R0009 - Movement - (13.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Withdrawal Space - 1hb - (21.99 SQM)	Student Space (10)	
B00D - R0012 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0013 - Practical Activities - 1hb - (22.83 SQM)	Student Space (10)	
B00D - R0015 - Withdrawal Space - 2hb - (9.47 SQM)	Student Space (4)	
B00D - R0017 - Home Base - (53.67 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0018 - Practical Activities - 1hb - (15.91 SQM)	Student Space (7)	
B00D - R0019 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0020 - Practical Activities - 1hb - (17.01 SQM)	Student Space (7)	
B00E - R0001 - Movement - (95.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Deputy Principal - (20.75 SQM)	Office (5)	
B00E - R0006 - Practical Activities - 1hb - (12.34 SQM)	Student Space (5)	
B00E - R0009 - Home Base - (85.31 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0010 - Home Base - (85.3 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0013 - Practical Activities - 1hb - (14.81 SQM)	Student Space (6)	
B00E - R0015 - Home Base - (56.98 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0001 - Home Base - (75.67 SQM) - Teaching Space: 1	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0002 - Practical Activities - 1hb - (14.44 SQM)	● Student Space (6)	
B00F - R0005 - Movement - (28.24 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (67.01 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0009 - Home Base - (53.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0010 - Duplicating Workroom - (13.2 SQM)	● Office (3)	
B00F - R0011 - Practical Activities - 1hb - (12.82 SQM)	● Student Space (5)	
B00F - R0012 - Movement - (31.27 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Movement - (41.45 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Practical Activities - 1hb - (23.6 SQM)	● Student Space (10)	
B00G - R0003 - Interview - (13.29 SQM)	● Office (3)	
B00G - R0005 - Home Base - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0007 - Home Base - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0008 - Practical Activities - 1hb - (16.29 SQM)	● Student Space (7)	
B00G - R0011 - Movement - (9.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Home Base - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0014 - Practical Activities - 1hb - (16.43 SQM)	● Student Space (7)	
B00G - R0015 - Home Base - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0016 - Practical Activities - 1hb - (23.59 SQM)	● Student Space (10)	
B00H - R0003 - Home Base - E - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0007 - Practical Activities - 1hb - (17.82 SQM)	● Student Space (8)	
B00H - R0010 - Movement - (9.32 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Home Base - M - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0013 - Practical Activities - M - 1hb - (15.64 SQM)	● Student Space (7)	
B00H - R0014 - Home Base - M - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0015 - Practical Activities - M - 1hb - (23.61 SQM)	● Student Space (10)	
B00H - R0019 - Practical Activities - M - 1hb - (16.84 SQM)	● Student Space (7)	
B00H - R0022 - Clerical/Printing - (16.34 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Home Base - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R0003 - Movement - (12.73 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Practical Activities - 1hb - (41.6 SQM)	● Student Space (19)	
B00I - R0007 - Withdrawal Space - 1hb - (7.2 SQM)	● Student Space (3)	
B00I - R0008 - Movement - (15.46 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (11.8 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Interview - (19.17 SQM)	● Office (4)	
B00K - R0001 - Movement - (90.02 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Canteen - (43.5 SQM)	Not Applicable	Circulation or storage space.
B00K - R0016 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Movement - (6.65 SQM)	Not Applicable	Circulation or storage space.
B00K - R0025 - Special Programs Room - (58.78 SQM)	● Student Space (27)	
B00K - R0026 - Withdrawal Space - 1hb - (6.84 SQM)	● Student Space (3)	
B00K - R0027 - Home Base - (71.51 SQM) - Teaching Space: 1	● Student Space (33)	
B00K - R0028 - Practical Activities/Movement - 1hb - (16.13 SQM)	● Student Space (7)	
B00K - R0029 - Home Base - (50.54 SQM) - Teaching Space: 1	● Student Space (23)	
B00K - R0031 - Special Programs Room - (32.52 SQM)	● Student Space (15)	
B00M - R0001 - Communal Space - (200.47 SQM)	● Student Space (93)	
B00M - R0002 - Raised Platform - (56.47 SQM)	Not Applicable	Circulation or storage space.
B00M - R0016 - Movement - (6.94 SQM)	Not Applicable	Circulation or storage space.
B00M - R0018 - Movement - (16.83 SQM)	Not Applicable	Circulation or storage space.
OH 045 17046 - OH 045 17046 - OSHC Hub 45 - (SQM)	● Student Space ()	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 11109 - OS 602 11109 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	