

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Tarago Public School (3162)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Goulburn</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Goulburn Mulwaree</b>

3162 - Tarago Public School  
Site Plan (11330)










1:643

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (53.5 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0004 - Staff Room - (13.39 SQM)	 Office (3)	
B00A - R0008 - Principal - (15.73 SQM)	 Office (3)	
B00B - R0001 - Reading Area - (40.58 SQM)	 Student Space (18)	
B00C - R0003 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Clerical Office - (43.99 SQM)	 Office (10)	
B00D - R0001 - Practical Activities - 1hb - (21.44 SQM)	 Student Space (9)	
B00D - R0002 - Home Base - (46.78 SQM) - Teaching Space: 1	 Student Space (21)	