

VENTILATION AUDIT REPORT

SCHOOL:	Taree High School (8140)
AMU REGION:	North Coast
STATE ELECTORATE:	Myall Lakes
LOCAL GOVERNMENT AREA:	Mid-Coast

8140 - Taree High School
Site Plan (12866)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - General Learning Space - (62.64 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0011 - Food Technology L.S. - (118.13 SQM) - Teaching Space: 1	Student Space (54)	
B00A - R0013 - Interview/Office - Type 1 - (13.02 SQM)	Office (3)	
B00A - R0015 - Clinic - Boys - (15.87 SQM)	Office (3)	
B00A - R0026 - Leading Teacher - (15.2 SQM)	Office (3)	
B00A - R0028 - Staff Study - (22.88 SQM)	Office (5)	
B00A - R0029 - Computer Learning Space - (47.38 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0030 - Computer Learning Space - (51.55 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0031 - General Learning Space - (51.61 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0032 - General Learning Space - (51.76 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0036 - Staff Study - (13.24 SQM)	Office (3)	
B00A - R0037 - General Learning Space - (48.96 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0038 - Staff Study - (33.8 SQM)	Office (8)	
B00A - R0041 - General Learning Space - (48.96 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0052 - Deputy Principal Office - (15.09 SQM)	Office (3)	
B00A - R0053 - Deputy Principal Office - (15.16 SQM)	Office (3)	
B00A - R0054 - Student Waiting - (20.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Principal Office - (19.42 SQM)	Office (4)	
B00A - R0056 - Interview/Office - Type 2 - (14.32 SQM)	Office (3)	
B00A - R0057 - Public Reception - (31.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0059 - Public Entry - (19.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0062 - Movement - (135.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0063 - Movement - (103 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Laboratory L.S. - (52.32 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1002 - Laboratory L.S. - (80.25 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R1003 - Preparation - (43.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Laboratory L.S. - (91.97 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1005 - Movement - (246.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Audio Visual Workroom - (32.28 SQM)	Student Space (14)	
B00A - R1007 - Staff Study - (20.81 SQM)	Office (5)	
B00A - R1008 - Staff Kitchen - (15.75 SQM)	Office (3)	
B00A - R1009 - Commonroom - (80.34 SQM)	Office (20)	
B00A - R1013 - General Learning Space - (48 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1014 - General Learning Space - (49.32 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1015 - General Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1016 - General Learning Space - (53.1 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1017 - General Learning Space - (53.52 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1019 - General Learning Space - (50.43 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1020 - Staff Study - (34.15 SQM)	Office (8)	
B00A - R1023 - General Learning Space - (50.6 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R9001 - Duplicating Workroom - (28.26 SQM)	Office (7)	
B00A - R9003 - General Assistants - (27.11 SQM)	Office (6)	
B00A - R9005 - Movement - (117.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R9010 - Gymnasium - (98.17 SQM)	Student Space (45)	
B00A - R9011 - Darkroom Space - (29 SQM)	Office (7)	
B00B - R0005 - Materials Technology L.S. - (67.38 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0007 - General Learning Space - M - (66.51 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0008 - Staff Study - (39.61 SQM)	Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0014 - Food Technology L.S. - (111.9 SQM) - Teaching Space: 1	● Student Space (51)	
B00B - R0017 - Staff Study - (24.51 SQM)	● Office (6)	
B00B - R0021 - Kitchen - Type 2 - (94.36 SQM)	● Student Space (43)	
B00B - R0023 - Preparation - Materials - (18.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Outdoor Learning Area - (34.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Movement - (140.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (129.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R1006 - General Learning Space - (67.32 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R1007 - General Learning Space - (52.77 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1008 - General Learning Space - (66.51 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1009 - Computer Learning Space - (67.53 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R1010 - Staff Study - (38.5 SQM)	● Office (9)	
B00B - R1011 - General Learning Space - (52.99 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1013 - General Learning Space - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - M0001 - Seminar - (19.39 SQM)	● Office (4)	
B00C - M0002 - Staff Study - (20.53 SQM)	● Office (5)	
B00C - M0003 - Senior Study - (142.62 SQM)	● Office (35)	
B00C - R0001 - Laboratory L.S. - (90.67 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0002 - Preparation - (48.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Laboratory L.S. - (86.88 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0005 - Staff Study - (33.97 SQM)	● Office (8)	
B00C - R0007 - Movement - (28.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Movement - (41.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Laboratory L.S. - (91.32 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0010 - Preparation - (48.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Laboratory L.S. - (90.77 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R1001 - Seminar - (13.09 SQM)	● Office (3)	
B00C - R1002 - Seminar - (12.61 SQM)	● Office (3)	
B00C - R1006 - Staff Study - (12.02 SQM)	● Office (3)	
B00C - R1007 - Seminar - (11.67 SQM)	● Office (2)	
B00C - R1008 - Seminar - (11.61 SQM)	● Office (2)	
B00C - R1009 - Main Area - (396.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - Audio Visual Workroom - (28.05 SQM)	● Student Space (13)	
B00C - R1013 - Workroom - (20.91 SQM)	● Office (5)	
B00C - R1015 - Movement - (25.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Art Learning Space - (64.33 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0004 - Art Entry/Display - (17.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Art Learning Space - (61.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0006 - Workshop - (61.08 SQM)	● Student Space (28)	
B00D - R0007 - Art Entry/Display - (17.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Art Learning Space - (61.07 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0012 - Staff Study - (22.13 SQM)	● Office (5)	
B00D - R0013 - Interview/Office - Type 1 - (15.02 SQM)	● Office (3)	
B00D - R0026 - General Learning Space - (59.02 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0027 - Administration - Clerical - (29.56 SQM)	● Office (7)	
B00D - R0029 - General Learning Space - (62.78 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R1001 - General Learning Space - (47.33 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R1002 - General Learning Space - (47.33 SQM) - Teaching Space: 1	● Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1005 - Staff Study - (34.59 SQM)	Office (8)	
B00D - R1006 - Ancillary Staff - (15.95 SQM)	Office (3)	
B00D - R1008 - General Learning Space - (50.39 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1010 - Seminar - (15.08 SQM)	Office (3)	
B00D - R1011 - General Learning Space - (51.83 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1012 - General Learning Space - (50.66 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1013 - General Learning Space - (51.62 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1015 - Seminar - (15.24 SQM)	Office (3)	
B00D - R1016 - General Learning Space - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0001 - Staff Study - (28.19 SQM)	Office (7)	
B00E - R0002 - Seminar/Technology Space - (25.63 SQM)	Office (6)	
B00E - R0003 - Movement - (74.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Materials Technology L.S. - (103.39 SQM) - Teaching Space: 1	Student Space (47)	
B00E - R0009 - Materials Technology L.S. - (95.55 SQM) - Teaching Space: 1	Student Space (44)	
B00E - R0010 - Metal Technology Bay - (22.13 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Welding Area - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Materials Technology L.S. - (72.14 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R0015 - Design L.S. - (52.4 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0018 - Design/Technology L.S. - (77.88 SQM) - Teaching Space: 1	Student Space (36)	
B00E - R0019 - Movement - (21.84 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Wood Technology Bay - (35.47 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Materials Technology L.S. - (90.77 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R0007 - Workshop - (70.81 SQM)	Student Space (32)	
B00G - R0001 - Student Canteen - (56.37 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (96.32 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Movement - (5.29 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Stage - (77.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (6.01 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Multi-Purpose Space - (261.05 SQM)	Student Space (121)	
B00H - R0019 - Staff Study - (8.71 SQM)	Office (2)	
B00H - R0020 - Public Entry - (7.57 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Performance Workspace - (112.75 SQM)	Student Space (52)	
B00J - R0005 - Multi-Purpose Space - (701.26 SQM)	Student Space (325)	
B00J - R0007 - Movement - (35.78 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Entry - (19.64 SQM)	Not Applicable	Circulation or storage space.
B00J - R0015 - Staff Study - (19.25 SQM)	Office (4)	
B00K - R0001 - Growing/Breeding - (8.08 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Workshop - (28.53 SQM)	Student Space (13)	
B00K - R0008 - Movement - (14.46 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Practice/Seminar - (26.67 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Music Learning Space - (79.19 SQM) - Teaching Space: 1	Student Space (36)	
B00L - R0004 - Music Learning Space - (61.26 SQM) - Teaching Space: 1	Student Space (28)	
B00L - R0006 - Staff Study - (17.34 SQM)	Office (4)	
B00L - R0008 - Movement - (40.04 SQM)	Not Applicable	Circulation or storage space.
NS 200 10568 - NS 200 10568 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.