


VENTILATION AUDIT REPORT

SCHOOL:	Taree Public School (3167)
AMU REGION:	North Coast
STATE ELECTORATE:	Myall Lakes
LOCAL GOVERNMENT AREA:	Mid-Coast

3167 - Taree Public School
Site Plan (12633)



1:695

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (47.71 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0002 - Staff Kitchen - (9.73 SQM)	Office (2)	
B00A - R0003 - Practical Activities - 1hb - (22.06 SQM)	Student Space (10)	
B00A - R0005 - Home Base - M - (55.02 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0006 - Home Base - M - (47.82 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0007 - Practical Activities - M - 1hb - (27.02 SQM)	Student Space (12)	
B00A - R0011 - Movement - (65.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Withdrawal Space - 1hb - (18.95 SQM)	Student Space (8)	
B00A - R0013 - Staff Room Annexe - (11.87 SQM)	Office (2)	
B00A - R1002 - Movement - (84.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Withdrawal Space - 1hb - (9.38 SQM)	Student Space (4)	
B00A - R1004 - Home Base - (62.17 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1005 - Practical Activities - 1hb - (21.82 SQM)	Student Space (10)	
B00A - R1007 - Home Base - (57.48 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1008 - Home Base - (49.64 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1009 - Practical Activities - 1hb - (11.28 SQM)	Student Space (5)	
B00A - R1010 - Withdrawal Space - 1hb - (18.96 SQM)	Student Space (8)	
B00B - R0008 - Movement - (13.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Reading Area - (118.81 SQM)	Student Space (55)	
B00B - R0015 - Special Programs Room - (38.29 SQM)	Student Space (17)	
B00B - R0018 - Movement - (13.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Duplicating Workroom - (13.34 SQM)	Office (3)	
B00B - R0020 - Interview - (9.29 SQM)	Office (2)	
B00B - R0024 - Clerical Office - (10.84 SQM)	Office (2)	
B00B - R0026 - Movement - (8.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Principal - (14.27 SQM)	Office (3)	
B00B - R0029 - Deputy Principal - (12.12 SQM)	Office (3)	
B00B - R0034 - Staff Kitchen - (9.36 SQM)	Office (2)	
B00B - R0035 - Staff Room - (65.71 SQM)	Office (16)	
B00B - R0036 - Movement - (11.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0037 - Clerical Office/Workroom - (23.62 SQM)	Office (5)	
B00B - R0038 - Sick Bay - (7.81 SQM)	Student Space (3)	
B00C - R0001 - Home Base - (94.05 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R0009 - Movement - (53.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Home Base - (63.84 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R0015 - Staff Room Annexe - (18.45 SQM)	Office (4)	
B00C - R0023 - Interview - (23.4 SQM)	Office (5)	
B00C - R0026 - Home Base - (86.36 SQM) - Teaching Space: 1	Student Space (40)	
B00C - R0027 - Practical Activities - 1hb - (10.73 SQM)	Student Space (4)	
B00C - R1001 - Home Base - (64.02 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R1005 - Home Base - (64.32 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R1006 - Home Base - (64.32 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R1008 - Home Base - (62.36 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1010 - Movement - (9.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R1011 - Home Base - (128.72 SQM) - Teaching Space: 1	Student Space (59)	
B00C - R1014 - Practical Activities - 1hb - (21.17 SQM)	Student Space (9)	
B00C - R1015 - Withdrawal - M - (8.33 SQM)	Student Space (3)	
B00F - R0005 - Canteen - (29.36 SQM)	Not Applicable	Circulation or storage space.