

VENTILATION AUDIT REPORT

SCHOOL:	Tarrawanna Public School (3820)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Keira
LOCAL GOVERNMENT AREA:	Wollongong

3820 - Tarrawanna Public School
Site Plan (11778)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (20.39 SQM)	Office (5)	
B00A - R0002 - Duplicating Workroom - (11.04 SQM)	Office (2)	
B00A - R0008 - Sick Bay - (7.75 SQM)	Student Space (3)	
B00A - R0009 - Principal - (20.26 SQM)	Office (5)	
B00A - R0012 - Entry Vestibule - (9.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (14.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (7.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (53.37 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0005 - Home Base - (53.37 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0006 - Withdrawal Space - 1hb - (10.77 SQM)	Student Space (4)	
B00B - R0007 - Practical Activities - 1hb - (11.16 SQM)	Student Space (5)	
B00B - R0008 - Home Base - (53.36 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0009 - Home Base - (53.22 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0010 - Withdrawal Space - 1hb - (29.64 SQM)	Student Space (13)	
B00B - R0011 - Movement - (80.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (56.97 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0003 - Movement - (6.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0008 - Movement - (58.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Home Base - (77.19 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R0011 - Raised Platform - (8.47 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (10.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Staff Room - (52.42 SQM)	Office (13)	
B00D - R0005 - Reading Area - (13.23 SQM)	Student Space (6)	
B00D - R0006 - Reading Area - (120.5 SQM)	Student Space (55)	
B00E - R0001 - Movement - (84.63 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Home Base - (53.3 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0006 - Home Base - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0009 - Home Base - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0010 - Home Base - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0011 - Withdrawal Space - 1hb - (22.18 SQM)	Student Space (10)	
B00E - R0013 - Movement - (27.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Deputy Principal - (19.7 SQM)	Office (4)	
B00E - R0020 - Seminar/Study - (21.34 SQM)	Office (5)	
B00E - R0021 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Movement - (7.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Communal Space - (58.69 SQM)	Student Space (27)	
B00E - R0026 - Communal Space - (86.21 SQM)	Student Space (39)	
B00E - R0031 - Movement - (77.37 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Canteen - (19.21 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Movement - (31.3 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Canteen - (16.51 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Movement - (15.09 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Communal Space - (150.47 SQM)	Student Space (69)	
B00K - R0002 - Raised Platform - (55.56 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Movement - (6.09 SQM)	Not Applicable	Circulation or storage space.
B00K - R0016 - Movement - (6.93 SQM)	Not Applicable	Circulation or storage space.
B00K - R0017 - Movement - (13.34 SQM)	Not Applicable	Circulation or storage space.