

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Tarro Public School (4263)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wallsend</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Newcastle</b>

4263 - Tarro Public School  
Site Plan (11977)



1:916

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Withdrawal Space - 1hb - (35.01 SQM)	 Student Space (16)	
B00A - R0004 - Practical Activities - 1hb - (11.47 SQM)	 Student Space (5)	
B00A - R0005 - Home Base - (95.27 SQM) - Teaching Space: 1	 Student Space (44)	
B00A - R0007 - Home Base - (65.91 SQM) - Teaching Space: 1	 Student Space (30)	
B00A - R0009 - Staff Room - (20.94 SQM)	 Office (5)	
B00A - R0010 - Movement - (7.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Home Base - (66.13 SQM) - Teaching Space: 1	 Student Space (30)	
B00A - R0013 - Home Base - (66.03 SQM) - Teaching Space: 1	 Student Space (30)	
B00A - R0016 - Clerical Office - (27.28 SQM)	 Office (6)	
B00A - R0017 - Principal - (17.89 SQM)	 Office (4)	
B00A - R0019 - Sick Bay - (7.54 SQM)	 Student Space (3)	
B00A - R0020 - Movement - (7.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Entry Vestibule - (10.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Reading Area - (80.12 SQM)	 Student Space (37)	
B00B - R0002 - Movement - (5.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Canteen - (22.18 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (19.38 SQM)	 Student Space (8)	
B00E - R0004 - Home Base - (58.81 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	 Student Space (4)	
B00E - R0006 - Home Base - (58.72 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0008 - Practical Activities - 1hb - (19.38 SQM)	 Student Space (8)	