


VENTILATION AUDIT REPORT

SCHOOL:	Tathra Public School (3173)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Bega
LOCAL GOVERNMENT AREA:	Bega Valley



3173 - Tathra Public School
Site Plan (12045)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (56.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (24.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (18.1 SQM)	Office (4)	
B00A - R0004 - Sick Bay - (8.66 SQM)	Student Space (4)	
B00A - R0006 - Interview - (13.05 SQM)	Office (3)	
B00A - R0007 - Deputy Principal - (13.05 SQM)	Office (3)	
B00A - R0009 - Movement - (23.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Principal - (16.53 SQM)	Office (4)	
B00A - R0016 - Duplicating Workroom - (20.93 SQM)	Office (5)	
B00A - R0017 - Staff Room - (58.97 SQM)	Office (14)	
B00A - R0019 - Staff Room Annexe - (5.03 SQM)	Office (1)	
B00B - R0006 - Home Base - (68.96 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0004 - Special Programs Room - (31.53 SQM)	Student Space (14)	
B00C - R0006 - Reading Area - (151.08 SQM)	Student Space (70)	
B00C - R0009 - Practical Activities - 1hb - (27.68 SQM)	Student Space (12)	
B00C - R0010 - Home Base - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0012 - Withdrawal Space - 1hb - (5.76 SQM)	Student Space (2)	
B00C - R0013 - Practical Activities - 1hb - (27.27 SQM)	Student Space (12)	
B00C - R0014 - Home Base - (50.63 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0016 - Withdrawal Space - 1hb - (5.73 SQM)	Student Space (2)	
B00C - R0017 - Movement - (163.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (62.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (54.5 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0004 - Practical Activities - 1hb - (19.56 SQM)	Student Space (9)	
B00E - R0006 - Withdrawal Space - 1hb - (5.59 SQM)	Student Space (2)	
B00E - R0007 - Movement - (59.59 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (14.04 SQM)	Student Space (6)	
B00F - R0006 - Practical Activities - 1hb - (23.44 SQM)	Student Space (10)	
B00F - R0012 - Home Base - (56.52 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0014 - Movement - (15.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Staff Room Annexe - (11.4 SQM)	Office (2)	
B00F - R0016 - Home Base - (56.55 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0018 - Movement - (15.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Movement - (33.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Staff Kitchen - (7.91 SQM)	Office (1)	
B00G - R0007 - Canteen - (27.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Movement - (6.82 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Raised Platform - (47.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00H - R0022 - Communal Space - (268.67 SQM)	Student Space (124)	
B00I - R0001 - Movement - (153.87 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Withdrawal Space - 1hb - (5.83 SQM)	Student Space (2)	
B00I - R0005 - Practical Activities - 1hb - (26.97 SQM)	Student Space (12)	
B00I - R0006 - Home Base - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00I - R0007 - Practical Activities - 1hb - (26.16 SQM)	Student Space (12)	
B00I - R0009 - Withdrawal Space - 1hb - (5.62 SQM)	Student Space (2)	
B00I - R0010 - Home Base - (50.7 SQM) - Teaching Space: 1	Student Space (23)	
B00K - R0002 - Canteen - (25.73 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Movement - (46.47 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0002 - Special Programs Room - (38.44 SQM)	 Student Space (17)	
OS 602 13948 - OS 602 13948 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	