

VENTILATION AUDIT REPORT





















SCHOOL:	Telegraph Point Public School (3176)
AMU REGION:	North Coast
STATE ELECTORATE:	Port Macquarie
LOCAL GOVERNMENT AREA:	Port Macquarie-Hastings

3176 - Telegraph Point Public School
Site Plan (10621)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0005 - Home Base - (47.37 SQM) - Teaching Space: 1	 Student Space (21)	
B002 - R0001 - Practical Activities - 1hb - (32.74 SQM)	 Student Space (15)	
B002 - R0002 - Canteen - (6.54 SQM)	Not Applicable	Circulation or storage space.
B002 - R0003 - Home Base - (52.49 SQM) - Teaching Space: 1	 Student Space (24)	
B002 - R0004 - Home Base - (52.56 SQM) - Teaching Space: 1	 Student Space (24)	
B002 - R0007 - Practical Activities - 1hb - (17.07 SQM)	 Student Space (7)	
B002 - R0008 - Home Base - (53.89 SQM) - Teaching Space: 1	 Student Space (25)	
B006 - R0002 - Practical Activities - 1hb - (19.39 SQM)	 Student Space (8)	
B006 - R0004 - Home Base - (58.85 SQM) - Teaching Space: 1	 Student Space (27)	
B006 - R0005 - Withdrawal Space - 2hb - (10.69 SQM)	 Student Space (4)	
B006 - R0006 - Home Base - (58.76 SQM) - Teaching Space: 1	 Student Space (27)	
B006 - R0008 - Practical Activities - 1hb - (19.39 SQM)	 Student Space (8)	
B007 - R0005 - Reading Area - (92.81 SQM)	 Student Space (43)	
OS 502 10766 - OS 502 10766 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	
OS 532 14678 - OS 532 14678 - Library - (114 SQM)	 Student Space (52)	
OS 602 11321 - OS 602 11321 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11499 - OS 602 11499 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12787 - OS 602 12787 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14209 - OS 602 14209 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15830 - OS 602 15830 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 19502 - OS 602 19502 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	