

VENTILATION AUDIT REPORT

SCHOOL:	Temora High School (8168)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Temora

8168 - Temora High School
Site Plan (11491)



1:1,444

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - General Learning Space - (49.71 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0006 - General Learning Space - (47.53 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0007 - General Learning Space - (49.57 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0008 - General Learning Space - (49.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0019 - General Learning Space - S/P - (50.04 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0020 - Pupil Entry - (6.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Commonroom - (17.53 SQM)	● Office (4)	
B00A - R0025 - Movement - (12.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (112.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (135.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (20.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Special Learning Space - (38.5 SQM) - Teaching Space: 1	● Student Space (17)	
B00A - R0032 - Withdrawal - S - (10.26 SQM)	● Student Space (4)	
B00A - R1002 - General Learning Space - (50.68 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1003 - Darkroom Space - (13.22 SQM)	● Office (3)	
B00A - R1004 - Computer Learning Space - (49.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1005 - Preparation - (13.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Laboratory L.S. - (86.26 SQM) - Teaching Space: 1	● Student Space (40)	
B00A - R1007 - Staff Study - (49.42 SQM)	● Office (12)	
B00A - R1012 - Interview/Meeting - (9.24 SQM)	● Office (2)	
B00A - R1013 - Movement - (47.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Movement - (134.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R1018 - Duplicating Workroom - (24.72 SQM)	● Office (6)	
B00A - R1019 - Movement - (6.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Movement - (20.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Laboratory L.S. - (104.62 SQM) - Teaching Space: 1	● Student Space (48)	
B00B - R0002 - Growing/Breeding - (8.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Preparation - (17.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Staff Study - (25.53 SQM)	● Office (6)	
B00B - R0014 - Movement - (80.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (26.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Art Learning Space - (67 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0018 - Darkroom Space - (10.59 SQM)	● Office (2)	
B00B - R0020 - Darkroom Space - (13.92 SQM)	● Office (3)	
B00B - R0022 - Workshop - (46.01 SQM)	● Student Space (21)	
B00B - R1004 - Computer Learning Space - (53.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1015 - Staff Study - (70.54 SQM)	● Office (17)	
B00B - R1016 - Movement - (23.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R1017 - Movement - (56.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R1019 - Art Learning Space - (60.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1020 - General Learning Space - (54.09 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0002 - General Learning Space - (44.49 SQM) - Teaching Space: 1	● Student Space (20)	
B00C - R0003 - General Learning Space - (44.35 SQM) - Teaching Space: 1	● Student Space (20)	
B00C - R0005 - Movement - (33.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Pupil Entry - (15.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (24.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Pupil Entry - (15.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Student Canteen - (58.26 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Pupil Entry - (9.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (8.52 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0012 - Practice/Seminar - (26.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Music Learning Space - (83.54 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R0014 - Movement - (69.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - General Learning Space - (62.8 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R0016 - Art Entry/Display - (8.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Movement - (18.2 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Seminar/Technology Space - (31.89 SQM)	○ Office (7)	
B00F - R0022 - Food Technology L.S. - (91.98 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0025 - Preparation - Materials - (15.48 SQM)	Not Applicable	Circulation or storage space.
B00H - M0001 - Stage - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00H - M0002 - Stage - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Staff Kitchen - (13.86 SQM)	○ Office (3)	
B00H - R0006 - Staff Study - (8.69 SQM)	○ Office (2)	
B00H - R0007 - Staff Study - (8.68 SQM)	○ Office (2)	
B00H - R0009 - Multi-Purpose Space - (457.46 SQM)	● Student Space (212)	
B00H - R0016 - Movement - (206.3 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Stage - (62.97 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - General Assistants - (22.58 SQM)	○ Office (5)	
B00L - R0001 - Laboratory L.S. - (91.62 SQM) - Teaching Space: 1	● Student Space (42)	
B00L - R0002 - General Learning Space - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0003 - Preparation - (43.72 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Interview/Office - Type 1 - (7.61 SQM)	○ Office (1)	
B00L - R0011 - Laboratory L.S. - (91.81 SQM) - Teaching Space: 1	● Student Space (42)	
B00L - R0013 - Movement - (152.12 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Main Area - (190.48 SQM)	Not Applicable	Circulation or storage space.
B00L - R1002 - Senior Study - (53.08 SQM)	○ Office (13)	
B00L - R1004 - Workroom - (7.64 SQM)	○ Office (1)	
B00L - R1005 - Workroom - (11.13 SQM)	○ Office (2)	
B00L - R1010 - Workroom - (12.42 SQM)	○ Office (3)	
B00L - R1011 - Audio Visual Workroom - (12.78 SQM)	● Student Space (5)	
B00L - R1012 - Seminar - (12.82 SQM)	○ Office (3)	
B00L - R1013 - Seminar - (12.82 SQM)	○ Office (3)	
B00L - R1014 - Movement - (35.3 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Interview/Office - Type 1 - (13.11 SQM)	○ Office (3)	
B00M - R0002 - Interview/Office - Type 1 - (11.9 SQM)	○ Office (2)	
B00M - R0003 - Public Entry - (10.58 SQM)	Not Applicable	Circulation or storage space.
B00M - R0006 - Clerical Office - (18.82 SQM)	○ Office (4)	
B00M - R0008 - Deputy Principal Office - (18.63 SQM)	○ Office (4)	
B00M - R0010 - Commonroom - (55.48 SQM)	○ Office (13)	
B00M - R0020 - Clinic-Waiting - (13.74 SQM)	○ Office (3)	
B00M - R0021 - Teachers Aides - (13.04 SQM)	○ Office (3)	
B00M - R0022 - Administration - Clerical - (19.6 SQM)	○ Office (4)	
B00M - R0023 - Movement - (61.03 SQM)	Not Applicable	Circulation or storage space.
B00M - R0024 - Movement - (7.87 SQM)	Not Applicable	Circulation or storage space.
B00M - R0025 - Movement - (19.69 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Staff Study - (31.26 SQM)	○ Office (7)	
B00N - R0002 - Seminar/Technology Space - (15.23 SQM)	○ Office (3)	
B00N - R0003 - Movement - (8.29 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Metal Technology Bay - (36.54 SQM)	Not Applicable	Circulation or storage space.
B00N - R0006 - Materials Technology L.S. - (85.67 SQM) - Teaching Space: 1	● Student Space (39)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0007 - Welding Area - (9.69 SQM)	Not Applicable	Circulation or storage space.
B00N - R0009 - Workshop - (64.01 SQM)	● Student Space (29)	
B00N - R0010 - Welding Area - (13.74 SQM)	Not Applicable	Circulation or storage space.
B00N - R0015 - Materials Technology L.S. - (105.61 SQM) - Teaching Space: 1	● Student Space (48)	
B00N - R0016 - Wood Technology Bay - (31.23 SQM)	Not Applicable	Circulation or storage space.
B00N - R0018 - Movement - (78.05 SQM)	Not Applicable	Circulation or storage space.
B00N - R0019 - Movement - (30.01 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Performance Workshop - (178.07 SQM)	● Student Space (82)	
B00P - R0002 - Outdoor Workshop - (61.27 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0002 - Workshop Area - (220.24 SQM)	● Student Space (102)	
B00S - R0001 - General Learning Space - (93.23 SQM) - Teaching Space: 1	● Student Space (43)	
B00T - R0001 - General Learning Space - (49.74 SQM) - Teaching Space: 1	● Student Space (23)	
B00T - R0002 - Materials Workshop - Type 2 - (39.17 SQM)	● Student Space (18)	
NS 111 15052 - NS 111 15052 - Learning Unit - Double Secondary/Secure - (114 SQM)	● Student Space (52)	