

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Temora Public School (3178)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Cootamundra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Temora</b>

3178 - Temora Public School  
Site Plan (12869)



Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (51.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Home Base - (53.13 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0010 - Home Base - (47.29 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0011 - Home Base - (47.25 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0012 - Home Base - (47.88 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0013 - Withdrawal Space - 1hb - (39.46 SQM)	● Student Space (18)	
B00A - R0015 - Duplicating Workroom - (31.97 SQM)	● Office (7)	
B00A - R0016 - Clerical Office - (19.72 SQM)	● Office (4)	
B00A - R0018 - Entry Vestibule - (10.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Principal - (19.79 SQM)	● Office (4)	
B00A - R0021 - Staff Room Annexe - (8.49 SQM)	● Office (2)	
B00A - R0022 - Staff Room Annexe - (9.61 SQM)	● Office (2)	
B00A - R0025 - Movement - (30.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Home Base - (47.76 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0027 - Home Base - (47.57 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0029 - Home Base - (46.63 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0031 - Movement - (73.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Home Base - (45.18 SQM) - Teaching Space: 1	● Student Space (20)	
B00A - R0034 - Movement - (16.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Special Programs Room - (20.92 SQM)	● Student Space (9)	
B00A - R0037 - Interview - (18.56 SQM)	● Office (4)	
B00A - R0040 - Movement - (5.13 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Communal Space - (161.17 SQM)	● Student Space (74)	
B00C - R0006 - Raised Platform - (20.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (85.59 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0006 - Home Base - (85.19 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0010 - Entry Vestibule - (13.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Staff Room Annexe - (12.67 SQM)	● Office (3)	
B00D - R1004 - Home Base - (56.78 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1005 - Home Base - (56.79 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1008 - Movement - (13.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R1009 - Home Base - (56.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1010 - Practical Activities - 1hb - (16.88 SQM)	● Student Space (7)	
B00D - R1012 - Movement - (8.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R1013 - Staff Room Annexe - (16.96 SQM)	● Office (4)	
B00F - R0001 - Staff Room - (54.74 SQM)	● Office (13)	
B00G - R0001 - Movement - (24.77 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Home Base - (46.85 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0003 - Home Base - (46.98 SQM) - Teaching Space: 1	● Student Space (21)	
B00H - R0002 - Home Base - (47.57 SQM) - Teaching Space: 1	● Student Space (22)	
B00J - R0001 - Reading Area - (164.8 SQM)	● Student Space (76)	
B00K - R0001 - Canteen - (26.81 SQM)	Not Applicable	Circulation or storage space.