


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Tenterfield High School (8358)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Lismore</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Tenterfield</b>

8358 - Tenterfield High School  
Site Plan (11496)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (51.17 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0002 - Movement - (15.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - General Learning Space - (54.24 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0005 - General Learning Space - (53.25 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0007 - Movement - (14.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - General Learning Space - (50.48 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0009 - Staff Study - (41.7 SQM)	● Office (10)	
B00B - R0001 - Movement - (36.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Commonroom - (75.62 SQM)	● Office (18)	
B00B - R0004 - Principal Office - (16.91 SQM)	● Office (4)	
B00B - R0005 - Duplicating Workroom - (21.06 SQM)	● Office (5)	
B00B - R0006 - Administration - Clerical - (18.45 SQM)	● Office (4)	
B00B - R0007 - Interview/Office - Type 1 - (12.98 SQM)	● Office (3)	
B00B - R0008 - Clinic - Boys - (14.24 SQM)	● Office (3)	
B00B - R0011 - Movement - (16.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Clinic - Girls - (14.02 SQM)	● Office (3)	
B00B - R0013 - Deputy Principal Office - (14.42 SQM)	● Office (3)	
B00B - R0015 - Public Entry - (6.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (53.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (90.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Movement - (35.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Computer Learning Space - (57.56 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0010 - Laboratory L.S. - (92.57 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0011 - Preparation - (38.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Laboratory L.S. - (92.8 SQM) - Teaching Space: 1	● Student Space (43)	
B00C - R0014 - General Learning Space - (52.99 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0018 - General Learning Space - (52.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0019 - Staff Study - (33.07 SQM)	● Office (8)	
B00C - R0024 - Movement - (26.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Movement - (194.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Movement - (5.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0029 - Movement - (14.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Movement - (42.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0034 - Movement - (23.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0035 - General Learning Space - (47.45 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1001 - General Learning Space - (52.83 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1002 - General Learning Space - (52.18 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1003 - Staff Study - (25.76 SQM)	● Office (6)	
B00C - R1004 - General Learning Space - (52.69 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1005 - General Learning Space - (52.39 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1006 - Staff Study - (25.98 SQM)	● Office (6)	
B00C - R1007 - Interview/Office - Type 1 - (12.84 SQM)	● Office (3)	
B00C - R1009 - Staff Study - (32.78 SQM)	● Office (8)	
B00C - R1010 - General Learning Space - (53.05 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1011 - General Learning Space - (58.38 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1015 - General Learning Space - (52.47 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1019 - Music Learning Space - (52.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1020 - Practice/Seminar - (33.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R1021 - Movement - (23.48 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1026 - Movement - (8.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R1030 - Movement - (159.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R9001 - Darkroom Space - (28.25 SQM)	Office (7)	
B00C - R9004 - Movement - (220.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R9006 - General Assistants - (32.88 SQM)	Office (8)	
B00C - R9015 - Student Canteen - (41.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R9020 - Movement - (29.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R9023 - Movement - (19.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Senior Study - (52.94 SQM)	Office (13)	
B00D - R0002 - Laboratory L.S. - (87.18 SQM) - Teaching Space: 1	Student Space (40)	
B00D - R0003 - Preparation - (31.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Workroom - (19.93 SQM)	Office (4)	
B00D - R0005 - Audio Visual Workroom - (19.08 SQM)	Student Space (8)	
B00D - R0006 - Main Area - (166.62 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (11.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Seminar - (12.21 SQM)	Office (3)	
B00D - R0010 - Seminar - (13.47 SQM)	Office (3)	
B00D - R0011 - Seminar - (12.63 SQM)	Office (3)	
B00D - R0012 - Movement - (113.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R9008 - Art Learning Space - (63.29 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R9012 - Movement - (30.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R9014 - Movement - (173.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Materials Technology L.S. - (120.39 SQM) - Teaching Space: 1	Student Space (55)	
B00E - R0004 - Materials Technology L.S. - (109.78 SQM) - Teaching Space: 1	Student Space (50)	
B00E - R0005 - Welding Area - (10.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Welding Area - (15.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Staff Study - (15.57 SQM)	Office (3)	
B00E - R0015 - Design L.S. - (59.9 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0019 - Movement - (78.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Movement - (8.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R1007 - Staff Study - (16.13 SQM)	Office (4)	
B00E - R1008 - Materials Technology L.S. - (77.19 SQM) - Teaching Space: 1	Student Space (35)	
B00E - R1015 - Movement - (54.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R1016 - Food Technology L.S. - (107.7 SQM) - Teaching Space: 1	Student Space (49)	
B00E - R1019 - Preparation - (12.81 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Staff Kitchen - (11.9 SQM)	Office (2)	
B00F - R0008 - Movement - (16.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Movement - (11.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (11.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Movement - (12.5 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Multi-Purpose Space - (455.08 SQM)	Student Space (211)	
B00F - R0017 - Stage - (84.29 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (21.89 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Workshop Area - (75.09 SQM)	Student Space (34)	