


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Teralba Public School (3183)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lake Macquarie</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

3183 - Teralba Public School  
Site Plan (11168)
















1:741

Printed: 12-Oct-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Principal - (12.82 SQM)	 Office (3)	
B00A - R0003 - Clerical Office - (13.03 SQM)	 Office (3)	
B00A - R0004 - Home Base - (51.95 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0006 - Home Base - (53.45 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0007 - Home Base - (52.23 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0008 - Home Base - (53.21 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0005 - Canteen - (12.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (14.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (14.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (53.43 SQM) - Teaching Space: 1	 Student Space (24)	
B00D - R0003 - Practical Activities - 1hb - (11.23 SQM)	 Student Space (5)	
B00D - R0004 - Home Base - (53.58 SQM) - Teaching Space: 1	 Student Space (24)	
B00D - R0005 - Practical Activities - 1hb - (22.41 SQM)	 Student Space (10)	
B00D - R0008 - Staff Room - (29.24 SQM)	 Office (7)	
B00D - R0011 - Movement - (6.73 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Reading Area - (91.95 SQM)	 Student Space (42)	
OS 508 10758 - OS 508 10758 - Administration - (114 SQM)	 Office (28)	