


VENTILATION AUDIT REPORT

SCHOOL:	Terara Public School (3185)
AMU REGION:	Southern NSW
STATE ELECTORATE:	South Coast
LOCAL GOVERNMENT AREA:	Shoalhaven

3185 - Terara Public School
Site Plan (11924)

















1:468

Printed: 14-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Home Base - (81.56 SQM) - Teaching Space: 1	 Student Space (37)	
B00A - R0005 - Withdrawal Space - 1hb - (20.88 SQM)	 Student Space (9)	
B00A - R0006 - Entry Vestibule - (9.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (10.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Principal - (14.26 SQM)	 Office (3)	
B00A - R0010 - Movement - (7.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Staff Kitchen - (13.28 SQM)	 Office (3)	
B00A - R0016 - Interview - (14.34 SQM)	 Office (3)	
B00A - R0017 - Clerical Office/Workroom - (14.31 SQM)	 Office (3)	
B00A - R0018 - Duplicating Workroom - (25.05 SQM)	 Office (6)	
B00A - R0019 - Staff Room - (11.52 SQM)	 Office (2)	
B00B - R0001 - Movement - (16.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Reading Area - (46.77 SQM)	 Student Space (21)	
B00C - R0003 - Reading Area - (46.65 SQM)	 Student Space (21)	
B00F - R0001 - Reading Area - (91.8 SQM)	 Student Space (42)	
OS 601 10479 - OS 601 10479 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13524 - OS 601 13524 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 16150 - OS 601 16150 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	