


VENTILATION AUDIT REPORT

SCHOOL:	Terranora Public School (3189)
AMU REGION:	North Coast
STATE ELECTORATE:	Tweed
LOCAL GOVERNMENT AREA:	Tweed

3189 - Terranora Public School
Site Plan (11337)











1:1,076

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (25.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Staff Room - (45.8 SQM)	 Office (11)	
B00A - R0003 - Staff Room Annexe - (19.59 SQM)	 Office (4)	
B00A - R0012 - Sick Bay - (8.69 SQM)	 Student Space (4)	
B00A - R0013 - Duplicating Workroom - (19.87 SQM)	 Office (4)	
B00A - R0014 - Clerical Office - (17.74 SQM)	 Office (4)	
B00A - R0015 - Interview - (12.09 SQM)	 Office (3)	
B00A - R0017 - Principal - (16.75 SQM)	 Office (4)	
B00A - R0018 - Deputy Principal - (13.15 SQM)	 Office (3)	
B00A - R0019 - Deputy Principal - (13.15 SQM)	 Office (3)	
B00A - R0020 - Movement - (8.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Entry Vestibule - (20.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (32.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (17.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (60.41 SQM) - Teaching Space: 1	 Student Space (28)	
B00D - R0003 - Practical Activities - 1hb - (14.69 SQM)	 Student Space (6)	
B00D - R0004 - Withdrawal Space - 1hb - (11.69 SQM)	 Student Space (5)	
B00D - R0006 - Movement - (49.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Practical Activities - 1hb - (14.99 SQM)	 Student Space (6)	
B00D - R0009 - Movement - (17.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Home Base - (60.03 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0001 - Movement - (17.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (56.32 SQM) - Teaching Space: 1	 Student Space (26)	
B00E - R0003 - Practical Activities - 1hb - (18.7 SQM)	 Student Space (8)	
B00E - R0004 - Withdrawal Space - 1hb - (12.18 SQM)	 Student Space (5)	
B00E - R0006 - Movement - (48.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Practical Activities - 1hb - (18.85 SQM)	 Student Space (8)	
B00E - R0009 - Movement - (17.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Home Base - (56.09 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0001 - Movement - (19.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Clerical Office - (25.45 SQM)	 Office (6)	
B00F - R0006 - Movement - (24.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Special Programs Room - (43.56 SQM)	 Student Space (20)	
B00F - R0009 - Reading Area - (116.79 SQM)	 Student Space (54)	
B00G - R0001 - Movement - (14.66 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Home Base - (59.85 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0003 - Practical Activities - 1hb - (13.21 SQM)	 Student Space (6)	
B00G - R0004 - Withdrawal Space - 1hb - (11.59 SQM)	 Student Space (5)	
B00G - R0006 - Movement - (73.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Home Base - (59.83 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0010 - Movement - (14.88 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Practical Activities - 1hb - (13.16 SQM)	 Student Space (6)	
B00H - R0001 - Movement - (17.91 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Home Base - (57 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R0003 - Practical Activities - 1hb - (18.29 SQM)	 Student Space (8)	
B00H - R0004 - Withdrawal Space - 1hb - (12.14 SQM)	 Student Space (5)	
B00H - R0006 - Movement - (75.73 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Practical Activities - 1hb - (18.19 SQM)	 Student Space (8)	
B00H - R0010 - Movement - (17.71 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0011 - Home Base - (56.85 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0001 - Movement - (55.64 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Raised Platform - (40.65 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Communal Space - (221.8 SQM)	● Student Space (102)	
B00J - R0009 - Movement - (142.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Movement - (139.81 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Canteen - (25.48 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (22.26 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Movement - (38.47 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00N - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00N - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00P - R0002 - Practical Activities - 1hb - (18.65 SQM)	● Student Space (8)	
B00P - R0004 - Home Base - (59.99 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R0005 - Withdrawal Space - 2hb - (11.5 SQM)	● Student Space (5)	
B00P - R0006 - Home Base - (59.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R0008 - Practical Activities - 1hb - (17.88 SQM)	● Student Space (8)	
B00P - R0009 - Practical Activities - 1hb - (19.82 SQM)	● Student Space (9)	
B00P - R0010 - Home Base - (57.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00P - R0012 - Withdrawal Space - 1hb - (8.8 SQM)	● Student Space (4)	
B00P - R1002 - Practical Activities - 1hb - (18.46 SQM)	● Student Space (8)	
B00P - R1004 - Home Base - (59.96 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R1005 - Withdrawal Space - 2hb - (11.61 SQM)	● Student Space (5)	
B00P - R1006 - Home Base - (59.66 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R1008 - Practical Activities - 1hb - (17.71 SQM)	● Student Space (8)	
B00P - R1009 - Practical Activities - 1hb - (19.79 SQM)	● Student Space (9)	
B00P - R1010 - Home Base - (58.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R1012 - Withdrawal Space - 1hb - (8.86 SQM)	● Student Space (4)	
OS 602 15992 - OS 602 15992 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 11429 - OS 603 11429 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	