



VENTILATION AUDIT REPORT

SCHOOL:	Terrigal High School (8533)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Terrigal
LOCAL GOVERNMENT AREA:	Central Coast

8533 - Terrigal High School
Site Plan (12871)



1:2,092































Printed: 27-Apr-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (46.04 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0002 - General Learning Space - (46.89 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0003 - General Learning Space - (46.89 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0004 - General Learning Space - (46.81 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0010 - Deputy Principal Office - (21.41 SQM)	Office (5)	
B00A - R0011 - Deputy Principal Office - (24.95 SQM)	Office (6)	
B00A - R0013 - General Learning Space - (46.16 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0014 - General Learning Space - (46.89 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0015 - General Learning Space - (46.96 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0016 - General Learning Space - (46.09 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0028 - Interview/Office - Type 1 - (13.86 SQM)	Office (3)	
B00A - R0029 - Leading Teacher - (13.99 SQM)	Office (3)	
B00A - R0030 - Administration - Executive - (16.44 SQM)	Office (4)	
B00A - R0032 - Clinic - (10.21 SQM)	Office (2)	
B00A - R0034 - Coffee Kiosk - (10.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Staff Study - (41.29 SQM)	Office (10)	
B00A - R0039 - Growing/Breeding - (22.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Laboratory L.S. - (79.17 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0042 - Preparation - Science - (45.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Laboratory L.S. - (79.17 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0045 - Laboratory L.S. - (79.17 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0046 - Preparation - Science - (47.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0047 - Laboratory L.S. - (79.35 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0048 - Performance Workspace - (42.33 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R0049 - Movement - (7.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0053 - Laboratory L.S. - (79.08 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0054 - Preparation - Science - (44.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Laboratory L.S. - (79.08 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0057 - Movement - (196.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0060 - General Assistants - (21.64 SQM)	Office (5)	
B00A - R0066 - Movement - (51.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0081 - Movement - (95.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0082 - Movement - (360.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0090 - Movement - (32.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0091 - Administration - Clerical - (75.31 SQM)	Office (18)	
B00A - R0097 - Staff Study - (20.17 SQM)	Office (5)	
B00A - R0099 - Movement - (78.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0101 - Special Learning Space - (10.84 SQM) - Teaching Space: 1	Student Space (5)	
B00A - R1001 - General Learning Space - (46.18 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1002 - General Learning Space - (46.04 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1003 - General Learning Space - (45.91 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1004 - General Learning Space - (45.97 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1008 - General Learning Space - (45.84 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1009 - General Learning Space - (45.97 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1010 - General Learning Space - (46.33 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1011 - General Assistants - (45.97 SQM)	Office (11)	
B00A - R1015 - Ancillary Staff - (28.54 SQM)	Office (7)	
B00A - R1016 - Principal Office - (20.24 SQM)	Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1017 - Deputy Principal Office - (21.38 SQM)	Office (5)	
B00A - R1018 - Leading Teacher - (11.21 SQM)	Office (2)	
B00A - R1019 - Interview/Office - Type 1 - (11.14 SQM)	Office (2)	
B00A - R1025 - Movement - (104.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R1034 - Movement - (9.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R1038 - Staff Study - (25.16 SQM)	Office (6)	
B00A - R1039 - Staff Study - (21.67 SQM)	Office (5)	
B00A - R1040 - Interview/Office - Type 1 - (11.11 SQM)	Office (2)	
B00A - R1041 - Interview/Office - Type 1 - (22.56 SQM)	Office (5)	
B00A - R1046 - Staff Study - (25.54 SQM)	Office (6)	
B00A - R1047 - Staff Study - (21.64 SQM)	Office (5)	
B00A - R1052 - Movement - (85.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1054 - Movement - (84.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R1055 - Performance Workspace - (66.47 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0001 - General Learning Space - (45.97 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0002 - General Learning Space - (46.11 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0003 - General Learning Space - (45.97 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0004 - General Learning Space - (45.97 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0010 - General Learning Space - (46.11 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0011 - General Learning Space - (45.97 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0012 - General Learning Space - (45.97 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0013 - General Learning Space - (45.9 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0018 - Main Area - (419.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Seminar - (10.97 SQM)	Office (2)	
B00B - R0020 - Seminar - (10.89 SQM)	Office (2)	
B00B - R0021 - Seminar - (10.55 SQM)	Office (2)	
B00B - R0023 - Computer Learning Space - (47.3 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0027 - Movement - (18.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Food Technology L.S. - (102.59 SQM) - Teaching Space: 1	Student Space (47)	
B00B - R0032 - Food Technology L.S. - (100.72 SQM) - Teaching Space: 1	Student Space (46)	
B00B - R0035 - Preparation - Materials - (13.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0036 - Tea Room - (13.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0037 - Art Learning Space - (58.19 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0038 - Art Learning Space - (57.82 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0039 - Computer Learning Space - (45.43 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0041 - Art Learning Space - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0042 - Art Learning Space - (56.58 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0043 - Staff Study - (27.1 SQM)	Office (6)	
B00B - R0049 - Seminar - Type 1 - (16.28 SQM)	Office (4)	
B00B - R0050 - Movement - (52.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0074 - Staff Study - (24.67 SQM)	Office (6)	
B00B - R0075 - Staff Study - (21.73 SQM)	Office (5)	
B00B - R0079 - Movement - (358.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0080 - Movement - (136.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R0083 - Movement - (94.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0085 - Movement - (95.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - General Learning Space - (46.11 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1004 - General Learning Space - (46.11 SQM) - Teaching Space: 1	Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1005 - General Learning Space - (45.98 SQM) - Teaching Space: 1	 Student Space (21)	
B00B - R1006 - General Learning Space - (46.32 SQM) - Teaching Space: 1	 Student Space (21)	
B00B - R1010 - Staff Lounge - (21.29 SQM)	 Office (5)	
B00B - R1013 - General Learning Space - (46.04 SQM) - Teaching Space: 1	 Student Space (21)	
B00B - R1014 - General Learning Space - (46.18 SQM) - Teaching Space: 1	 Student Space (21)	
B00B - R1015 - General Assistants - (45.97 SQM)	 Office (11)	
B00B - R1016 - General Learning Space - (46.04 SQM) - Teaching Space: 1	 Student Space (21)	
B00B - R1028 - Design/Technology L.S. - (69.65 SQM) - Teaching Space: 1	 Student Space (32)	
B00B - R1029 - Textiles Technology L.S. - (69.45 SQM) - Teaching Space: 1	 Student Space (32)	
B00B - R1032 - Staff Study - (25.58 SQM)	 Office (6)	
B00B - R1034 - Movement - (69.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R1036 - Senior Study - (22.8 SQM)	 Office (5)	
B00B - R1037 - Movement - (31.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R1038 - Performance Workshop - (32.78 SQM)	 Student Space (15)	
B00B - R1039 - Movement Studio - (109.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R1041 - Staff Study - (25.71 SQM)	 Office (6)	
B00B - R1042 - Staff Study - (21.72 SQM)	 Office (5)	
B00B - R1044 - Staff Study - (25.5 SQM)	 Office (6)	
B00B - R1045 - Staff Study - (21.66 SQM)	 Office (5)	
B00B - R1053 - Movement - (85.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R1055 - Movement - (85.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R1057 - Movement - (85.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Multi-Purpose Space - (465.46 SQM)	 Student Space (215)	
B00C - R0007 - Stage - (99.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Tea Room - (11.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Staff Study - (21.78 SQM)	 Office (5)	
B00C - R0019 - Music Learning Space - (77.04 SQM) - Teaching Space: 1	 Student Space (35)	
B00C - R0023 - Movement - (15.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Student Canteen - (57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0043 - Welding Area - (15.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0044 - Metal Technology L.S. - (79.26 SQM) - Teaching Space: 1	 Student Space (36)	
B00C - R0045 - Welding Area - (5.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0060 - Music Learning Space - (53.9 SQM) - Teaching Space: 1	 Student Space (25)	
B00C - R0063 - Movement - (61.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0064 - Music Learning Space - (52.94 SQM) - Teaching Space: 1	 Student Space (24)	
B00C - R0066 - Movement - (201.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0067 - Metal Technology L.S. - (88.79 SQM) - Teaching Space: 1	 Student Space (41)	
B00C - R0070 - Wood Technology L.S. - (116.58 SQM) - Teaching Space: 1	 Student Space (54)	
B00C - R0072 - Wood Technology L.S. - (104.62 SQM) - Teaching Space: 1	 Student Space (48)	
B00C - R0074 - Movement - (88.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Staff Study - (22.55 SQM)	 Office (5)	
B00C - R1002 - Computer Learning Space - (48.54 SQM) - Teaching Space: 1	 Student Space (22)	
B00C - R1003 - Design L.S. - (50.36 SQM) - Teaching Space: 1	 Student Space (23)	
B00C - R1004 - Staff Study - (22.17 SQM)	 Office (5)	
B00C - R1005 - Movement - (43.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R1021 - Staff Study - (11.3 SQM)	 Office (2)	