

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Terrigal Public School (3191)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Terrigal</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

3191 - Terrigal Public School  
Site Plan (11935)



1:927

Printed: 01-Jun-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (12.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Home Base - (62.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0003 - Practical Activities - 1hb - (12.54 SQM)	● Student Space (5)	
B00A - R0004 - Practical Activities - 1hb - (12.55 SQM)	● Student Space (5)	
B00A - R0005 - Home Base - (62.1 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0006 - Movement - (52.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (10.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Home Base - (62.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0010 - Practical Activities - 1hb - (12.55 SQM)	● Student Space (5)	
B00A - R0011 - Practical Activities - 1hb - (12.54 SQM)	● Student Space (5)	
B00A - R0012 - Home Base - (62.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0013 - Movement - (12.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (33.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Home Base - (63.36 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R1007 - Practical Activities - 1hb - (11.41 SQM)	● Student Space (5)	
B00A - R1008 - Movement - (27.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Movement - (27.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Movement - (11.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Home Base - (63.43 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R1017 - Practical Activities - 1hb - (11.12 SQM)	● Student Space (5)	
B00A - R1018 - Movement - (26.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (12.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (62.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0003 - Practical Activities - 1hb - (12.55 SQM)	● Student Space (5)	
B00B - R0004 - Practical Activities - 1hb - (12.55 SQM)	● Student Space (5)	
B00B - R0005 - Home Base - (62.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0006 - Movement - (50.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (9.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Home Base - (62.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0010 - Practical Activities - 1hb - (12.55 SQM)	● Student Space (5)	
B00B - R0011 - Practical Activities - 1hb - (12.55 SQM)	● Student Space (5)	
B00B - R0012 - Home Base - (62.1 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0013 - Movement - (12.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Withdrawal Space - 1hb - (14.08 SQM)	● Student Space (6)	
B00B - R1006 - Home Base - (63.37 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R1007 - Practical Activities - 1hb - (11.4 SQM)	● Student Space (5)	
B00B - R1008 - Movement - (27.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R1009 - Movement - (10.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Movement - (27.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R1016 - Home Base - (63.44 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R1017 - Practical Activities - 1hb - (11.12 SQM)	● Student Space (5)	
B00C - R0001 - Movement - (12.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (62.08 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0003 - Practical Activities - 1hb - (12.54 SQM)	● Student Space (5)	
B00C - R0004 - Practical Activities - 1hb - (12.54 SQM)	● Student Space (5)	
B00C - R0005 - Home Base - (62.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0006 - Movement - (12.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Home Base - (63.71 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R1007 - Practical Activities - 1hb - (11.27 SQM)	● Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1008 - Movement - (27.54 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (15.62 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (85.01 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0003 - Practical Activities - 1hb - (12.5 SQM)	● Student Space (5)	
B00D - R0004 - Practical Activities - 1hb - (12.5 SQM)	● Student Space (5)	
B00D - R0005 - Home Base - (85.01 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0006 - Movement - (15.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (14 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (14.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Movement - (41.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R1008 - Seminar/Study - (15.93 SQM)	○ Office (3)	
B00D - R1009 - Home Base - (92.93 SQM) - Teaching Space: 1	● Student Space (43)	
B00D - R1010 - Practical Activities - 1hb - (11.19 SQM)	● Student Space (5)	
B00E - M0002 - Movement - (22.61 SQM)	Not Applicable	Circulation or storage space.
B00E - M0003 - Communal Space - (103.97 SQM)	● Student Space (48)	
B00E - M0005 - Movement - (9.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Communal Space - (218.6 SQM)	● Student Space (101)	
B00E - R0006 - Raised Platform - (82.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Canteen - (47.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (124.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Interview - (10.53 SQM)	○ Office (2)	
B00F - R0002 - Principal - (21.16 SQM)	○ Office (5)	
B00F - R0003 - Sick Bay - (13.01 SQM)	● Student Space (6)	
B00F - R0004 - Clerical Office - (12.92 SQM)	○ Office (3)	
B00F - R0005 - Entry Vestibule - (9.32 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Interview - (13.06 SQM)	○ Office (3)	
B00F - R0007 - Deputy Principal - (14.23 SQM)	○ Office (3)	
B00F - R0009 - Movement - (39.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (38.8 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (11.96 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Duplicating Workroom - (18.14 SQM)	○ Office (4)	
B00F - R0016 - Staff Room Annexe - (9.15 SQM)	○ Office (2)	
B00F - R0017 - Staff Room - (75.61 SQM)	○ Office (18)	
B00F - R1002 - Reading Area - (264.05 SQM)	● Student Space (122)	
B00F - R1004 - Interview - (14.46 SQM)	○ Office (3)	
B00F - R1005 - Interview - (12.43 SQM)	○ Office (3)	
B00G - R0001 - Home Base - (57.42 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0002 - Practical Activities - 1hb - (7.2 SQM)	● Student Space (3)	
B00G - R0004 - Movement - (12.51 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Practical Activities - 1hb - (7.49 SQM)	● Student Space (3)	
B00G - R0006 - Home Base - (57.5 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0007 - Home Base - (63.16 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R0008 - Practical Activities - 1hb - (8.51 SQM)	● Student Space (3)	
B00G - R0009 - Withdrawal Space - 1hb - (18.54 SQM)	● Student Space (8)	
B00G - R0013 - Movement - (58.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Movement - (12.09 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Practical Activities - (14.08 SQM)	● Student Space (6)	
B00J - R0003 - Home Base - (60.1 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (11.57 SQM)	● Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0006 - Home Base - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0009 - Practical Activities - (13.69 SQM)	Student Space (6)	
B00J - R0010 - Home Base - P - (57.49 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0012 - Withdrawal - P - (9.42 SQM)	Student Space (4)	
B00J - R0013 - Practical Activities - P - 2hb - (38.11 SQM)	Student Space (17)	
B00J - R0018 - Home Base - P - (57.28 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0020 - Withdrawal - P - (9.39 SQM)	Student Space (4)	
B00J - R0021 - Practical Activities - (15.65 SQM)	Student Space (7)	
B00J - R0022 - Withdrawal Space - 1hb - (8.73 SQM)	Student Space (4)	
B00J - R0024 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00L - R0001 - Home Base - (68.43 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R0002 - Withdrawal Space - 1hb - (8.26 SQM)	Student Space (3)	
B00L - R0003 - Practical Activities - 1hb - (18.43 SQM)	Student Space (8)	
B00L - R0004 - Home Base - (65.01 SQM) - Teaching Space: 1	Student Space (30)	
B00L - R0005 - Withdrawal Space - 1hb - (8.28 SQM)	Student Space (3)	
B00L - R0006 - Practical Activities - 1hb - (16.97 SQM)	Student Space (7)	
B00L - R0008 - Entry Vestibule - (15.62 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Interview - (11.93 SQM)	Office (2)	
B00L - R0010 - Interview - (14.33 SQM)	Office (3)	
B00L - R0011 - Principal - (15.94 SQM)	Office (3)	
B00L - R0012 - Deputy Principal - (12.29 SQM)	Office (3)	
B00L - R0013 - Deputy Principal - (12.15 SQM)	Office (3)	
B00L - R0014 - Deputy Principal - (11.55 SQM)	Office (2)	
B00L - R0015 - Staff Kitchen - (5.02 SQM)	Office (1)	
B00L - R0019 - Movement - (42.85 SQM)	Not Applicable	Circulation or storage space.
B00L - R0022 - Sick Bay - (9.99 SQM)	Student Space (4)	
B00L - R0023 - Clerical/Printing - (25.21 SQM)	Not Applicable	Circulation or storage space.
B00L - R0024 - Clerical Office - (24.49 SQM)	Office (6)	
B00L - R0027 - Clerical Office - (8.35 SQM)	Office (2)	
B00L - R0032 - Clerical Office - (10.43 SQM)	Office (2)	
B00L - R1001 - Home Base - (57.58 SQM) - Teaching Space: 1	Student Space (26)	
B00L - R1002 - Home Base - (60.35 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R1003 - Withdrawal Space - 2hb - (11.86 SQM)	Student Space (5)	
B00L - R1004 - Home Base - (59.71 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R1005 - Home Base - (60.84 SQM) - Teaching Space: 1	Student Space (28)	
B00L - R1006 - Withdrawal Space - 2hb - (11.88 SQM)	Student Space (5)	
B00L - R1007 - Practical Activities - 4hb - (107.11 SQM)	Student Space (49)	
B00L - R1009 - Home Base - (61.39 SQM) - Teaching Space: 1	Student Space (28)	
B00L - R1010 - Home Base - (58.29 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R1011 - Withdrawal Space - 2hb - (11.88 SQM)	Student Space (5)	
B00L - R1012 - Home Base - (59.06 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R1013 - Home Base - (62.59 SQM) - Teaching Space: 1	Student Space (29)	
B00L - R1014 - Withdrawal Space - 2hb - (9.49 SQM)	Student Space (4)	
B00L - R1015 - Practical Activities/Movement - 4hb - (76.23 SQM)	Student Space (35)	
B00L - R1018 - Breakout Area - (16.85 SQM)	Not Applicable	Circulation or storage space.
B00L - R1019 - Movement - (19.06 SQM)	Not Applicable	Circulation or storage space.
B00L - R1022 - Movement - (17.78 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R1023 - Movement - (26.01 SQM)	Not Applicable	Circulation or storage space.
OS 602 13938 - OS 602 13938 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19055 - OS 606 19055 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	