


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Teven-Tintenbar Public School (4578)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Ballina</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Ballina</b>

4578 - Teven-Tintenbar Public School  
Site Plan (11338)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (8.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Sick Bay - (5.81 SQM)	● Student Space (2)	
B00A - R0006 - Principal - (12.84 SQM)	● Office (3)	
B00A - R0007 - Clerical Office - (24.17 SQM)	● Office (6)	
B00A - R0008 - Entry Vestibule - (10.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (11.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Staff Room - (36.74 SQM)	● Office (9)	
B00A - R0011 - Interview - (7.49 SQM)	● Office (1)	
B00B - R0001 - Canteen - (11.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Home Base - (61.93 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0004 - Practical Activities - 1hb - (22.11 SQM)	● Student Space (10)	
B00C - R0005 - Withdrawal Space - 1hb - (13.32 SQM)	● Student Space (6)	
B00C - R0006 - Home Base - (62 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0007 - Practical Activities - 1hb - (22.22 SQM)	● Student Space (10)	
B00C - R0009 - Reading Area - (72.28 SQM)	● Student Space (33)	
B00C - R0013 - Home Base - (62 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0014 - Practical Activities - 1hb - (22.3 SQM)	● Student Space (10)	
B00C - R0015 - Withdrawal Space - 1hb - (13.27 SQM)	● Student Space (6)	
B00C - R0016 - Home Base - (61.92 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0017 - Practical Activities - 1hb - (22.31 SQM)	● Student Space (10)	
B00C - R0023 - Special Programs Room - (84.49 SQM)	● Student Space (39)	
B00F - R0002 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00F - R0004 - Home Base - (58.91 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0005 - Withdrawal Space - 2hb - (10.7 SQM)	● Student Space (4)	
B00F - R0006 - Home Base - (58.82 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
OS 602 16356 - OS 602 16356 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19435 - OS 602 19435 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	