




































VENTILATION AUDIT REPORT

SCHOOL:	The Forest High School (8372)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Wakehurst
LOCAL GOVERNMENT AREA:	Northern Beaches



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Laboratory L.S. - (85.97 SQM) - Teaching Space: 1	 Student Space (39)	
B00A - R0003 - Preparation - Science - (16.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Preparation - Science - (16.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Laboratory L.S. - (79.49 SQM) - Teaching Space: 1	 Student Space (36)	
B00A - R0007 - Staff Study - (24.11 SQM)	 Office (6)	
B00A - R0009 - Food Technology L.S. - (66.82 SQM) - Teaching Space: 1	 Student Space (31)	
B00A - R0010 - Preparation - Materials - (12.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (153.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Staff Lounge - (23.74 SQM)	 Office (5)	
B00A - R0029 - Staff Study - (25.85 SQM)	 Office (6)	
B00A - R0030 - Food Technology L.S. - (91.07 SQM) - Teaching Space: 1	 Student Space (42)	
B00A - R1001 - Design L.S. - (66.93 SQM) - Teaching Space: 1	 Student Space (31)	
B00A - R1006 - General Learning Space - (69.6 SQM) - Teaching Space: 1	 Student Space (32)	
B00A - R1010 - General Learning Space - (53.6 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R1014 - General Learning Space - (52.73 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R1015 - General Learning Space - (53.39 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R1016 - Movement - (109.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Movement - (8.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R1021 - Staff Study - (46.05 SQM)	 Office (11)	
B00A - R1023 - Performance Workshop - (106.92 SQM)	 Student Space (49)	
B00A - R1024 - Stage - (22.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Student Canteen - (44.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Design/Technology L.S. - (75.27 SQM) - Teaching Space: 1	 Student Space (34)	
B00C - R0017 - Welding Area - (9.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Metal Technology Bay - (15.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (80.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Materials Technology L.S. - (78.95 SQM) - Teaching Space: 1	 Student Space (36)	
B00C - R0023 - Computer Learning Space - (33.91 SQM) - Teaching Space: 1	 Student Space (15)	
B00C - R0024 - Wood Technology L.S. - (79.34 SQM) - Teaching Space: 1	 Student Space (36)	
B00C - R0026 - Metal Technology L.S. - (78.21 SQM) - Teaching Space: 1	 Student Space (36)	
B00C - R0028 - Materials Technology L.S. - (78.87 SQM) - Teaching Space: 1	 Student Space (36)	
B00C - R0030 - Staff Study - (36.22 SQM)	 Office (9)	
B00D - R0006 - Deputy Principal Office - (14.68 SQM)	 Office (3)	
B00D - R0007 - General Assistants - (9.38 SQM)	 Office (2)	
B00D - R0011 - Principal Office - (20.54 SQM)	 Office (5)	
B00D - R0015 - Interview/Office - Type 1 - (10.81 SQM)	 Office (2)	
B00D - R0020 - Leading Teacher - (7.84 SQM)	 Office (1)	
B00D - R0022 - Deputy Principal Office - (12.68 SQM)	 Office (3)	
B00D - R0023 - Clinic - (18.46 SQM)	 Office (4)	
B00D - R0025 - Art Learning Space - (80.5 SQM) - Teaching Space: 1	 Student Space (37)	
B00D - R0039 - Movement - (15.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R0040 - Public Reception - (30.71 SQM)	Not Applicable	Circulation or storage space.
B00D - R0042 - Administration - Clerical - (29.16 SQM)	 Office (7)	
B00D - R0046 - Ancillary Staff - (12.05 SQM)	 Office (3)	
B00D - R0048 - Administration - Clerical - (30.67 SQM)	 Office (7)	
B00D - R0049 - Administration - Clerical - (6.76 SQM)	 Office (1)	
B00D - R0050 - Art Learning Space - (64.15 SQM) - Teaching Space: 1	 Student Space (29)	
B00D - R0052 - Movement - (128.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0053 - Student Waiting - (6.57 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1001 - General Learning Space - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1008 - Music Learning Space - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1010 - Music Learning Space - (67.15 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R1013 - Music Learning Space - (53.02 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1015 - Computer Learning Space - (66.95 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R1017 - General Learning Space - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1018 - Movement - (106.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R1021 - Staff Study - (39.91 SQM)	● Office (9)	
B00D - R1023 - Commonroom - (83.09 SQM)	● Office (20)	
B00D - R1024 - Staff Kitchen - (12.13 SQM)	● Office (3)	
B00E - R0001 - Laboratory L.S. - (85.41 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0002 - Preparation - Science - (42.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - General Learning Space - (53.39 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0005 - Design L.S. - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0006 - Special Learning Space - (39.34 SQM) - Teaching Space: 1	● Student Space (18)	
B00E - R0012 - Special Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0013 - General Learning Space - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0014 - Movement - (151.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - General Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1002 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1003 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1004 - General Learning Space - (52.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1005 - General Learning Space - (53.39 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1006 - General Learning Space - (53.83 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1007 - Computer Learning Space - (49.29 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R1011 - Staff Study - (78.9 SQM)	● Office (19)	
B00E - R1014 - General Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1015 - Movement - (109.63 SQM)	Not Applicable	Circulation or storage space.
B00F - M0001 - Movement - (5.39 SQM)	Not Applicable	Circulation or storage space.
B00F - M0003 - Movement - (9.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Staff Kitchen - (13.61 SQM)	● Office (3)	
B00F - R0005 - Multi-Purpose Space - (388.61 SQM)	● Student Space (180)	
B00F - R0006 - Stage - (98.35 SQM)	Not Applicable	Circulation or storage space.
B00F - R9012 - Movement - (14.12 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Laboratory L.S. - (92.3 SQM) - Teaching Space: 1	● Student Space (42)	
B00G - R0002 - Preparation - Science - (28.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Laboratory L.S. - (92.44 SQM) - Teaching Space: 1	● Student Space (42)	
B00G - R0005 - Staff Study - (54.9 SQM)	● Office (13)	
B00G - R0010 - Preparation - Science - (28.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Laboratory L.S. - (92.44 SQM) - Teaching Space: 1	● Student Space (42)	
B00G - R0021 - Staff Study - (10.88 SQM)	● Office (2)	
B00G - R0032 - Art Learning Space - (52.37 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0033 - Art Learning Space - (52.22 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0034 - Movement - (225.68 SQM)	Not Applicable	Circulation or storage space.
B00G - R0035 - Staff Study - (30.31 SQM)	● Office (7)	
B00G - R0038 - Darkroom Space - (6.22 SQM)	● Office (1)	
B00G - R0039 - Dark Room - (25.75 SQM)	● Office (6)	
B00G - R1003 - General Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1005 - General Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1007 - General Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1013 - Staff Study - (34.06 SQM)	● Office (8)	
B00G - R1016 - Computer Learning Space - (64.99 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R1021 - General Learning Space - (60.66 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R1022 - General Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1023 - General Learning Space - (52.3 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1024 - General Learning Space - (60.58 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R1025 - Movement - (254.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R1030 - Staff Study - (45.73 SQM)	● Office (11)	
B00G - R9017 - Movement - (29.86 SQM)	Not Applicable	Circulation or storage space.
B00G - R9021 - Performance Workshop - (193.71 SQM)	● Student Space (89)	
B00H - M0003 - Main Area - (108.57 SQM)	Not Applicable	Circulation or storage space.
B00H - M0006 - Movement - (5.35 SQM)	Not Applicable	Circulation or storage space.
B00H - M0008 - Seminar - (11.95 SQM)	● Office (2)	
B00H - M0009 - Seminar - (16.94 SQM)	● Office (4)	
B00H - M0010 - Seminar - (32.68 SQM)	● Office (8)	
B00H - R0003 - Audio Visual Workroom - (42.42 SQM)	● Student Space (19)	
B00H - R0005 - Main Area - (197.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Main Entry - (18.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Main Area - (224.61 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (5.64 SQM)	Not Applicable	Circulation or storage space.
B00H - R9005 - Fitness Laboratory - (101.78 SQM)	● Student Space (47)	
B00H - R9006 - Movement - (15.48 SQM)	Not Applicable	Circulation or storage space.
B00I - R0010 - Multi-Purpose Space - (523.61 SQM)	● Student Space (242)	
B00I - R0011 - Movement - (17.94 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Staff Study - (22.59 SQM)	● Office (5)	