

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>The Henry Lawson High School (8314)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Cootamundra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Weddin</b>

8314 - The Henry Lawson High School  
Site Plan (11906)













1:1,597

Printed: 13-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Commonroom - (70.39 SQM)	Office (17)	
B00A - R0002 - Interview/Office - Type 1 - (21.76 SQM)	Office (5)	
B00A - R0003 - Principal Office - (22.25 SQM)	Office (5)	
B00A - R0007 - Duplicating Workroom - (12.31 SQM)	Office (3)	
B00A - R0008 - Staff Study - (12.33 SQM)	Office (3)	
B00A - R0009 - Clinic - Boys - (9.67 SQM)	Office (2)	
B00A - R0012 - Administration - Clerical - (14.04 SQM)	Office (3)	
B00A - R0015 - Administration - Clerical - (19.89 SQM)	Office (4)	
B00A - R0016 - Deputy Principal Office - (17.36 SQM)	Office (4)	
B00A - R0017 - Movement - (51.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Audio Visual Workroom - (12.1 SQM)	Student Space (5)	
B00A - R1004 - Audio Visual Workroom - (12.03 SQM)	Student Space (5)	
B00A - R1009 - Workroom - (9.3 SQM)	Office (2)	
B00A - R1011 - Entry - (30.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Main Area - (152.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Seminar - (56.1 SQM)	Office (14)	
B00A - R1016 - Audio Visual Workroom - (26.15 SQM)	Student Space (12)	
B00B - R0004 - Materials Technology L.S. - (66.49 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0011 - Darkroom Space - (12.35 SQM)	Office (3)	
B00B - R0013 - Preparation - Materials - (15.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Kitchen - Type 1 - (106.11 SQM)	Student Space (49)	
B00B - R1001 - General Learning Space - (66.42 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1002 - General Learning Space - (66.61 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1003 - Stage - (32.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R1006 - Staff Study - (40.71 SQM)	Office (10)	
B00B - R1007 - Interview/Office - Type 1 - (8.28 SQM)	Office (2)	
B00C - R0001 - Seminar - (24.71 SQM)	Office (6)	
B00C - R0004 - General Assistants - (6.22 SQM)	Office (1)	
B00C - R0006 - Movement - (20.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Student Canteen - (50.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (312.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Multi-Purpose Space - (307.81 SQM)	Student Space (142)	
B00C - R0016 - Stage - (90.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R9002 - Staff Study - (11.93 SQM)	Office (2)	
B00C - R9009 - Movement - (13.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Art Learning Space - (63.18 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0005 - Staff Study - (22.13 SQM)	Office (5)	
B00D - R0016 - Darkroom Space - (21.59 SQM)	Office (5)	
B00D - R0018 - Computer Learning Space - (83.17 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R1001 - Music Learning Space - (53.37 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1005 - Staff Study - (23.4 SQM)	Office (5)	
B00D - R1006 - Staff Study - (21.01 SQM)	Office (5)	
B00D - R1017 - General Learning Space - (52.09 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1019 - Practice/Seminar - (11.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R1020 - Music Learning Space - (53.56 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1021 - General Learning Space - (52.9 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0001 - Laboratory L.S. - (90.9 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0003 - Preparation - (34.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Laboratory L.S. - (90.89 SQM) - Teaching Space: 1	Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1003 - General Learning Space - (55.98 SQM) - Teaching Space: 1	 Student Space (25)	
B00E - R1005 - General Learning Space - (57.84 SQM) - Teaching Space: 1	 Student Space (26)	
B00E - R1009 - Computer Learning Space - (97.62 SQM) - Teaching Space: 1	 Student Space (45)	
B00F - R0001 - Laboratory L.S. - (89.67 SQM) - Teaching Space: 1	 Student Space (41)	
B00F - R0003 - Movement - (25.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Preparation - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Welding Area - (12.51 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Metal Technology Bay - (372.56 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Senior Study - (32.49 SQM)	 Office (8)	
B00I - R0001 - General Learning Space - Type 10 - (59.93 SQM) - Teaching Space: 0.5	 Student Space (27)	
B00I - R0002 - Science Laboratory - (60.01 SQM)	 Student Space (27)	
B00I - R0003 - Preparation - (30.28 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Staff Study - (16.18 SQM)	 Office (4)	
B00I - R0005 - Seminar - Type 2 - (21.03 SQM)	 Office (5)	
B00I - R0007 - Movement - (6.24 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Workshop Area - (89.4 SQM)	 Student Space (41)	