

VENTILATION AUDIT REPORT

SCHOOL:	The Hills Sports High School (8412)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Seven Hills
LOCAL GOVERNMENT AREA:	Blacktown

8412 - The Hills Sports High School
Site Plan (12676)



1:1,966

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Commonroom - (85.23 SQM)	Office (21)	
B00A - R0022 - General Learning Space - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0024 - Staff Study - (13.74 SQM)	Office (3)	
B00A - R0025 - Food/Research Space - (12.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Food Technology L.S. - (67.56 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0030 - Food Technology L.S. - (79.17 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0031 - Darkroom Space - (32.14 SQM)	Office (8)	
B00A - R0033 - General Assistants - (17.53 SQM)	Office (4)	
B00A - R0040 - Deputy Principal Office - (20.87 SQM)	Office (5)	
B00A - R0058 - Clinic - Boys - (9.97 SQM)	Office (2)	
B00A - R0060 - Movement - (12.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - Interview/Meeting - (13.6 SQM)	Office (3)	
B00A - R0062 - Interview/Meeting - (13.49 SQM)	Office (3)	
B00A - R0064 - Administration - Clerical - (60.68 SQM)	Office (15)	
B00A - R0066 - Administration - Clerical - (8.66 SQM)	Office (2)	
B00A - R0068 - Movement - (35.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0069 - Public Reception - (24.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0070 - Principal Office - (24.75 SQM)	Office (6)	
B00A - R0071 - Tea Room - (8.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0074 - Student Waiting - (11.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0076 - Movement - (270.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0077 - Deputy Principal Office - (26.37 SQM)	Office (6)	
B00A - R0078 - Public Reception - (10.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Laboratory L.S. - (85.44 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R1004 - Art Learning Space - (66.82 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1009 - General Learning Space - (66.24 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1012 - Staff Study - (25.92 SQM)	Office (6)	
B00A - R1015 - Computer Learning Space - (67.27 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1019 - General Learning Space - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1022 - Art Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1023 - Art Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1026 - Duplicating Workroom - (24.83 SQM)	Office (6)	
B00A - R1029 - Design L.S. - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1033 - Staff Study - (26.88 SQM)	Office (6)	
B00A - R1034 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1036 - Preparation - (19.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R1037 - Movement - (243.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R1038 - Staff Study - (25.99 SQM)	Office (6)	
B00B - R0004 - Materials Technology L.S. - (103.65 SQM) - Teaching Space: 1	Student Space (48)	
B00B - R0005 - Design L.S. - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0006 - Staff Study - (23.16 SQM)	Office (5)	
B00B - R0007 - Staff Study - (29.86 SQM)	Office (7)	
B00B - R0009 - Materials Technology L.S. - (85.91 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0015 - Music Learning Space - (60.21 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0016 - Movement - (82.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (7.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Staff Lounge - (26.37 SQM)	Office (6)	
B00B - R0021 - Workshop Area - (57.36 SQM)	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1003 - Materials Technology L.S. - (108.83 SQM) - Teaching Space: 1	Student Space (50)	
B00B - R1004 - Design L.S. - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1007 - Materials Technology L.S. - (85.92 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R1013 - Music Learning Space - (60.21 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1015 - Movement - (72.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Gymnasium - (317.24 SQM)	Student Space (147)	
B00C - R0002 - Movement - (6.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Student Canteen - (59.13 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (22.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (6.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (53.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (9.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - Movement - (9.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Laboratory L.S. - (92.75 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R0002 - Preparation - (9.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Preparation - (27.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Laboratory L.S. - (92.75 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R0008 - General Learning Space - (64.7 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0009 - Laboratory L.S. - (85.45 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0010 - Preparation - (19 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - General Learning Space - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0015 - Staff Study - (25.78 SQM)	Office (6)	
B00D - R0017 - Staff Study - (13.07 SQM)	Office (3)	
B00D - R0020 - Movement - (159.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1002 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1003 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1004 - General Learning Space - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1008 - General Learning Space - (53.31 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1009 - Staff Study - (25.78 SQM)	Office (6)	
B00D - R1010 - Staff Study - (8.04 SQM)	Office (2)	
B00D - R1012 - General Learning Space - (51.59 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1013 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1014 - Staff Study - (11.48 SQM)	Office (2)	
B00D - R1016 - Computer Learning Space - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1017 - Staff Study - (25.93 SQM)	Office (6)	
B00D - R1018 - General Learning Space - (53.31 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1021 - Movement - (127.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Laboratory L.S. - (92.6 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0003 - Preparation - (28.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Laboratory L.S. - (92.23 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0011 - General Learning Space - (60.25 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0013 - Preparation - (28.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Laboratory L.S. - (98.74 SQM) - Teaching Space: 1	Student Space (45)	
B00E - R0022 - Movement - (164.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - General Learning Space - (52.55 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1001 - General Learning Space - (72.67 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R1004 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1006 - General Learning Space - (58.79 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1009 - General Learning Space - (52.95 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1012 - General Learning Space - (60.25 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1013 - Staff Study - (23.95 SQM)	Office (5)	
B00E - R1014 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1017 - General Learning Space - (59.15 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1019 - General Learning Space - (52.5 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1021 - Staff Study - (12.42 SQM)	Office (3)	
B00E - R1022 - Movement - (150.77 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0015 - General Learning Space - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0017 - Staff Study - (25.93 SQM)	Office (6)	
B00F - R0022 - Movement - (144.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0026 - Entry - (24.3 SQM)	Not Applicable	Circulation or storage space.
B00F - R0029 - Seminar - (17.51 SQM)	Office (4)	
B00F - R0035 - Seminar - (16.04 SQM)	Office (4)	
B00F - R0036 - Seminar - (17.33 SQM)	Office (4)	
B00F - R0037 - Main Area - (382.86 SQM)	Not Applicable	Circulation or storage space.
B00F - R0039 - General Learning Space - (59.13 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0040 - General Learning Space - (52.69 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1001 - General Learning Space - (59.15 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R1002 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1003 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1004 - General Learning Space - (59.15 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R1007 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1009 - General Learning Space - (59.16 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R1013 - Stage - (25.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R1014 - Performance Workspace - (52.59 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1015 - General Learning Space - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R1016 - Staff Study - (12.25 SQM)	Office (3)	
B00F - R1018 - Staff Study - (25.85 SQM)	Office (6)	
B00F - R1026 - Movement Studio - (150.97 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Multi-Purpose Space - (422.95 SQM)	Student Space (196)	
B00H - R0002 - Movement - (10.66 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Movement - (19.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Stage - (91.99 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Movement - (18.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Staff Kitchen - (12.51 SQM)	Office (3)	
B00I - R0001 - Gymnasium - (486.29 SQM)	Student Space (225)	
B00I - R0002 - Workroom - (8.54 SQM)	Office (2)	
B00I - R0007 - Movement - (17.59 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Staff Study - (52.15 SQM)	Office (13)	
BOJ1 - R0001 - Fitness Laboratory - (346.15 SQM)	Student Space (160)	
BOJ1 - R0002 - Entry - (12.48 SQM)	Not Applicable	Circulation or storage space.
BOJ1 - R0003 - Administration - Clerical - (23.6 SQM)	Office (5)	
BOJ1 - R0004 - Staff Study - (14.01 SQM)	Office (3)	
BOJ1 - R0005 - Seminar - (17.58 SQM)	Office (4)	
BOJ1 - R0006 - Seminar - (17.63 SQM)	Office (4)	
BOJ1 - R0013 - Staff Study - (19.87 SQM)	Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOJ1 - R0017 - Gymnasium - (159.28 SQM)	● Student Space (73)	
BOJ1 - R0018 - Stage - (6.47 SQM)	Not Applicable	Circulation or storage space.
BOJ1 - R0019 - Movement - (93.52 SQM)	Not Applicable	Circulation or storage space.