


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>The Jannali High School (8852)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Miranda</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

8852 - The Jannali High School  
Site Plan (10743)



1:1,107


















Printed: 16-Jun-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Materials Technology L.S. - (107.57 SQM) - Teaching Space: 1	● Student Space (49)	
B00A - R0002 - Wood Technology Bay - (71.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Design L.S. - (75.86 SQM) - Teaching Space: 1	● Student Space (35)	
B00B - R0002 - Materials Technology L.S. - (75.51 SQM) - Teaching Space: 1	● Student Space (35)	
B00B - R0003 - Metal Technology Bay - (22.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Materials Technology L.S. - (75.45 SQM) - Teaching Space: 1	● Student Space (35)	
B00B - R0006 - Staff Study - (53.52 SQM)	○ Office (13)	
B00B - R0009 - Darkroom Space - (6.57 SQM)	○ Office (1)	
B00B - R0010 - Design L.S. - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0011 - General Learning Space - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0002 - General Learning Space - (53.96 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0003 - General Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0004 - Staff Study - (22.48 SQM)	○ Office (5)	
B00C - R0005 - Staff Study - (31.12 SQM)	○ Office (7)	
B00C - R0006 - General Learning Space - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0007 - General Learning Space - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0002 - General Learning Space - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0003 - General Learning Space - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0004 - General Learning Space - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0005 - General Learning Space - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0006 - Staff Study - (46.05 SQM)	○ Office (11)	
B00E - R0004 - General Learning Space - (53.38 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0006 - Staff Study - (33.13 SQM)	○ Office (8)	
B00E - R0008 - Study Space - (33.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - General Learning Space - (66.76 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0002 - Laboratory L.S. - (89.33 SQM) - Teaching Space: 1	● Student Space (41)	
B00F - R0003 - Preparation - (17.72 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Laboratory L.S. - (89.34 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0001 - General Learning Space - (61 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0004 - General Learning Space - (52.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0008 - Laboratory L.S. - (94.51 SQM) - Teaching Space: 1	● Student Space (43)	
B00G - R0011 - Laboratory L.S. - (94.62 SQM) - Teaching Space: 1	● Student Space (43)	
B00G - R0013 - Staff Study - (39.49 SQM)	○ Office (9)	
B00G - R0023 - Movement - (139.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Staff Kitchen - (23.34 SQM)	○ Office (5)	
B00G - R0029 - Staff Lounge - (53.23 SQM)	○ Office (13)	
B00G - R0030 - Staff Lounge - (27.13 SQM)	○ Office (6)	
B00G - R0031 - Administration - Clerical - (24.2 SQM)	○ Office (6)	
B00G - R0033 - Preparation - (36.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - General Learning Space - (59.98 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1002 - Interview/Office - Type 1 - (13.67 SQM)	○ Office (3)	
B00G - R1004 - Computer Learning Space - (53.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1007 - Senior Study - (32.8 SQM)	○ Office (8)	
B00G - R1008 - Senior Study - (66.49 SQM)	○ Office (16)	
B00G - R1009 - Staff Study - (12.71 SQM)	○ Office (3)	
B00G - R1010 - Leading Teacher - (12.74 SQM)	○ Office (3)	
B00G - R1011 - Staff Study - (26.07 SQM)	○ Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1013 - General Learning Space - (59.68 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1014 - Movement - (7.36 SQM)	Not Applicable	Circulation or storage space.
B00G - R1017 - General Learning Space - (53.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1020 - Staff Study - (42.58 SQM)	● Office (10)	
B00G - R1022 - General Learning Space - (52.13 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1023 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1024 - Movement - (133.45 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Public Entry - (14.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Deputy Principal Office - (14.68 SQM)	● Office (3)	
B00H - R0018 - Public Entry - (6.43 SQM)	Not Applicable	Circulation or storage space.
B00H - R0020 - Deputy Principal Office - (16.25 SQM)	● Office (4)	
B00H - R0021 - Movement - (8.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0022 - Movement - (25.53 SQM)	Not Applicable	Circulation or storage space.
B00H - R0023 - Clinic - (7.85 SQM)	● Office (1)	
B00H - R0025 - Administration - Clerical - (48.36 SQM)	● Office (12)	
B00H - R0028 - Movement - (37.17 SQM)	Not Applicable	Circulation or storage space.
B00H - R0029 - Principal Office - (19.08 SQM)	● Office (4)	
B00J - R0001 - Movement - (11.63 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Movement - (350.38 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Movement - (8.47 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Student Canteen - (53.22 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Computer Learning Space - (48.97 SQM) - Teaching Space: 1	● Student Space (22)	
B00K - R0005 - Movement - (46.72 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Workroom - (49.47 SQM)	● Office (12)	
B00K - R0011 - Movement - (14.37 SQM)	Not Applicable	Circulation or storage space.
B00K - R0012 - Main Area - (215.56 SQM)	Not Applicable	Circulation or storage space.
B00K - R1003 - Movement - (124.66 SQM)	Not Applicable	Circulation or storage space.
B00K - R1005 - Seminar - (16.44 SQM)	● Office (4)	
B00K - R1006 - Seminar - (16.65 SQM)	● Office (4)	
B00K - R1010 - Computer Room - (49.65 SQM)	● Student Space (23)	
B00K - R1011 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00K - R1012 - Movement - (5.49 SQM)	Not Applicable	Circulation or storage space.
B00K - R1015 - Computer Learning Space - (39.54 SQM) - Teaching Space: 1	● Student Space (18)	
B00K - R1016 - Computer Learning Space - (58.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0002 - Stage - (76.17 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Multi-Purpose Space - (387.68 SQM)	● Student Space (179)	
B00L - R0007 - Staff Kitchen - (28.98 SQM)	● Office (7)	
B00L - R0012 - Movement - (5.25 SQM)	Not Applicable	Circulation or storage space.
B00L - R9003 - General Assistants - (30.76 SQM)	● Office (7)	
B00M - R0003 - Staff Study - (39.79 SQM)	● Office (9)	
B00M - R0007 - Design L.S. - (73.62 SQM) - Teaching Space: 1	● Student Space (34)	
B00M - R0008 - Food Technology L.S. - (101.91 SQM) - Teaching Space: 1	● Student Space (47)	
B00M - R0009 - Seminar/Technology Space - (12.55 SQM)	● Office (3)	
B00M - R0010 - Food/Research Space - (20.56 SQM)	Not Applicable	Circulation or storage space.
B00M - R0011 - Food Technology L.S. - (102.86 SQM) - Teaching Space: 1	● Student Space (47)	
B00M - R0014 - Music Learning Space - (76.38 SQM) - Teaching Space: 1	● Student Space (35)	
B00M - R0015 - Practice/Seminar - (25.71 SQM)	Not Applicable	Circulation or storage space.
B00M - R0016 - Music Learning Space - (60.32 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0003 - Art Learning Space - (112.12 SQM) - Teaching Space: 1	 Student Space (52)	
B00N - R0007 - Art Learning Space - (60.38 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R0008 - Art Learning Space - (60.38 SQM) - Teaching Space: 1	 Student Space (28)	
B00P - R0001 - Darkroom Space - (26.69 SQM)	 Office (6)	
B00P - R0002 - Materials Technology L.S. - (72.3 SQM) - Teaching Space: 1	 Student Space (33)	
B00P - R0004 - Materials Technology L.S. - (79.59 SQM) - Teaching Space: 1	 Student Space (36)	
B00P - R0008 - Staff Study - (5.17 SQM)	 Office (1)	
B00P - R0010 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Gymnasium - (503.05 SQM)	 Student Space (233)	
B00S - R0008 - Staff Study - (19.96 SQM)	 Office (4)	
OS 600 10235 - OS 600 10235 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 11540 - OS 600 11540 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 12285 - OS 600 12285 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 15893 - OS 600 15893 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 17425 - OS 600 17425 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19778 - OS 600 19778 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 12179 - OS 601 12179 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 710 19105 - OS 710 19105 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	
OS 720 12283 - OS 720 12283 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.