

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>The Junction Public School (2246)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Newcastle</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Newcastle</b>

2246 - The Junction Public School  
Site Plan (11785)



1:1,196

Printed: 18-Aug-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Deputy Principal - (14.24 SQM)	Office (3)	
B00A - R0008 - Principal - (17.93 SQM)	Office (4)	
B00A - R0009 - Interview - (13.02 SQM)	Office (3)	
B00A - R0015 - Sick Bay - (9.2 SQM)	Student Space (4)	
B00A - R0016 - Duplicating Workroom - (23.25 SQM)	Office (5)	
B00A - R0021 - Deputy Principal - (14.17 SQM)	Office (3)	
B00A - R0024 - Movement - (23.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (13.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Clerical Office - (25.18 SQM)	Office (6)	
B00A - R0028 - Movement - (15.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Staff Kitchen - (10.45 SQM)	Office (2)	
B00A - R0032 - Interview - (9.86 SQM)	Office (2)	
B00A - R0033 - Staff Room - (75.86 SQM)	Office (18)	
B00B - R0001 - Withdrawal Space - 1hb - (5.92 SQM)	Student Space (2)	
B00B - R0005 - Home Base - (61.15 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0007 - Practical Activities - 1hb - (16.96 SQM)	Student Space (7)	
B00B - R0008 - Home Base - (61.23 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0009 - Practical Activities - 1hb - (17.04 SQM)	Student Space (7)	
B00B - R0011 - Withdrawal Space - 1hb - (12.19 SQM)	Student Space (5)	
B00B - R0016 - Home Base - (61.23 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0019 - Practical Activities - 1hb - (16.97 SQM)	Student Space (7)	
B00B - R0020 - Home Base - (61.15 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0021 - Practical Activities - 1hb - (17 SQM)	Student Space (7)	
B00B - R0023 - Withdrawal Space - 1hb - (6.52 SQM)	Student Space (3)	
B00C - R0001 - Withdrawal Space - 1hb - (5.92 SQM)	Student Space (2)	
B00C - R0004 - Home Base - (61.07 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0006 - Practical Activities - 1hb - (16.98 SQM)	Student Space (7)	
B00C - R0008 - Home Base - (61.15 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0009 - Practical Activities - 1hb - (17.05 SQM)	Student Space (7)	
B00C - R0011 - Withdrawal Space - 1hb - (12.19 SQM)	Student Space (5)	
B00C - R0013 - Home Base - (61.23 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0016 - Practical Activities - 1hb - (17.05 SQM)	Student Space (7)	
B00C - R0017 - Home Base - (61.22 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0018 - Practical Activities - 1hb - (17.02 SQM)	Student Space (7)	
B00C - R0020 - Withdrawal Space - 1hb - (5.95 SQM)	Student Space (2)	
B00D - R0002 - Reading Area - (161.98 SQM)	Student Space (75)	
B00D - R0006 - Special Programs Room - (36.68 SQM)	Student Space (17)	
B00E - R0001 - Movement - (28.72 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Withdrawal Space - 1hb - (5.92 SQM)	Student Space (2)	
B00F - R0007 - Practical Activities - 1hb - (16.95 SQM)	Student Space (7)	
B00F - R0008 - Home Base - (61.87 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0009 - Practical Activities - 1hb - (16.79 SQM)	Student Space (7)	
B00F - R0011 - Home Base - (61.38 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0013 - Withdrawal Space - 1hb - (5.9 SQM)	Student Space (2)	
B00H - R0019 - Home Base X2 - (140.8 SQM) - Teaching Space: 2	Student Space (65)	
B00J - R0002 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0004 - Home Base - (59.25 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (11.37 SQM)	Student Space (5)	
B00J - R0006 - Home Base - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (19.42 SQM)	Student Space (9)	
B00K - R0002 - Practical Activities - 1hb - (20 SQM)	Student Space (9)	
B00K - R0003 - Home Base - (58.68 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0006 - Home Base - (58.69 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0007 - Practical Activities - (20.11 SQM)	Student Space (9)	
B00L - R0002 - Canteen - (46.36 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B00M - R0004 - Home Base - (58.16 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	Student Space (4)	
B00M - R0006 - Home Base - (58.16 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R0008 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B00N - R0002 - Communal Space - (197.41 SQM)	Student Space (91)	
B00N - R0003 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00N - R0004 - Raised Platform - (58.7 SQM)	Not Applicable	Circulation or storage space.
B00N - R0006 - Movement - (17.36 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Withdrawal Space - 1hb - (12.33 SQM)	Student Space (5)	
B00P - R0002 - Home Base - (86.1 SQM) - Teaching Space: 1	Student Space (39)	
B00P - R0005 - Withdrawal Space - 1hb - (12.33 SQM)	Student Space (5)	
B00P - R0006 - Home Base - (80.82 SQM) - Teaching Space: 1	Student Space (37)	
B00P - R0009 - Withdrawal Space - 1hb - (12.33 SQM)	Student Space (5)	
B00P - R0010 - Home Base - (80.82 SQM) - Teaching Space: 1	Student Space (37)	
B00P - R0013 - Home Base - (86.1 SQM) - Teaching Space: 1	Student Space (39)	
B00P - R0014 - Withdrawal Space - 1hb - (12.33 SQM)	Student Space (5)	
B00P - R0015 - Home Base - (80.82 SQM) - Teaching Space: 1	Student Space (37)	
B00P - R0016 - Withdrawal Space - 1hb - (12.33 SQM)	Student Space (5)	
OS 602 11169 - OS 602 11169 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15783 - OS 602 15783 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	