


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>The Oaks Public School (2793)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Wollondilly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wollondilly</b>

2793 - The Oaks Public School  
Site Plan (10629)




















1:823

Printed: 22-Jun-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (17.5 SQM)	Office (4)	
B00A - R0002 - Entry Vestibule - (15.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Movement - (78.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Duplicating Workroom - (20.12 SQM)	Office (5)	
B00A - R0005 - Principal - (16.55 SQM)	Office (4)	
B00A - R0010 - Movement - (39.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Staff Room Annexe - (19.06 SQM)	Office (4)	
B00A - R0012 - Staff Room - (45.09 SQM)	Office (11)	
B00A - R0014 - Deputy Principal - (12.29 SQM)	Office (3)	
B00A - R0015 - Deputy Principal - (13.08 SQM)	Office (3)	
B00A - R0016 - Interview - (13.08 SQM)	Office (3)	
B00A - R0019 - Sick Bay - (8.57 SQM)	Student Space (3)	
B00A - R0021 - Movement - (26.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R9003 - Movement - (10.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Reading Area - (162.66 SQM)	Student Space (75)	
B00B - R0006 - Movement - (73.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (28.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (65.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Special Programs Room - (37.9 SQM)	Student Space (17)	
B00C - R0008 - Interview - (13.89 SQM)	Office (3)	
B00C - R0010 - Movement - (14.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (85.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Practical Activities - 1hb - (26.36 SQM)	Student Space (12)	
B00D - R0005 - Withdrawal Space - 1hb - (5.97 SQM)	Student Space (2)	
B00D - R0006 - Home Base - (50.54 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0008 - Practical Activities - 1hb - (27.59 SQM)	Student Space (12)	
B00D - R0009 - Home Base - (50.68 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0011 - Withdrawal Space - 1hb - (12.11 SQM)	Student Space (5)	
B00D - R0012 - Home Base - (50.32 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0014 - Practical Activities - 1hb - (27.61 SQM)	Student Space (12)	
B00D - R0016 - Practical Activities - 1hb - (26.78 SQM)	Student Space (12)	
B00D - R0017 - Home Base - (50.69 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0018 - Withdrawal Space - 1hb - (5.9 SQM)	Student Space (2)	
B00H - R0001 - Movement - (77.22 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Canteen - (27.7 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (6.63 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Movement - (16.33 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Movement - (6.52 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (22.76 SQM)	Not Applicable	Circulation or storage space.
B00H - R0019 - Communal Space - (135.67 SQM)	Student Space (62)	
B00H - R0022 - Communal Space - (52.4 SQM)	Student Space (24)	
B00J - R0001 - Movement - (17.18 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Home Base - (66.97 SQM) - Teaching Space: 1	Student Space (31)	
B00K - R0002 - Movement - (13.18 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Practical Activities - 1hb - (25.96 SQM)	Student Space (12)	
B00M - R0003 - Withdrawal Space - 1hb - (5.71 SQM)	Student Space (2)	
B00M - R0004 - Home Base - (50.46 SQM) - Teaching Space: 1	Student Space (23)	
B00M - R0005 - Practical Activities - 1hb - (26.92 SQM)	Student Space (12)	
B00M - R0006 - Home Base - (50.83 SQM) - Teaching Space: 1	Student Space (23)	
B00M - R0008 - Withdrawal Space - 1hb - (12.01 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0010 - Practical Activities - 1hb - (27.04 SQM)	 Student Space (12)	
B00M - R0011 - Home Base - (50.76 SQM) - Teaching Space: 1	 Student Space (23)	
B00M - R0012 - Practical Activities - 1hb - (26.16 SQM)	 Student Space (12)	
B00M - R0013 - Home Base - (50.61 SQM) - Teaching Space: 1	 Student Space (23)	
B00M - R0015 - Withdrawal Space - 1hb - (5.76 SQM)	 Student Space (2)	
B00M - R0018 - Movement - (130.75 SQM)	Not Applicable	Circulation or storage space.
B0EE - R0004 - Special Programs Room - (33.17 SQM)	 Student Space (15)	
B0EE - R0005 - Movement - (6.22 SQM)	Not Applicable	Circulation or storage space.
B0EE - R0007 - Practical Activities/Movement - 1hb - (19.41 SQM)	 Student Space (9)	
B0EE - R0009 - Home Base - (61.11 SQM) - Teaching Space: 1	 Student Space (28)	
B0EE - R0010 - Withdrawal Space - 2hb - (11.71 SQM)	 Student Space (5)	
B0EE - R0011 - Home Base - (61.16 SQM) - Teaching Space: 1	 Student Space (28)	
B0EE - R0013 - Practical Activities/Movement - 1hb - (19.9 SQM)	 Student Space (9)	
B0FF - R0002 - Practical Activities/Movement - 1hb - (19.78 SQM)	 Student Space (9)	
B0FF - R0004 - Home Base - (61.13 SQM) - Teaching Space: 1	 Student Space (28)	
B0FF - R0005 - Withdrawal Space - 2hb - (11.74 SQM)	 Student Space (5)	
B0FF - R0006 - Home Base - (60.98 SQM) - Teaching Space: 1	 Student Space (28)	
B0FF - R0008 - Practical Activities/Movement - 1hb - (19.34 SQM)	 Student Space (8)	
OH 060 17013 - OH 060 17013 - OSHC Hub 60 - (190 SQM)	 Student Space (88)	