

# VENTILATION AUDIT REPORT

















SCHOOL:	The Pocket Public School (2890)
AMU REGION:	North Coast
STATE ELECTORATE:	Ballina
LOCAL GOVERNMENT AREA:	Byron

2890 - The Pocket Public School  
Site Plan (11339)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Seminar/Study - (20.08 SQM)	 Office (5)	
B00C - R0001 - Special Programs Room - (20.29 SQM)	 Student Space (9)	
B00E - R0002 - Home Base - (77.61 SQM) - Teaching Space: 1	 Student Space (36)	
B00E - R0003 - Withdrawal Space - 1hb - (8.81 SQM)	 Student Space (4)	
B00E - R0005 - Interview - (15.09 SQM)	 Office (3)	
B00E - R0006 - Staff Kitchen - (36.85 SQM)	 Office (9)	
B00E - R0008 - Movement - (24.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Sick Bay - (9.79 SQM)	 Student Space (4)	
B00E - R0013 - Principal - (12.65 SQM)	 Office (3)	
B00E - R0015 - Clerical Office - (22.53 SQM)	 Office (5)	
B00E - R0016 - Deputy Principal - (12.62 SQM)	 Office (3)	
B00E - R0017 - Entry Vestibule - (9.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Outdoor Learning Area - (18.38 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (19.49 SQM)	 Student Space (9)	
B00G - R0004 - Home Base - (58.59 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (10.64 SQM)	 Student Space (4)	
B00G - R0006 - Home Base - (58.71 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.56 SQM)	 Student Space (9)	
OS 606 15001 - OS 606 15001 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	