




# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>The Ponds High School (8911)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Riverstone</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blacktown</b>



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Public Reception - (44.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Visitors Office - (13.16 SQM)	Office (3)	
B00A - R0003 - Interview/Meeting - (12.26 SQM)	Office (3)	
B00A - R0004 - Interview/Meeting - (12 SQM)	Office (3)	
B00A - R0005 - Principal Office - (22.56 SQM)	Office (5)	
B00A - R0006 - Interview/Meeting - (14.48 SQM)	Office (3)	
B00A - R0012 - Student Reception - (30.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Staff Kitchen - (6.25 SQM)	Office (1)	
B00A - R0014 - Administration - Clerical - (118.34 SQM)	Office (29)	
B00A - R0015 - Deputy Principal Office - (13.01 SQM)	Office (3)	
B00A - R0016 - Deputy Principal Office - (13.53 SQM)	Office (3)	
B00A - R0017 - Student Waiting - (7.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Clinic - Boys - (17.12 SQM)	Office (4)	
B00A - R0020 - Clinic - Girls - (15.54 SQM)	Office (3)	
B00A - R0021 - Interview/Meeting - (12.85 SQM)	Office (3)	
B00A - R0022 - Interview/Office - Type 1 - (13.03 SQM)	Office (3)	
B00A - R0027 - General Learning Space - (59.29 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0028 - General Learning Space - (59.44 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0029 - Seminar - (21.13 SQM)	Office (5)	
B00A - R0030 - Seminar - (21.17 SQM)	Office (5)	
B00A - R0031 - General Learning Space - (59.36 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0032 - General Learning Space - (59.11 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0033 - Kitchen - Type 1 - (105.01 SQM)	Student Space (48)	
B00A - R0035 - Preparation - Materials - (33.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Kitchen - Type 1 - (99.41 SQM)	Student Space (46)	
B00A - R0042 - Movement - (27.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Movement - (37.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - General Learning Space - (57.57 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0046 - General Learning Space - (58.82 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0047 - Visual Arts Workshop - (99.01 SQM)	Student Space (45)	
B00A - R0052 - Movement - (19.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - General Learning Space - (58.77 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0057 - General Learning Space - (58.38 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0058 - Materials Workshop - Type 2 - (131.29 SQM)	Student Space (60)	
B00A - R0059 - Welding Area - (12.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - Workshop - (85.97 SQM)	Student Space (39)	
B00A - R0067 - Movement - (15.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0070 - Movement - (23.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Main Entry - (28.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Main Area - (504.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Seminar - (13.14 SQM)	Office (3)	
B00A - R1005 - Seminar - (13.09 SQM)	Office (3)	
B00A - R1006 - Seminar - (13.46 SQM)	Office (3)	
B00A - R1008 - Senior Study - (64.17 SQM)	Office (16)	
B00A - R1009 - Computer Learning Space - (62.91 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1015 - General Learning Space - (59.5 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1016 - General Learning Space - (59.27 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1017 - General Learning Space - (59.43 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1018 - General Learning Space - (59.51 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1019 - Seminar - (21.2 SQM)	Office (5)	
B00A - R1020 - Seminar - (21.13 SQM)	Office (5)	
B00A - R1021 - General Learning Space - (59.51 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1022 - General Learning Space - (59.26 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1023 - Science Laboratory - (104.89 SQM)	Student Space (48)	
B00A - R1024 - Preparation - Science - (63.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R1028 - Science Laboratory - (106.12 SQM)	Student Space (49)	
B00A - R1029 - Seminar - (28.34 SQM)	Office (7)	
B00A - R1031 - Science Laboratory - (103.62 SQM)	Student Space (48)	
B00A - R1034 - Movement - (32.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R1035 - Movement - (38.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R1040 - General Learning Space - (59.26 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1041 - General Learning Space - (61.44 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1042 - Workshop - (103.81 SQM)	Student Space (48)	
B00A - R1043 - Dark Room - (27.67 SQM)	Office (6)	
B00B - R0009 - Student Canteen - (53.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (64.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0036 - Movement - (6.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Staff Study - (295.88 SQM)	Office (73)	
B00B - R1002 - Interview/Meeting - (11.95 SQM)	Office (2)	
B00B - R1003 - Interview/Meeting - (12.51 SQM)	Office (3)	
B00B - R1004 - Interview/Meeting - (12.08 SQM)	Office (3)	
B00B - R1005 - Interview/Meeting - (12.84 SQM)	Office (3)	
B00B - R1006 - Staff Study - (218.63 SQM)	Office (54)	
B00B - R1007 - Staff Lounge - (141.22 SQM)	Office (35)	
B00B - R1016 - Movement - (49.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R1019 - Movement - (6.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Gymnasium - (667.67 SQM)	Student Space (309)	
B00C - R0003 - Movement - (6.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (28.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Stage - (98.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (31.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - General Learning Space - (62.3 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0002 - General Learning Space - (62.13 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0003 - Fitness Laboratory - (100.53 SQM)	Student Space (46)	
B00D - R0005 - Seminar - (19.4 SQM)	Office (4)	
B00D - R0009 - General Learning Space - (58.8 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0010 - General Learning Space - (59.15 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0011 - General Learning Space - (59.3 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0012 - General Learning Space - (59.05 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0013 - Shared Learning Space - (89.83 SQM)	Student Space (41)	
B00D - R0015 - General Learning Space - (65.99 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0016 - Seminar - (30.79 SQM)	Office (7)	
B00D - R0017 - General Learning Space - (58.98 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0018 - General Learning Space - (59.23 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0019 - General Learning Space - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0020 - General Learning Space - (59.05 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0021 - Seminar - (30.67 SQM)	Office (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0022 - General Learning Space - (58.64 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0023 - Movement - (191.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - General Learning Space - (58.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0030 - General Learning Space - (58.97 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0031 - Shared Learning Space - (99.47 SQM)	● Student Space (46)	
B00D - R0032 - General Learning Space - (58.9 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0034 - General Learning Space - (58.88 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0035 - General Learning Space - (66.49 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0036 - General Learning Space - (59.3 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0037 - General Learning Space - (59.55 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0038 - General Learning Space - (58.73 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0040 - Movement - (128.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - (63.56 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R1002 - General Learning Space - (62.21 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1003 - Performance Workshop - (103.35 SQM)	● Student Space (47)	
B00D - R1005 - Practice/Seminar - (20.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R1008 - General Learning Space - (59.32 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1009 - General Learning Space - (59.31 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1010 - General Learning Space - (59.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1011 - General Learning Space - (59.37 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1012 - Shared Learning Space - (90.13 SQM)	● Student Space (41)	
B00D - R1013 - General Learning Space - (66.07 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1015 - General Learning Space - (67.33 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R1016 - Seminar - (33.28 SQM)	● Office (8)	
B00D - R1017 - General Learning Space - (60.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1018 - General Learning Space - (60.51 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1020 - Shared Learning Space - (88.91 SQM)	● Student Space (41)	
B00D - R1021 - Seminar - (33.28 SQM)	● Office (8)	
B00D - R1022 - General Learning Space - (59.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1023 - Seminar - (44.15 SQM)	● Office (11)	
B00D - R1024 - Movement - (179.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R1027 - General Learning Space - (58.95 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1028 - General Learning Space - (58.82 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1029 - Shared Learning Space - (99.49 SQM)	● Student Space (46)	
B00D - R1030 - General Learning Space - (59.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1032 - General Learning Space - (58.78 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1033 - General Learning Space - (67.93 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R1034 - General Learning Space - (60.68 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1035 - General Learning Space - (62.05 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1036 - General Learning Space - (60.93 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1037 - Movement - (121.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R1046 - Practical Activities - (6.67 SQM)	● Student Space (3)	
OS 510 11409 - OS 510 11409 - Staff Common Room - (114 SQM)	● Office (28)	
OS 601 10367 - OS 601 10367 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 10418 - OS 601 10418 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 10517 - OS 601 10517 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11395 - OS 601 11395 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 601 11517 - OS 601 11517 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11629 - OS 601 11629 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11633 - OS 601 11633 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11779 - OS 601 11779 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11904 - OS 601 11904 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12054 - OS 601 12054 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12308 - OS 601 12308 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12328 - OS 601 12328 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12669 - OS 601 12669 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12936 - OS 601 12936 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13004 - OS 601 13004 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13229 - OS 601 13229 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13451 - OS 601 13451 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13529 - OS 601 13529 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14110 - OS 601 14110 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14571 - OS 601 14571 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14693 - OS 601 14693 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14967 - OS 601 14967 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 16817 - OS 601 16817 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 18303 - OS 601 18303 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19367 - OS 601 19367 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19368 - OS 601 19368 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19370 - OS 601 19370 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10874 - OS 602 10874 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 710 12531 - OS 710 12531 - Home Science/Pantry/Laundry - (95 SQM)	● Office (23)	
OS 720 14454 - OS 720 14454 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 15479 - OS 720 15479 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 15754 - OS 720 15754 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 17930 - OS 720 17930 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 760 12334 - OS 760 12334 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 760 13079 - OS 760 13079 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 770 10761 - OS 770 10761 - Technics - Metalwork/Heat Area/Store - (114 SQM)	Not Applicable	Circulation or storage space.