


VENTILATION AUDIT REPORT

SCHOOL:	The Rivers Secondary College Lismore High Campus (8124)
AMU REGION:	North Coast
STATE ELECTORATE:	Lismore
LOCAL GOVERNMENT AREA:	Lismore

8124 - The Rivers Secondary College Lismore High Campus
Site Plan (10411)



1:1,656

Printed: 06-Jun-2020




Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Interview/Office - Type 1 - (13.88 SQM)	Office (3)	
B00A - R0002 - Interview/Office - Type 1 - (12.15 SQM)	Office (3)	
B00A - R0004 - Interview/Office - Type 1 - (11.18 SQM)	Office (2)	
B00A - R0006 - Commonroom - (12.17 SQM)	Office (3)	
B00A - R0009 - Principal Office - (18.86 SQM)	Office (4)	
B00A - R0016 - Staff Study - (23.53 SQM)	Office (5)	
B00A - R0017 - General Learning Space - (57.76 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0018 - Movement - (15.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - General Learning Space - (51.18 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0027 - Laboratory L.S. - (91.84 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0028 - Preparation - (29.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Preparation - (8.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Laboratory L.S. - (84.31 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0032 - Movement - (15.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Clinic - Girls - (17.01 SQM)	Office (4)	
B00A - R0037 - Movement - (151.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Clinic - Boys - (12.56 SQM)	Office (3)	
B00A - R0040 - Administration - Clerical - (26.62 SQM)	Office (6)	
B00A - R0046 - Public Reception - (37.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Administration - Clerical - (51.59 SQM)	Office (12)	
B00A - R0049 - Deputy Principal - (12.5 SQM)	Office (3)	
B00A - R0050 - Student Waiting - (10.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - Deputy Principal - (12.5 SQM)	Office (3)	
B00A - R0056 - Public Entry - (61.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R1040 - Movement - (9.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R1041 - General Learning Space - (51.55 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1045 - General Learning Space - (52.07 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1046 - General Learning Space - (51.84 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1048 - Commonroom - (110.49 SQM)	Office (27)	
B00A - R1050 - Movement - (9.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R1053 - Computer Learning Space - (50.47 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1055 - Staff Study - (12.84 SQM)	Office (3)	
B00A - R1056 - Computer Learning Space - (57.85 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1059 - Computer Learning Space - (52.17 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1060 - Food Technology L.S. - (78.62 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R1061 - Movement - (152.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R1065 - Design L.S. - (71.08 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R0001 - Duplicating Workroom - (31.27 SQM)	Office (7)	
B00B - R0005 - Food Technology L.S. - (103.49 SQM) - Teaching Space: 1	Student Space (48)	
B00B - R0007 - Movement - (15.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Music Learning Space - (51.27 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0011 - Design L.S. - (84.64 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0012 - Metal Technology Bay - (24.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Materials Technology L.S. - (91.86 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0015 - Design L.S. - (57.85 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0017 - Movement - (14.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Special Learning Space - (50.16 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0021 - Movement - (154.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0046 - Kitchen - Type 2 - (92.57 SQM)	Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0049 - Preparation - (14.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R1023 - Practice/Seminar - (51.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R1025 - Art Learning Space - (71.01 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R1027 - Visual Arts Workshop - (52.44 SQM)	● Student Space (24)	
B00B - R1029 - Art Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1030 - Staff Study - (31.32 SQM)	● Office (7)	
B00B - R1031 - Staff Study - (12.28 SQM)	● Office (3)	
B00B - R1035 - General Learning Space - (51.37 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1036 - General Learning Space - (57.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1038 - Design L.S. - (78.49 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R1039 - Wood Technology Bay - (33.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R1041 - Materials Technology L.S. - (84.08 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R1052 - Movement - (176.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (317.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Student Canteen - (13.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (10.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (6.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Movement - (19.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Movement - (30.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0029 - Student Canteen - (25.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0033 - Movement - (7.31 SQM)	Not Applicable	Circulation or storage space.
B00C - R1026 - Movement - (13.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R1029 - Ancillary Staff - (6.28 SQM)	● Office (1)	
B00C - R1032 - Movement - (13.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Multi-Purpose Space - (15.59 SQM)	● Student Space (7)	
B00D - R0007 - Staff Study - (25.67 SQM)	● Office (6)	
B00D - R0008 - Preparation - (5.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Laboratory L.S. - (91.33 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0014 - General Learning Space - (50.85 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0019 - Laboratory L.S. - (84.23 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0026 - General Learning Space - (51.1 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0035 - Preparation - (37.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0036 - Science Laboratory - (99.12 SQM)	● Student Space (45)	
B00D - R0038 - Seminar - (19.9 SQM)	● Office (4)	
B00D - R0040 - Movement - (165.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R1027 - Movement - (8.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R1031 - General Learning Space - (57.86 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1032 - Audio Visual Workroom - (25.71 SQM)	● Student Space (11)	
B00D - R1033 - Staff Study - (38.9 SQM)	● Office (9)	
B00D - R1034 - Staff Study - (12.52 SQM)	● Office (3)	
B00D - R1035 - Senior Study - (25.72 SQM)	● Office (6)	
B00D - R1039 - General Learning Space - (50.57 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1040 - Movement - (8.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R1044 - General Learning Space - (57.76 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1046 - Staff Study - (25.67 SQM)	● Office (6)	
B00D - R1047 - Staff Study - (12.46 SQM)	● Office (3)	
B00D - R1048 - General Learning Space - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1049 - General Learning Space - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1050 - General Learning Space - (57.73 SQM) - Teaching Space: 1	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1051 - Interview/Office - Type 1 - (12.8 SQM)	Office (3)	
B00D - R1053 - General Learning Space - (51.59 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1054 - Movement - (161.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R1055 - Performance Workspace - (110.76 SQM) - Teaching Space: 1	Student Space (51)	
B00E - R0018 - General Learning Space - (49.64 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0019 - General Learning Space - (57.78 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0020 - Staff Study - (19.2 SQM)	Office (4)	
B00E - R0021 - Staff Study - (25.72 SQM)	Office (6)	
B00E - R0022 - Staff Study - (11.22 SQM)	Office (2)	
B00E - R0023 - Senior Study - (25.89 SQM)	Office (6)	
B00E - R0024 - Senior Study - (65.4 SQM)	Office (16)	
B00E - R0025 - Senior Study - (31.78 SQM)	Office (7)	
B00E - R0026 - Movement - (16.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R0027 - Seminar - (16.85 SQM)	Office (4)	
B00E - R0028 - Seminar - (16.95 SQM)	Office (4)	
B00E - R0029 - Seminar - (15.29 SQM)	Office (3)	
B00E - R0030 - Seminar - (14.65 SQM)	Office (3)	
B00E - R0032 - Workroom - (41.34 SQM)	Office (10)	
B00E - R0033 - Audio Visual Workroom - (26.07 SQM)	Student Space (12)	
B00E - R0036 - Main Area - (387.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0038 - Movement - (195.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R1028 - Movement - (10.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R1029 - General Learning Space - (57.75 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1030 - Workroom - (25.67 SQM)	Office (6)	
B00E - R1031 - General Learning Space - (52.09 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1032 - General Learning Space - (52.09 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1033 - General Learning Space - (57.74 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1034 - Interview/Office - Type 1 - (12.57 SQM)	Office (3)	
B00E - R1036 - General Learning Space - (51.09 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1039 - Movement - (9.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R1040 - Movement - (140.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R1041 - Laboratory L.S. - (84.32 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R1042 - Preparation - (22.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R1044 - Preparation - (12.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R1045 - Laboratory L.S. - (91.85 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R1049 - General Learning Space - (50.58 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0001 - Student Canteen - (15.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Public Entry - (24.25 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Multi-Purpose Space - (448.77 SQM)	Student Space (208)	
B00F - R0006 - Stage - (94.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Movement - (6.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (6.35 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Staff Study - (16.85 SQM)	Office (4)	
B00G - R0004 - Metal Technology Bay - (128.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Welding Area - (6.93 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Welding Area - (6.93 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Outdoor Workshop - (66.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Darkroom Space - (12.72 SQM)	Office (3)	
B00I - R0001 - Gymnasium - (543.22 SQM)	Student Space (252)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 507 10410 - OS 507 10410 - Administration - Library - (95 SQM)	 Office (23)	
OS 621 10290 - OS 621 10290 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	
OS 621 19716 - OS 621 19716 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	