

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>The Rock Central School (2976)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Wagga Wagga</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lockhart</b>

2976 - The Rock Central School  
Site Plan (10710)



1:833

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0002 - Food Technology L.S. - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0002 - Materials Technology L.S. - (93.07 SQM) - Teaching Space: 1	● Student Space (43)	
B00F - R0002 - Home Base - (59.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0003 - Practical Activities - 1hb - (17.79 SQM)	● Student Space (8)	
B00F - R0005 - Practical Activities - 1hb - (17.77 SQM)	● Student Space (8)	
B00F - R0006 - Home Base - (59.82 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0009 - Withdrawal Space - 1hb - (11.75 SQM)	● Student Space (5)	
B00G - R0001 - Home Base - (86.72 SQM) - Teaching Space: 1	● Student Space (40)	
B00G - R0003 - Movement - (11.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Staff Room Annexe - (18.27 SQM)	● Office (4)	
B00H - R0001 - Home Base - (46.82 SQM) - Teaching Space: 1	● Student Space (21)	
B00H - R0003 - Movement - (36.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Home Base - (48.63 SQM) - Teaching Space: 1	● Student Space (22)	
B00H - R0005 - Home Base - (48.9 SQM) - Teaching Space: 1	● Student Space (22)	
B00H - R0006 - Home Base - (47.71 SQM) - Teaching Space: 1	● Student Space (22)	
B00H - R0009 - Movement - (20.06 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Staff Room Annexe - (8.87 SQM)	● Office (2)	
B00H - R0018 - Staff Study - (30.28 SQM)	● Office (7)	
B00I - R0001 - Computer Learning Space - (54.54 SQM) - Teaching Space: 1	● Student Space (25)	
B00J - R0003 - General Learning Space - (43.88 SQM) - Teaching Space: 1	● Student Space (20)	
B00K - R0001 - General Assistants - (33.87 SQM)	● Office (8)	
B00O - R0002 - Practical Activities - 1hb - (21.6 SQM)	● Student Space (10)	
B00O - R0004 - Home Base - (63.33 SQM) - Teaching Space: 1	● Student Space (29)	
B00O - R0005 - Withdrawal Space - 2hb - (10.83 SQM)	● Student Space (5)	
B00O - R0006 - Home Base - (63.33 SQM) - Teaching Space: 1	● Student Space (29)	
B00O - R0008 - Practical Activities - 1hb - (21.6 SQM)	● Student Space (10)	
B00S - R0006 - Canteen - (36.32 SQM)	Not Applicable	Circulation or storage space.
B00T - R0001 - Movement - (62.03 SQM)	Not Applicable	Circulation or storage space.
B00T - R0002 - Public Reception - (16.8 SQM)	Not Applicable	Circulation or storage space.
B00T - R0004 - Administration - Clerical - (34.81 SQM)	● Office (8)	
B00T - R0005 - Clerical/Printing - (12.32 SQM)	Not Applicable	Circulation or storage space.
B00T - R0007 - Movement - (24.22 SQM)	Not Applicable	Circulation or storage space.
B00T - R0008 - Principal Office - (14.51 SQM)	● Office (3)	
B00T - R0011 - Preparation - (11.45 SQM)	Not Applicable	Circulation or storage space.
B00T - R0013 - Laboratory L.S. - (59.02 SQM) - Teaching Space: 1	● Student Space (27)	
B00T - R0015 - Sick Bay - (5.46 SQM)	● Student Space (2)	
B00T - R0016 - Sick Bay - (6.29 SQM)	● Student Space (2)	
B00T - R0019 - Deputy Principal Office - (9.57 SQM)	● Office (2)	
B00T - R0020 - Interview - (5.99 SQM)	● Office (1)	
OS 534 12921 - OS 534 12921 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 601 10762 - OS 601 10762 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	