

VENTILATION AUDIT REPORT

| | |
|-------------------------------|---|
| SCHOOL: | Thornleigh West Public School (4276) |
| AMU REGION: | Northern Sydney |
| STATE ELECTORATE: | Hornsby |
| LOCAL GOVERNMENT AREA: | Hornsby |

4276 - Thornleigh West Public School
Site Plan (12636)










































1:1,016

Printed: 21-Mar-2020

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|--|-------------------------------|
| B00A - R0012 - Reading Area - (174.51 SQM) |  Student Space (80) | |
| B00A - R0013 - Special Programs Room - (69.67 SQM) |  Student Space (32) | |
| B00A - R0014 - Special Programs Room - (26.99 SQM) |  Student Space (12) | |
| B00B - R0001 - Clerical Office - (22.23 SQM) |  Office (5) | |
| B00B - R0002 - Duplicating Workroom - (29.24 SQM) |  Office (7) | |
| B00B - R0006 - Sick Bay - (6.67 SQM) |  Student Space (3) | |
| B00B - R0008 - Staff Room Annexe - (11.2 SQM) |  Office (2) | |
| B00B - R0009 - Deputy Principal - (13.13 SQM) |  Office (3) | |
| B00B - R0012 - Staff Room - (75.24 SQM) |  Office (18) | |
| B00B - R0014 - Home Base - (60.89 SQM) - Teaching Space: 1 |  Student Space (28) | |
| B00B - R0016 - Practical Activities - 1hb - (14.17 SQM) |  Student Space (6) | |
| B00B - R0018 - Principal - (16.77 SQM) |  Office (4) | |
| B00B - R0020 - Staff Room Annexe - (12.39 SQM) |  Office (3) | |
| B00B - R0021 - Movement - (6.68 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0022 - Entry Vestibule - (22.77 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0026 - Movement - (41.89 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0003 - Canteen - (40.29 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0007 - Practical Activities - 1hb - (25.73 SQM) |  Student Space (11) | |
| B00C - R0008 - Home Base - (56.89 SQM) - Teaching Space: 1 |  Student Space (26) | |
| B00C - R0012 - Practical Activities - 1hb - (12.46 SQM) |  Student Space (5) | |
| B00C - R0015 - Home Base - (57.04 SQM) - Teaching Space: 1 |  Student Space (26) | |
| B00C - R0016 - Home Base - (56.96 SQM) - Teaching Space: 1 |  Student Space (26) | |
| B00C - R0019 - Practical Activities - 1hb - (12.46 SQM) |  Student Space (5) | |
| B00C - R0022 - Home Base - (57.05 SQM) - Teaching Space: 1 |  Student Space (26) | |
| B00D - R0001 - Home Base - (57.52 SQM) - Teaching Space: 1 |  Student Space (26) | |
| B00D - R0006 - Home Base - (57.44 SQM) - Teaching Space: 1 |  Student Space (26) | |
| B00D - R0008 - Practical Activities - 2hb - (8.28 SQM) |  Student Space (3) | |
| B00D - R0011 - Withdrawal Space - 2hb - (11.9 SQM) |  Student Space (5) | |
| B00D - R1001 - Home Base - (63.97 SQM) - Teaching Space: 1 |  Student Space (29) | |
| B00D - R1002 - Home Base - (62.86 SQM) - Teaching Space: 1 |  Student Space (29) | |
| B00D - R1003 - Practical Activities - 1hb - (16.56 SQM) |  Student Space (7) | |
| B00D - R1004 - Withdrawal Space - 2hb - (11.29 SQM) |  Student Space (5) | |
| B00D - R1005 - Practical Activities - 1hb - (16.64 SQM) |  Student Space (7) | |
| B00E - R0003 - Home Base - (60.03 SQM) - Teaching Space: 1 |  Student Space (27) | |
| B00E - R0004 - Movement - (11.55 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0005 - Withdrawal Space - 1hb - (11.55 SQM) |  Student Space (5) | |
| B00E - R0006 - Home Base - (62.44 SQM) - Teaching Space: 1 |  Student Space (28) | |
| B00E - R0007 - Movement - (28.29 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0010 - Practical Activities - 1hb - (45.48 SQM) |  Student Space (21) | |
| B00E - R0012 - Special Programs Room - (32.38 SQM) |  Student Space (15) | |
| B00E - R0015 - Movement - (19.57 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0016 - Home Base - (60.02 SQM) - Teaching Space: 1 |  Student Space (27) | |
| B00E - R0018 - Withdrawal Space - 1hb - (11.62 SQM) |  Student Space (5) | |
| B00E - R0020 - Home Base - (60.02 SQM) - Teaching Space: 1 |  Student Space (27) | |
| B00E - R0027 - Practical Activities - 1hb - (71 SQM) |  Student Space (32) | |
| B00E - R0028 - Movement - (18.74 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0029 - Home Base - (60.27 SQM) - Teaching Space: 1 |  Student Space (27) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00E - R1003 - Home Base - (60.03 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00E - R1004 - Movement - (11.55 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R1005 - Seminar/Study - (11.55 SQM) | ● Office (2) | |
| B00E - R1006 - Home Base - (62.44 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00E - R1007 - Movement - (28.29 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R1010 - Practical Activities - 1hb - (45.49 SQM) | ● Student Space (21) | |
| B00E - R1012 - Special Programs Room - (32.38 SQM) | ● Student Space (15) | |
| B00E - R1015 - Seminar/Study - (15.05 SQM) | ● Office (3) | |
| B00E - R1016 - Movement - (19.57 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R1017 - Practical Activities - 1hb - (49.58 SQM) | ● Student Space (23) | |
| B00E - R1020 - Home Base - (59.25 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00E - R1021 - Seminar/Study - (11.52 SQM) | ● Office (2) | |
| B00E - R1022 - Home Base - (65.04 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00E - R1025 - Movement - (24.18 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R9002 - Movement - (29.32 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R9004 - Movement - (9.26 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0002 - Canteen - (24.81 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0008 - Raised Platform - (72.7 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0009 - Staff Room - (34.65 SQM) | ● Office (8) | |
| B00G - R0011 - Movement - (52.08 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0015 - Communal Space - (367.84 SQM) | ● Student Space (170) | |
| B00H - R0001 - Withdrawal Space - 2hb - (46.73 SQM) | ● Student Space (21) | |
| B00H - R0002 - Practical Activities - 1hb - (46.6 SQM) | ● Student Space (21) | |
| B00J - R0001 - Home Base - (54.99 SQM) - Teaching Space: 1 | ● Student Space (25) | |
| B00J - R0003 - Practical Activities - 1hb - (21.06 SQM) | ● Student Space (9) | |
| B00J - R0006 - Movement - (31.28 SQM) | Not Applicable | Circulation or storage space. |
| B00J - R0011 - Home Base - (47.86 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00J - R0013 - Practical Activities - 1hb - (21.12 SQM) | ● Student Space (9) | |
| B00J - R0018 - Practical Activities - 1hb - (21.07 SQM) | ● Student Space (9) | |
| B00J - R0020 - Home Base - (54.99 SQM) - Teaching Space: 1 | ● Student Space (25) | |
| B00K - R0003 - Practical Activities - 1hb - (16.95 SQM) | ● Student Space (7) | |
| B00K - R0005 - Home Base - (84.77 SQM) - Teaching Space: 1 | ● Student Space (39) | |
| B00K - R0006 - Home Base - (84.77 SQM) - Teaching Space: 1 | ● Student Space (39) | |
| B00K - R0008 - Practical Activities - 1hb - (17.65 SQM) | ● Student Space (8) | |
| OS 602 18273 - OS 602 18273 - Learning Unit - Standard With P.A.A. - (76 SQM) | ● Student Space (35) | |
| OS 606 19147 - OS 606 19147 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | ● Student Space (35) | |
| OS 606 19148 - OS 606 19148 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | ● Student Space (35) | |
| OS 606 19607 - OS 606 19607 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | ● Student Space (35) | |