

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Thornton Public School (3204)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Maitland</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Maitland</b>













## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (21.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Principal - (18.08 SQM)	Office (4)	
B00A - R0005 - Staff Room Annexe - (13.09 SQM)	Office (3)	
B00A - R0008 - Staff Room Annexe - (26.94 SQM)	Office (6)	
B00A - R0009 - Staff Room - (59.04 SQM)	Office (14)	
B00A - R0010 - Staff Room Annexe - (13.44 SQM)	Office (3)	
B00A - R0016 - Duplicating Workroom - (30.23 SQM)	Office (7)	
B00A - R0018 - Sick Bay - (8.85 SQM)	Student Space (4)	
B00A - R0022 - Movement - (11.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Clerical Office - (33.74 SQM)	Office (8)	
B00A - R0024 - Movement - (20.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Entry Vestibule - (14.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (63.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (9.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Reading Area - (176.54 SQM)	Student Space (81)	
B00C - R0005 - Special Programs Room - (44.58 SQM)	Student Space (20)	
B00D - R0005 - Withdrawal Space - 1hb - (7.49 SQM)	Student Space (3)	
B00D - R0006 - Home Base - (63.67 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0007 - Practical Activities - 1hb - (18.19 SQM)	Student Space (8)	
B00D - R0008 - Home Base - (63.16 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0009 - Practical Activities - 1hb - (18.19 SQM)	Student Space (8)	
B00D - R0011 - Withdrawal Space - 1hb - (6.83 SQM)	Student Space (3)	
B00D - R0013 - Movement - (126.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (320.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Withdrawal Space - 1hb - (6.72 SQM)	Student Space (3)	
B00E - R0005 - Home Base - (63.16 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0006 - Practical Activities - 1hb - (18.03 SQM)	Student Space (8)	
B00E - R0007 - Home Base - (62.92 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0008 - Practical Activities - 1hb - (18.14 SQM)	Student Space (8)	
B00E - R0010 - Withdrawal Space - 1hb - (6.61 SQM)	Student Space (3)	
B00E - R0015 - Withdrawal Space - 1hb - (6.61 SQM)	Student Space (3)	
B00E - R0016 - Home Base - (63.24 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0017 - Practical Activities - 1hb - (18.13 SQM)	Student Space (8)	
B00E - R0018 - Home Base - (63.08 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0019 - Practical Activities - 1hb - (18.07 SQM)	Student Space (8)	
B00E - R0021 - Withdrawal Space - 1hb - (12.45 SQM)	Student Space (5)	
B00E - R0024 - Home Base - (63.04 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0025 - Practical Activities - 1hb - (18.21 SQM)	Student Space (8)	
B00E - R0026 - Home Base - (63.45 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0027 - Practical Activities - 1hb - (17.88 SQM)	Student Space (8)	
B00E - R0029 - Withdrawal Space - 1hb - (12.53 SQM)	Student Space (5)	
B00E - R0033 - Home Base - (63.09 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0034 - Practical Activities - 1hb - (17.68 SQM)	Student Space (8)	
B00E - R0035 - Home Base - (63.26 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0036 - Practical Activities - 1hb - (18.05 SQM)	Student Space (8)	
B00E - R0038 - Withdrawal Space - 1hb - (6.62 SQM)	Student Space (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0001 - Withdrawal Space - 1hb - (8.71 SQM)	● Student Space (4)	
B00F - R0002 - Home Base - (47.46 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R0004 - Practical Activities - 1hb - (26.21 SQM)	● Student Space (12)	
B00F - R0005 - Home Base - (47.95 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R0006 - Practical Activities - 1hb - (27.69 SQM)	● Student Space (12)	
B00F - R0007 - Withdrawal Space - 1hb - (7.36 SQM)	● Student Space (3)	
B00G - R0001 - Movement - (47.61 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (24.62 SQM)	● Student Space (11)	
B00G - R0003 - Home Base - (67.05 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R0005 - Withdrawal Space - 1hb - (10.7 SQM)	● Student Space (4)	
B00G - R0007 - Home Base - (67.71 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R0008 - Practical Activities - 1hb - (25.12 SQM)	● Student Space (11)	
B00H - R0004 - Movement - (6.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Canteen - (47.79 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (6.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0021 - Home Base - (65.71 SQM) - Teaching Space: 1	● Student Space (30)	
B00H - R0022 - Home Base - (67.74 SQM) - Teaching Space: 1	● Student Space (31)	
B00H - R0023 - Practical Activities - 1hb - (20.25 SQM)	● Student Space (9)	
B00H - R0024 - Withdrawal Space - 2hb - (12.43 SQM)	● Student Space (5)	
B00H - R0025 - Practical Activities - 1hb - (20.45 SQM)	● Student Space (9)	
B00J - R0011 - Movement - (33.93 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Special Programs Room - (22.5 SQM)	● Student Space (10)	
B00J - R0013 - Special Programs Room - (21.95 SQM)	● Student Space (10)	
B00J - R0015 - Movement - (22.25 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Interview - (27.52 SQM)	● Office (6)	
B00J - R0017 - Movement - (32.81 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Withdrawal Space - 1hb - (6.78 SQM)	● Student Space (3)	
B00K - R0005 - Home Base - (63.28 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R0006 - Practical Activities - 1hb - (18.86 SQM)	● Student Space (8)	
B00K - R0007 - Practical Activities - 1hb - (18.83 SQM)	● Student Space (8)	
B00K - R0008 - Home Base - (63.2 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R0009 - Withdrawal Space - 1hb - (6.78 SQM)	● Student Space (3)	
B00K - R0012 - Movement - (64.11 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Withdrawal Space - 1hb - (6.79 SQM)	● Student Space (3)	
B00L - R0005 - Home Base - (63.05 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R0006 - Practical Activities - 1hb - (18.86 SQM)	● Student Space (8)	
B00L - R0007 - Practical Activities - 1hb - (18.83 SQM)	● Student Space (8)	
B00L - R0008 - Home Base - (63.21 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R0009 - Withdrawal Space - 1hb - (6.78 SQM)	● Student Space (3)	
B00L - R0012 - Movement - (56.51 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00M - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00M - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00O - R0002 - Special Programs Room - Type 1 - (61.86 SQM)	● Student Space (28)	
B00O - R0007 - Staff Kitchen - (15.14 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0002 - Communal Space - (198.82 SQM)	 Student Space (92)	
B00P - R0003 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00P - R0004 - Raised Platform - (59.1 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Movement - (12.84 SQM)	Not Applicable	Circulation or storage space.
B00P - R0006 - Movement - (14.96 SQM)	Not Applicable	Circulation or storage space.
OS 602 16287 - OS 602 16287 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 10951 - OS 606 10951 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 13198 - OS 606 13198 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 17891 - OS 606 17891 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 18245 - OS 606 18245 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19102 - OS 606 19102 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19212 - OS 606 19212 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19575 - OS 606 19575 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19894 - OS 606 19894 - Learning Unit - Standard With P.A.A A/C - ( SQM)	 Student Space ( )	