

VENTILATION AUDIT REPORT

SCHOOL:	Timbumburi Public School (1016)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Tamworth
LOCAL GOVERNMENT AREA:	Tamworth

1016 - Timbumburi Public School
Site Plan (11170)



1:826

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Practical Activities - 1hb - (17.79 SQM)	● Student Space (8)	
B00A - R0003 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0006 - Withdrawal Space - 1hb - (11.89 SQM)	● Student Space (5)	
B00A - R0009 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0010 - Practical Activities - 1hb - (17.79 SQM)	● Student Space (8)	
B00B - R0003 - Reading Area - (77.74 SQM)	● Student Space (36)	
B00B - R0006 - Reading Area - (62.55 SQM)	● Student Space (29)	
B00C - R0002 - Home Base - (57.67 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0002 - Canteen - (28.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Home Base - (48.79 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0002 - Practical Activities - 1hb - (19.36 SQM)	● Student Space (8)	
B00E - R0004 - Home Base - (58.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	● Student Space (4)	
B00E - R0006 - Home Base - (58.67 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0008 - Practical Activities - 1hb - (19.36 SQM)	● Student Space (8)	
NS 020 17667 - NS 020 17667 - Staff Study/Store - (38 SQM)	Not Applicable	Circulation or storage space.
OS 505 15595 - OS 505 15595 - Admin Staff/Principal/Secure Store - (76 SQM)	● Office (19)	
OS 606 19037 - OS 606 19037 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	