

VENTILATION AUDIT REPORT

SCHOOL:	Tingha Public School (3218)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Armidale

3218 - Tingha Public School
Site Plan (11934)



1:1,062

Printed: 21-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Principal - (18.54 SQM)	Office (4)	
B00A - R0003 - Entry Vestibule - (13.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - (52.15 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0005 - Sick Bay - (6.77 SQM)	Student Space (3)	
B00A - R0007 - Home Base - (47.68 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0008 - Withdrawal Space - 1hb - (9.37 SQM)	Student Space (4)	
B00A - R0012 - Reading Area - (82.18 SQM)	Student Space (38)	
B00A - R0015 - Practical Activities - 1hb - (32.48 SQM)	Student Space (15)	
B00A - R0016 - Movement - (21.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Staff Room - (30.42 SQM)	Office (7)	
B00A - R0022 - Clerical Office - (21.88 SQM)	Office (5)	
B00A - R0023 - Practical Activities - (36.33 SQM)	Student Space (16)	
B00A - R0024 - Communal Space - (78.19 SQM)	Student Space (36)	
B00B - R0002 - Home Base - (78.87 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0004 - Home Base - (55.03 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0007 - Home Base - (77.12 SQM) - Teaching Space: 1	Student Space (35)	
B00B - R0012 - Movement - (19.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Practical Activities - 1hb - (14.62 SQM)	Student Space (6)	
B00B - R0014 - Movement - (20.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Practical Activities - M - 1hb - (14.76 SQM)	Student Space (6)	
B00H - R0001 - Withdrawal Space - 1hb - (44.09 SQM)	Student Space (20)	
B00I - R0002 - Home Base - (52.23 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R0003 - Home Base - (52.67 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R0004 - Practical Activities - 1hb - (20.15 SQM)	Student Space (9)	
B00I - R0005 - Staff Room Annexe - (5.65 SQM)	Office (1)	
B00K - R0001 - Movement - (33.74 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Communal Space - (113.98 SQM)	Student Space (52)	
OS 600 13225 - OS 600 13225 - Learning Unit - Small - (57 SQM)	Student Space (26)	