

VENTILATION AUDIT REPORT

SCHOOL:	Tinonee Public School (3219)
AMU REGION:	North Coast
STATE ELECTORATE:	Myall Lakes
LOCAL GOVERNMENT AREA:	Mid-Coast

3219 - Tinonee Public School
Site Plan (12043)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office - (21.56 SQM)	Office (5)	
B00A - R0003 - Duplicating Workroom - (18.04 SQM)	Office (4)	
B00A - R0004 - Entry Vestibule - (6.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Interview - (9.72 SQM)	Office (2)	
B00A - R0006 - Movement - (10.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Staff Room Annexe - (11.22 SQM)	Office (2)	
B00A - R0008 - Principal - (14.62 SQM)	Office (3)	
B00A - R0010 - Sick Bay - (7.04 SQM)	Student Space (3)	
B00A - R0011 - Canteen - (29.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Canteen - (14.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Staff Room Annexe - (22.09 SQM)	Office (5)	
B00B - R0003 - Staff Room Annexe - (13.99 SQM)	Office (3)	
B00B - R0005 - Seminar/Study - (13.98 SQM)	Office (3)	
B00B - R0006 - Staff Room Annexe - (17.52 SQM)	Office (4)	
B00B - R0007 - Staff Room - (13.36 SQM)	Office (3)	
B00B - R0009 - Movement - (9.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Staff Kitchen - (10.37 SQM)	Office (2)	
B00D - R0001 - Movement - (14.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Withdrawal Space - 1hb - (5.97 SQM)	Student Space (2)	
B00E - R0005 - Home Base - (61.02 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0006 - Practical Activities - 1hb - (18.5 SQM)	Student Space (8)	
B00E - R0007 - Home Base - (61.41 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0008 - Practical Activities - 1hb - (18.09 SQM)	Student Space (8)	
B00E - R0009 - Withdrawal Space - 1hb - (6.54 SQM)	Student Space (3)	
B00F - R0004 - Withdrawal Space - 1hb - (6.51 SQM)	Student Space (3)	
B00F - R0006 - Home Base - (61.72 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0007 - Practical Activities - 1hb - (18.11 SQM)	Student Space (8)	
B00F - R0008 - Home Base - (61.39 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0009 - Practical Activities - 1hb - (17.94 SQM)	Student Space (8)	
B00F - R0010 - Withdrawal Space - 1hb - (5.99 SQM)	Student Space (2)	
B00H - R0004 - Withdrawal Space - 1hb - (6.53 SQM)	Student Space (3)	
B00H - R0006 - Home Base - (61.56 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0007 - Practical Activities - 1hb - (18.26 SQM)	Student Space (8)	
B00H - R0008 - Home Base - (61.47 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0009 - Practical Activities - 1hb - (18.29 SQM)	Student Space (8)	
B00H - R0010 - Withdrawal Space - 1hb - (6.59 SQM)	Student Space (3)	
B00I - R0002 - Reading Area - (60.81 SQM)	Student Space (28)	
B00I - R0003 - Reading Area - (21.69 SQM)	Student Space (10)	
B00I - R0004 - Special Programs Room - (32.66 SQM)	Student Space (15)	
B00I - R0005 - Movement - (5.76 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Communal Space - (144.97 SQM)	Student Space (67)	
B00J - R0002 - Raised Platform - (57.2 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Movement - (6.73 SQM)	Not Applicable	Circulation or storage space.
B00J - R0017 - Movement - (15.95 SQM)	Not Applicable	Circulation or storage space.
OS 601 70101 - OS 601 70101 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	