


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Tintinhull Public School (3221)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Tamworth</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Tamworth</b>

3221 - Tintinhull Public School  
Site Plan (11489)



















1:1,232

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office/Workroom - (14.38 SQM)	 Office (3)	
B00A - R0002 - Entry Vestibule - (8.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Home Base - (51.31 SQM) - Teaching Space: 1	 Student Space (23)	
B00C - R0001 - Principal - (10.67 SQM)	 Office (2)	
B00C - R0003 - Clerical Office/Workroom - (17.49 SQM)	 Office (4)	
B00C - R0004 - Sick Bay - (5.49 SQM)	 Student Space (2)	
B00C - R0005 - Staff Kitchen - (6.45 SQM)	 Office (1)	
B00C - R0006 - Staff Room - (12.22 SQM)	 Office (3)	
B00D - R0002 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
B00D - R0004 - Home Base - (58.76 SQM) - Teaching Space: 1	 Student Space (27)	
B00D - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	 Student Space (4)	
B00D - R0006 - Home Base - (58.67 SQM) - Teaching Space: 1	 Student Space (27)	
B00D - R0008 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
B00E - R0002 - Reading Area - (92.96 SQM)	 Student Space (43)	
B00F - R0001 - Movement - (16.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Staff Room - (17.47 SQM)	 Office (4)	
B00F - R0008 - Staff Kitchen - (18.69 SQM)	 Office (4)	
OS 602 14151 - OS 602 14151 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	