

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Tomerong Public School (3226)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>South Coast</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Shoalhaven</b>

3226 - Tomerong Public School  
Site Plan (13197)



1:969

Printed: 15-Jun-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Canteen - (11.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Entry Vestibule - (9.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Sick Bay - (6.17 SQM)	● Student Space (2)	
B00A - R0006 - Principal - (16.77 SQM)	● Office (4)	
B00A - R0007 - Clerical Office - (15.13 SQM)	● Office (3)	
B00A - R0009 - Staff Room Annexe - (14.6 SQM)	● Office (3)	
B00A - R0011 - Staff Room - (19.35 SQM)	● Office (4)	
B00A - R0013 - Clerical Office/Workroom - (11.14 SQM)	● Office (2)	
B00A - R0016 - Duplicating Workroom - (5.56 SQM)	● Office (1)	
B00A - R0017 - Staff Kitchen - (11.88 SQM)	● Office (2)	
B00C - R0001 - Practical Activities - 1hb - (26.23 SQM)	● Student Space (12)	
B00C - R0003 - Withdrawal Space - 1hb - (5.97 SQM)	● Student Space (2)	
B00C - R0004 - Home Base - (51.68 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0006 - Practical Activities - 1hb - (25.66 SQM)	● Student Space (11)	
B00C - R0008 - Withdrawal Space - 1hb - (5.93 SQM)	● Student Space (2)	
B00C - R0009 - Home Base - (51.67 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R0001 - Reading Area - (53.57 SQM)	● Student Space (24)	
B00F - R0002 - Reading Area - (16.37 SQM)	● Student Space (7)	
B00F - R0005 - Movement - (7.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Withdrawal Space - 1hb - (5.93 SQM)	● Student Space (2)	
B00H - R0002 - Home Base - (51.61 SQM) - Teaching Space: 1	● Student Space (23)	
B00H - R0003 - Practical Activities - 1hb - (25.16 SQM)	● Student Space (11)	
B00H - R0006 - Practical Activities - 1hb - (26.27 SQM)	● Student Space (12)	
B00H - R0008 - Home Base - (51.53 SQM) - Teaching Space: 1	● Student Space (23)	
B00H - R0009 - Withdrawal Space - 1hb - (5.93 SQM)	● Student Space (2)	
B00J - R0002 - Practical Activities - 1hb - (19.36 SQM)	● Student Space (8)	
B00J - R0004 - Home Base - (58.75 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	● Student Space (4)	
B00J - R0006 - Home Base - (58.66 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (19.36 SQM)	● Student Space (8)	
B00K - R0002 - Staff Room - (37.17 SQM)	● Office (9)	
B00K - R0003 - Staff Kitchen - (5.93 SQM)	● Office (1)	
OS 606 19099 - OS 606 19099 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	