


VENTILATION AUDIT REPORT

SCHOOL:	Tooleybuc Central School (3235)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Murray
LOCAL GOVERNMENT AREA:	Murray River

3235 - Tooleybuc Central School
Site Plan (13566)



1:618

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (74.23 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R0002 - Home Base - (73.82 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R0004 - Home Base - (92.14 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1001 - Senior Study - (18.01 SQM)	Office (4)	
B00A - R1002 - Senior Study - (18.05 SQM)	Office (4)	
B00A - R1005 - Home Base - (74.81 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R1006 - Staff Room Annexe - (14.14 SQM)	Office (3)	
B00A - R1010 - Computer Learning Space - (89.17 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0008 - Canteen - (26.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (14.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (54.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Gymnasium - (26.95 SQM)	Student Space (12)	
B00B - R0018 - Movement - (9.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Laboratory L.S. - (79.42 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R1004 - Staff Room Annexe - (25.88 SQM)	Office (6)	
B00B - R1005 - Interview - (16.23 SQM)	Office (4)	
B00B - R1010 - Materials Technology L.S. - (89.39 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R1016 - Preparation - (18.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Withdrawal Space - 1hb - (22.16 SQM)	Student Space (10)	
B00C - R0003 - Home Base - (53.28 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0004 - General Learning Space - (52.91 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0005 - Interview - (10.92 SQM)	Office (2)	
B00C - R0006 - Deputy Principal - (10.69 SQM)	Office (2)	
B00C - R0007 - Food Technology L.S. - (60.5 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0008 - Kitchen - Type 2 - (45.91 SQM)	Student Space (21)	
B00C - R0013 - Dark Room - (6.23 SQM)	Office (1)	
B00D - R0005 - General Learning Space - (52.47 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0007 - General Learning Space - (53.21 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1002 - General Learning Space - (53.87 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1003 - General Learning Space - (52.25 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1004 - General Learning Space - (54.39 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0003 - Interview - (13.17 SQM)	Office (3)	
B00E - R0005 - Movement - (28.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Staff Room - (61.82 SQM)	Office (15)	
B00E - R0013 - Clerical Office - (7.74 SQM)	Office (1)	
B00E - R0016 - Clerical Office - (29.39 SQM)	Office (7)	
B00M - R0001 - Welding Area - (48.4 SQM)	Not Applicable	Circulation or storage space.
B00N - R0003 - Movement - (12.62 SQM)	Not Applicable	Circulation or storage space.
B00R - R0001 - Special Programs Room - (16.08 SQM)	Student Space (7)	
B00S - R0002 - Reading Area - (91.54 SQM)	Student Space (42)	