

VENTILATION AUDIT REPORT

SCHOOL:	Toongabbie East Public School (4366)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Seven Hills
LOCAL GOVERNMENT AREA:	Parramatta

4366 - Toongabbie East Public School
Site Plan (12878)



1:1,182

Printed: 28-Nov-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (36.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (30.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Home Base - (69.84 SQM)	● Student Space (32)	
B00A - R0008 - Home Base - (70.56 SQM)	● Student Space (32)	
B00A - R0012 - Home Base - (70.29 SQM)	● Student Space (32)	
B00A - R0013 - Home Base - (69.84 SQM)	● Student Space (32)	
B00A - R0019 - Practical Activities - 1hb - (21.52 SQM)	● Student Space (9)	
B00A - R0020 - Home Base - (47.63 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0021 - Home Base - (47.63 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0022 - Practical Activities - 1hb - (21.52 SQM)	● Student Space (9)	
B00A - R0023 - Practical Activities - 1hb - (21.52 SQM)	● Student Space (9)	
B00A - R0024 - Home Base - (47.63 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0025 - Home Base - (47.63 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0026 - Practical Activities - 1hb - (21.52 SQM)	● Student Space (9)	
B00A - R1002 - Movement - (29.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Home Base - (70.49 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R1007 - Reading Area - (273.01 SQM)	● Student Space (126)	
B00A - R1011 - Seminar/Study - (15.58 SQM)	● Office (3)	
B00B - R0001 - Duplicating Workroom - (12.96 SQM)	● Office (3)	
B00B - R0005 - Clerical Office - (14.35 SQM)	● Office (3)	
B00B - R0006 - Movement - (52.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Principal - (19.6 SQM)	● Office (4)	
B00B - R0013 - Sick Bay - (8.09 SQM)	● Student Space (3)	
B00B - R0014 - Deputy Principal - (13.74 SQM)	● Office (3)	
B00B - R0015 - Staff Room Annexe - (13.74 SQM)	● Office (3)	
B00B - R0016 - Interview - (13.62 SQM)	● Office (3)	
B00B - R0017 - Staff Room - (55.88 SQM)	● Office (13)	
B00B - R0021 - Home Base - (55.81 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0023 - Home Base - (56.03 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0026 - Home Base - (56.41 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0028 - Movement - (23.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R9001 - Special Programs Room - (51.92 SQM)	● Student Space (24)	
B00C - R0006 - Movement - (82.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (85.36 SQM) - Teaching Space: 1	● Student Space (39)	
B00C - R0008 - Home Base - (56.6 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0018 - Staff Room - (21.49 SQM)	● Office (5)	
B00C - R9002 - Home Base - (65.59 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R9005 - Movement - (31.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R9016 - Movement - (28.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R9017 - Movement - (28.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R9018 - Communal Space - (139.94 SQM)	● Student Space (64)	
B00C - R9019 - Raised Platform - (53.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R9020 - Movement - (12.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R9021 - Movement - (19.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (56.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - Pre - (66.47 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0007 - Withdrawal - Pre - (19.51 SQM)	● Student Space (9)	
B00D - R0008 - Home Base - Pre - (44.79 SQM) - Teaching Space: 1	● Student Space (20)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0012 - Home Base - Pre - (57.35 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0014 - Movement - (5.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R9002 - Home Base - (63.94 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R9005 - Movement - (11.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R9009 - Movement - (11.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Canteen - (9.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Canteen - (18.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (12.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Movement - (33.46 SQM)	Not Applicable	Circulation or storage space.