

VENTILATION AUDIT REPORT

SCHOOL:	Toongabbie Public School (3240)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Seven Hills
LOCAL GOVERNMENT AREA:	Parramatta

3240 - Toongabbie Public School
Site Plan (11171)



1:846

Printed: 15-May-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (24.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Withdrawal Space - 1hb - (27.6 SQM)	● Student Space (12)	
B00A - R0007 - Home Base - (34.05 SQM) - Teaching Space: 1	● Student Space (15)	
B00B - R0002 - Home Base - (86.06 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R0007 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (85.88 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R0010 - Home Base - (57.21 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0014 - Withdrawal Space - 1hb - (28.25 SQM)	● Student Space (13)	
B00C - R0006 - Home Base - (85.83 SQM) - Teaching Space: 1	● Student Space (39)	
B00C - R0007 - Home Base - (56.91 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0002 - Home Base - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0003 - Home Base - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0002 - Home Base - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0003 - Home Base - (52.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0001 - Home Base - (51.29 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R0003 - Movement - (46.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Practical Activities - 1hb - (42.71 SQM)	● Student Space (19)	
B00F - R0005 - Home Base - (50.84 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R0006 - Home Base - (50.94 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R0008 - Staff Room Annexe - (15.9 SQM)	○ Office (3)	
B00F - R0009 - Interview - (12.09 SQM)	○ Office (3)	
B00F - R0010 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Canteen - (42.91 SQM)	Not Applicable	Circulation or storage space.
B00H - R0026 - Reading Area - (193.71 SQM)	● Student Space (89)	
B00H - R0032 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Interview - (22.08 SQM)	○ Office (5)	
B00J - R0011 - Staff Room Annexe - (22.26 SQM)	○ Office (5)	
B00J - R0012 - Staff Room Annexe - (53.61 SQM)	○ Office (13)	
B00J - R0013 - Staff Room - (41.08 SQM)	○ Office (10)	
B00J - R0014 - Staff Kitchen - (12.3 SQM)	○ Office (3)	
B00K - R0001 - Deputy Principal - (15.12 SQM)	○ Office (3)	
B00K - R0004 - Clerical Office - (16.21 SQM)	○ Office (4)	
B00K - R0005 - Duplicating Workroom - (14.83 SQM)	○ Office (3)	
B00K - R0006 - Sick Bay - (9.03 SQM)	● Student Space (4)	
B00K - R0010 - Movement - (12.33 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Principal - (17.86 SQM)	○ Office (4)	
B00K - R0022 - Clerical Office - (27.43 SQM)	○ Office (6)	
B00L - R0002 - Home Base - (92.35 SQM) - Teaching Space: 1	● Student Space (42)	
B00L - R0004 - Home Base - (56.76 SQM) - Teaching Space: 1	● Student Space (26)	
B00L - R0006 - Movement - (5.24 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Deputy Principal - (10.34 SQM)	○ Office (2)	
B00L - R0008 - Home Base - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0005 - Home Base - (57.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0007 - Movement - (13.77 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Home Base - (57.2 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0010 - Home Base - (56.51 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0012 - Movement - (14.02 SQM)	Not Applicable	Circulation or storage space.
B00M - R0015 - Home Base - (57.99 SQM) - Teaching Space: 1	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R1002 - Movement - (120.54 SQM)	Not Applicable	Circulation or storage space.
B00M - R1003 - Home Base - (57.53 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R1005 - Movement - (13.88 SQM)	Not Applicable	Circulation or storage space.
B00M - R1007 - Home Base - (56.65 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R1008 - Home Base - (56.89 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R1010 - Movement - (13.73 SQM)	Not Applicable	Circulation or storage space.
B00M - R1013 - Home Base - (58.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00N - R0001 - Home Base - (57.46 SQM) - Teaching Space: 1	● Student Space (26)	
B00N - R0006 - Home Base - (56.77 SQM) - Teaching Space: 1	● Student Space (26)	
B00N - R0008 - Home Base - (56.84 SQM) - Teaching Space: 1	● Student Space (26)	
B00N - R0013 - Home Base - (57.31 SQM) - Teaching Space: 1	● Student Space (26)	
B00O - R0001 - Communal Space - (203.62 SQM)	● Student Space (94)	
B00O - R0002 - Raised Platform - (61.36 SQM)	Not Applicable	Circulation or storage space.
B00O - R0018 - Movement - (13.61 SQM)	Not Applicable	Circulation or storage space.
B00O - R0019 - Movement - (5.43 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Practical Activities - (11.89 SQM)	● Student Space (5)	