

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Toormina High School (8527)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Coffs Harbour</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Coffs Harbour</b>

Siteplan



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Administration - Clerical - (14.72 SQM)	Office (3)	
B00A - R0002 - Deputy Principal Office - (14.73 SQM)	Office (3)	
B00A - R0003 - Duplicating Workroom - (29.83 SQM)	Office (7)	
B00A - R0006 - Clinic - Girls - (12.2 SQM)	Office (3)	
B00A - R0008 - Clinic - Boys - (12.17 SQM)	Office (3)	
B00A - R0014 - Principal Office - (25.64 SQM)	Office (6)	
B00A - R0019 - Staff Study - (14.45 SQM)	Office (3)	
B00A - R0020 - Seminar - (28.72 SQM)	Office (7)	
B00A - R0022 - Interview/Office - Type 1 - (12.2 SQM)	Office (3)	
B00A - R0023 - Staff Study - (12.21 SQM)	Office (3)	
B00A - R0024 - Staff Study - (17.21 SQM)	Office (4)	
B00A - R0026 - Darkroom Space - (26.4 SQM)	Office (6)	
B00A - R0031 - Entry - (7.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Main Area - (300.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Workroom - (43.64 SQM)	Office (10)	
B00A - R0035 - Audio Visual Workroom - (41.81 SQM)	Student Space (19)	
B00A - R0036 - Study Space - (60.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Seminar - (14.93 SQM)	Office (3)	
B00A - R0038 - Seminar - (11.89 SQM)	Office (2)	
B00A - R0040 - Study Space - (104.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Seminar - (11.62 SQM)	Office (2)	
B00A - R0042 - Seminar - (13.24 SQM)	Office (3)	
B00A - R0047 - Staff Study - (110.44 SQM)	Office (27)	
B00A - R0048 - Staff Kitchen - (16.92 SQM)	Office (4)	
B00A - R0053 - Movement - (113.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Public Reception - (33.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Public Entry - (36.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Study Space - (15.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (8.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Special Learning Space - (52.15 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0010 - General Learning Space - (50.51 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0011 - General Learning Space - (50.65 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0012 - Staff Study - (37.81 SQM)	Office (9)	
B00B - R0013 - Movement - (68.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Special Learning Space - (86.07 SQM) - Teaching Space: 1	Student Space (39)	
B00C - M0003 - Staff Study - (20.42 SQM)	Office (5)	
B00C - M0007 - Staff Study - (16.38 SQM)	Office (4)	
B00C - R0001 - Administration - Clerical - (12.28 SQM)	Office (3)	
B00C - R0002 - Staff Study - (23.3 SQM)	Office (5)	
B00C - R0005 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0006 - General Learning Space - (53.01 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0008 - General Learning Space - (52.93 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0009 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0018 - Art Learning Space - (65.62 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0019 - Art Learning Space - (66.17 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0021 - Art Learning Space - (66.18 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0023 - Workshop - (51.29 SQM)	Student Space (23)	
B00C - R0024 - Art Learning Space - (64.66 SQM) - Teaching Space: 1	Student Space (29)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0026 - Music Learning Space - (71.6 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R0027 - Practice/Seminar - (25.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0029 - Music Learning Space - (91.65 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0030 - Staff Study - (16.79 SQM)	● Office (4)	
B00C - R0033 - Materials Technology L.S. - (67 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0037 - Materials Technology L.S. - (66.87 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0038 - Food Technology L.S. - (104.34 SQM) - Teaching Space: 1	● Student Space (48)	
B00C - R0040 - Preparation - (10.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0043 - Food Technology L.S. - (104.96 SQM) - Teaching Space: 1	● Student Space (48)	
B00C - R0045 - Movement - (96.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0046 - Movement - (16.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0048 - Movement - (8.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0049 - Movement - (13.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0052 - Duplicating Workroom - (18.7 SQM)	● Office (4)	
B00C - R0058 - Movement - (49.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0065 - Movement - (14.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0072 - Practice/Seminar - (26.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0076 - Art Entry/Display - (82.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0078 - Movement - (5.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0081 - Movement - (36.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R0082 - Movement - (271.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R0083 - Movement - (116.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Senior Study - (38.96 SQM)	● Office (9)	
B00C - R1004 - Staff Study - (70.64 SQM)	● Office (17)	
B00C - R1007 - Study Space - (17.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - General Learning Space - (39.34 SQM) - Teaching Space: 1	● Student Space (18)	
B00C - R1009 - General Learning Space - (39.33 SQM) - Teaching Space: 1	● Student Space (18)	
B00C - R1011 - Staff Study - (30.7 SQM)	● Office (7)	
B00C - R1013 - Movement - (107.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R1018 - Movement - (40.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R1019 - Tiered Learning Area - (29.41 SQM)	● Student Space (13)	
B00C - R1020 - Tiered Learning Area - (14.81 SQM)	● Student Space (6)	
B00C - R1021 - Movement - (11.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R2001 - General Learning Space - (50.29 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R2006 - General Learning Space - (50.43 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R2007 - General Learning Space - (50.37 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R2008 - General Learning Space - (38.63 SQM) - Teaching Space: 1	● Student Space (17)	
B00C - R2012 - Senior Study - (29.24 SQM)	● Office (7)	
B00C - R2013 - Movement - (72.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (23.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (23.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Multi-Purpose Space - (462.04 SQM)	● Student Space (214)	
B00D - R0018 - Movement - (30.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Staff Study - (25.17 SQM)	● Office (6)	
B00D - R0021 - Gymnasium - (24.86 SQM)	● Student Space (11)	
B00D - R0024 - Movement - (53.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - Movement - (240.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Student Canteen - (62.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - Movement - (42.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0032 - Movement - (71.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0002 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0003 - Movement - (26.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - General Learning Space - (52.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0005 - General Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0011 - Movement - (107.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Movement - (13.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Movement - (8.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Laboratory L.S. - (92.41 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0015 - Preparation - (53.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Laboratory L.S. - (92.73 SQM) - Teaching Space: 1	● Student Space (43)	
B00E - R0018 - Laboratory L.S. - (92.08 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0019 - Staff Study - (30.72 SQM)	● Office (7)	
B00E - R0022 - Movement - (59.58 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Materials Technology L.S. - (105.64 SQM) - Teaching Space: 1	● Student Space (49)	
B00E - R0027 - Metal Technology Bay - (24.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - Welding Area - (5.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0030 - Design L.S. - (70.64 SQM) - Teaching Space: 1	● Student Space (32)	
B00E - R0031 - Seminar Space - (24.58 SQM)	● Office (6)	
B00E - R0033 - Materials Technology L.S. - (96.31 SQM) - Teaching Space: 1	● Student Space (44)	
B00E - R0034 - Wood Technology Bay - (20.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0035 - Materials Technology L.S. - (96.31 SQM) - Teaching Space: 1	● Student Space (44)	
B00E - R0039 - Staff Study - (19.83 SQM)	● Office (4)	
B00E - R0042 - Design L.S. - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0044 - Design L.S. - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0048 - Movement - (8.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0050 - Laboratory L.S. - (92.03 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0051 - Preparation - (64.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R0052 - Laboratory L.S. - (92.08 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0054 - Laboratory L.S. - (92.31 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0057 - Movement - (81.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0063 - General Learning Space - (51.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0064 - General Learning Space - (52.99 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0066 - General Learning Space - (52.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0067 - General Learning Space - (51.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0069 - Deputy Principal Office - (21.82 SQM)	● Office (5)	
B00E - R0071 - Staff Study - (12.2 SQM)	● Office (3)	
B00E - R0073 - Movement - (456.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0075 - Movement - (11.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0076 - Movement - (11.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0077 - Movement - (5.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R0080 - Movement - (5.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0081 - Movement - (5.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0082 - Movement - (11.73 SQM)	Not Applicable	Circulation or storage space.
B00E - R0083 - Movement - (11.72 SQM)	Not Applicable	Circulation or storage space.
B00E - R0084 - Movement - (6.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0085 - Movement - (11.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R0086 - Staff Study - (14.41 SQM)	● Office (3)	
B00E - R0088 - Commonroom - (67.62 SQM)	● Office (16)	
B00E - R0089 - Commonroom - (30.58 SQM)	● Office (7)	
B00E - R0091 - Materials Workshop - Type 2 - (35.94 SQM)	● Student Space (16)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0093 - Movement - (123.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - General Assistants - (24.95 SQM)	 Office (6)	
OS 601 13630 - OS 601 13630 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	