

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Toronto High School (8909)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lake Macquarie</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

8909 - Toronto High School  
Site Plan (10750)



1:1,395

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Principal Office - (19 SQM)	Office (4)	
B00A - R0015 - General Learning Space - (52.88 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0024 - Administration - Clerical - (20.66 SQM)	Office (5)	
B00A - R0028 - Special Learning Space - (79.45 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0031 - General Learning Space - (66.29 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0032 - Staff Study - (42.78 SQM)	Office (10)	
B00A - R0045 - Movement - (8.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Movement - (12.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0047 - Interview/Office - Type 1 - (12.39 SQM)	Office (3)	
B00A - R0050 - Administration - Clerical - (41.42 SQM)	Office (10)	
B00A - R0052 - Movement - (58.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Deputy Principal Office - (16.29 SQM)	Office (4)	
B00A - R0056 - Duplicating Workroom - (26.04 SQM)	Office (6)	
B00A - R0061 - Clinic - Girls - (12.44 SQM)	Office (3)	
B00A - R0062 - Clinic - Boys - (14.09 SQM)	Office (3)	
B00A - R0063 - Interview/Office - Type 1 - (11.87 SQM)	Office (2)	
B00A - R0064 - Leading Teacher - (13.23 SQM)	Office (3)	
B00A - R0066 - General Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0067 - General Learning Space - (52.75 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0072 - Kitchen - Type 3 - (18.81 SQM)	Student Space (8)	
B00A - R0074 - General Learning Space - M - (53.11 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0075 - General Learning Space - (53.11 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0076 - Computer Learning Space - (79.74 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0079 - Movement - (89.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0080 - Movement - (193.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Ancillary Staff - (8.56 SQM)	Office (2)	
B00A - R1007 - Staff Study - (26.26 SQM)	Office (6)	
B00A - R1018 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1021 - Staff Study - (25.74 SQM)	Office (6)	
B00A - R1022 - Staff Study - (25.6 SQM)	Office (6)	
B00A - R1023 - Staff Study - (46.41 SQM)	Office (11)	
B00A - R1024 - Study Space - (12.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R1027 - General Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1032 - Staff Study - (25.74 SQM)	Office (6)	
B00A - R1035 - General Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1040 - Movement - (214.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R1041 - Audio Visual Workroom - (72.93 SQM)	Student Space (33)	
B00A - R1043 - Staff Study - (25.85 SQM)	Office (6)	
B00A - R1044 - General Learning Space - (53.04 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1045 - General Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1046 - General Learning Space - (52.75 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1048 - General Learning Space - (52.96 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1049 - Study Space - (26 SQM)	Not Applicable	Circulation or storage space.
B00A - R1050 - General Learning Space - (53.17 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1051 - General Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1052 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1058 - Staff Kitchen - (24.45 SQM)	Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1059 - Staff Study - (12.23 SQM)	Office (3)	
B00A - R1060 - Staff Lounge - (103.44 SQM)	Office (25)	
B00B - R0004 - Movement - (76.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (397.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (214.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - General Assistants - (8.82 SQM)	Office (2)	
B00B - R0017 - Gymnasium - (56.35 SQM)	Student Space (26)	
B00B - R0018 - Student Canteen - (45.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Design/Technology L.S. - (97.87 SQM) - Teaching Space: 1	Student Space (45)	
B00C - R0025 - Design/Technology L.S. - (73.19 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R0026 - Seminar - (15.26 SQM)	Office (3)	
B00C - R0027 - Staff Study - (10.56 SQM)	Office (2)	
B00C - R0028 - Staff Study - (34.32 SQM)	Office (8)	
B00C - R0031 - Design/Technology L.S. - (59.69 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0034 - Design/Technology L.S. - (45.15 SQM) - Teaching Space: 1	Student Space (20)	
B00C - R0040 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0044 - Materials Workshop - Type 3 - (121.7 SQM)	Student Space (56)	
B00C - R0045 - General Learning Space - (30.91 SQM) - Teaching Space: 1	Student Space (14)	
B00C - R0046 - Movement - (78.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R0047 - Workshop - (58.45 SQM)	Student Space (27)	
B00E - M0001 - Stage - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00E - M0003 - Stage - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (9.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (46.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Stage - (70.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (9.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Multi-Purpose Space - (16.08 SQM)	Student Space (7)	
B00E - R0010 - Staff Study - (18.73 SQM)	Office (4)	
B00E - R0016 - Gymnasium - (518.93 SQM)	Student Space (240)	
B00E - R0017 - Movement - (226.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Main Area - (401.81 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Audio Visual Workroom - (35.22 SQM)	Student Space (16)	
B00F - R0005 - Workroom - (40.58 SQM)	Office (10)	
B00F - R0006 - Entry - (16.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Seminar - (13.17 SQM)	Office (3)	
B00F - R0012 - Seminar - (20.72 SQM)	Office (5)	
B00F - R0013 - Movement - (5.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Movement - (100.99 SQM)	Not Applicable	Circulation or storage space.
BOCA - R0004 - Food Technology L.S. - (74.52 SQM) - Teaching Space: 1	Student Space (34)	
BOCA - R0006 - Food Technology L.S. - (74.79 SQM) - Teaching Space: 1	Student Space (34)	
BOCA - R0007 - Food/Research Space - (39.37 SQM)	Not Applicable	Circulation or storage space.
BOCB - R0001 - Wood Technology L.S. - (100.97 SQM) - Teaching Space: 1	Student Space (46)	
BOCB - R0004 - Metal Technology Bay - (35.21 SQM)	Not Applicable	Circulation or storage space.
BOCB - R0007 - Welding Area - (9.55 SQM)	Not Applicable	Circulation or storage space.
BOCB - R0010 - Wood Technology Bay - (35.58 SQM)	Not Applicable	Circulation or storage space.
BOCB - R0011 - Wood Technology L.S. - (99.15 SQM) - Teaching Space: 1	Student Space (46)	
BOCB - R0012 - Movement - (67.14 SQM)	Not Applicable	Circulation or storage space.
BODA - R0001 - Laboratory L.S. - (93.63 SQM) - Teaching Space: 1	Student Space (43)	
BODA - R0002 - Laboratory L.S. - (91.26 SQM) - Teaching Space: 1	Student Space (42)	
BODA - R0005 - Growing/Breeding - (24.55 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
BODA - R0006 - Preparation - (69.82 SQM)	Not Applicable	Circulation or storage space.
BODA - R0010 - Staff Study - (36.36 SQM)	Office (9)	
BODA - R0011 - Laboratory L.S. - (91.87 SQM) - Teaching Space: 1	Student Space (42)	
BODA - R0012 - Laboratory L.S. - (94.55 SQM) - Teaching Space: 1	Student Space (43)	
BODA - R0013 - Laboratory L.S. - (94 SQM) - Teaching Space: 1	Student Space (43)	
BODA - R0014 - Laboratory L.S. - (93.84 SQM) - Teaching Space: 1	Student Space (43)	
BODA - R0015 - Movement - (48.25 SQM)	Not Applicable	Circulation or storage space.
BODA - R0017 - Movement - (251.65 SQM)	Not Applicable	Circulation or storage space.
BOEA - R0006 - Computer Learning Space - (61.89 SQM) - Teaching Space: 1	Student Space (28)	
BOEA - R0011 - Darkroom Space - (31.34 SQM)	Office (7)	
BOEA - R0013 - Movement - (231.21 SQM)	Not Applicable	Circulation or storage space.
BOEA - R0016 - Art Learning Space - (59.5 SQM) - Teaching Space: 1	Student Space (27)	
BOEA - R0017 - Art Learning Space - (59.49 SQM) - Teaching Space: 1	Student Space (27)	
BOEA - R0018 - Workshop - (46.57 SQM)	Student Space (21)	
BOEA - R0019 - Art Learning Space - (59.49 SQM) - Teaching Space: 1	Student Space (27)	
BOEA - R0020 - Music Learning Space - (59.5 SQM) - Teaching Space: 1	Student Space (27)	
BOEA - R0025 - Performance Workshop - (94.16 SQM)	Student Space (43)	
BOEA - R1001 - Interview/Office - Type 1 - (15.44 SQM)	Office (3)	
BOEA - R1002 - Interview/Office - Type 1 - (15.48 SQM)	Office (3)	
BOEA - R1003 - General Learning Space - (47.67 SQM) - Teaching Space: 1	Student Space (22)	
BOEA - R1004 - General Learning Space - (46.71 SQM) - Teaching Space: 1	Student Space (21)	
BOEA - R1005 - General Learning Space - (47.53 SQM) - Teaching Space: 1	Student Space (22)	
BOEA - R1006 - General Learning Space - (47.53 SQM) - Teaching Space: 1	Student Space (22)	
BOEA - R1011 - General Learning Space - (47.67 SQM) - Teaching Space: 1	Student Space (22)	
BOEA - R1012 - General Learning Space - (47.54 SQM) - Teaching Space: 1	Student Space (22)	
BOEA - R1013 - General Learning Space - (46.73 SQM) - Teaching Space: 1	Student Space (21)	
BOEA - R1014 - General Learning Space - (47.53 SQM) - Teaching Space: 1	Student Space (22)	
BOEA - R1015 - General Learning Space - (47.53 SQM) - Teaching Space: 1	Student Space (22)	
BOEA - R1019 - Movement - (137.8 SQM)	Not Applicable	Circulation or storage space.
BOEA - R1022 - Interview - (15.44 SQM)	Office (3)	
BOFA - R0001 - Staff Study - (30.47 SQM)	Office (7)	
BOFA - R0003 - Music Learning Space - (60.3 SQM) - Teaching Space: 1	Student Space (27)	
BOFA - R0005 - Practice/Seminar - (29.66 SQM)	Not Applicable	Circulation or storage space.
BOFA - R0006 - Music Learning Space - (73.12 SQM) - Teaching Space: 1	Student Space (33)	
BOFA - R0008 - Movement - (70.03 SQM)	Not Applicable	Circulation or storage space.
OS 534 11087 - OS 534 11087 - Library/Group Study/Office/A V Store - (152 SQM)	Student Space (70)	
OS 601 18333 - OS 601 18333 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 19727 - OS 601 19727 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	