


# VENTILATION AUDIT REPORT

SCHOOL:	Tottenham Central School (3249)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Lachlan

3249 - Tottenham Central School  
Site Plan (13579)



1:161

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Home Base - (65.51 SQM) - Teaching Space: 1	Student Space (30)	
B001 - R0002 - Home Base - (67.76 SQM) - Teaching Space: 1	Student Space (31)	
B001 - R0003 - Deputy Principal - (11.14 SQM)	Office (2)	
B001 - R0006 - Movement - (26.69 SQM)	Not Applicable	Circulation or storage space.
B002 - R0001 - Interview - (7.86 SQM)	Office (1)	
B002 - R0002 - Staff Room Annexe - (26.71 SQM)	Office (6)	
B002 - R0003 - Home Base - (67.37 SQM) - Teaching Space: 1	Student Space (31)	
B002 - R0004 - Home Base - (68.12 SQM) - Teaching Space: 1	Student Space (31)	
B002 - R0006 - Movement - (5.69 SQM)	Not Applicable	Circulation or storage space.
B003 - R0001 - Movement - (33.46 SQM)	Not Applicable	Circulation or storage space.
B003 - R0002 - General Learning Space - (57.55 SQM) - Teaching Space: 1	Student Space (26)	
B003 - R0005 - General Learning Space - (57.55 SQM) - Teaching Space: 1	Student Space (26)	
B004 - R0002 - Seminar/Study - (28.3 SQM)	Office (7)	
B004 - R0003 - Reading Area - (175.57 SQM)	Student Space (81)	
B005 - R0003 - Staff Room Annexe - (5.01 SQM)	Office (1)	
B005 - R0007 - General Learning Space - (35.14 SQM) - Teaching Space: 1	Student Space (16)	
B005 - R0008 - Staff Room Annexe - (30.95 SQM)	Office (7)	
B005 - R0009 - Computer Learning Space - (64.3 SQM) - Teaching Space: 1	Student Space (29)	
B005 - R0013 - Seminar/Study - (22.25 SQM)	Office (5)	
B005 - R0014 - Seminar/Study - (6.01 SQM)	Office (1)	
B005 - R0017 - Food Technology L.S. - (67.96 SQM) - Teaching Space: 1	Student Space (31)	
B005 - R0018 - Preparation - Materials - (19.91 SQM)	Not Applicable	Circulation or storage space.
B006 - R0001 - Staff Room Annexe - (9.39 SQM)	Office (2)	
B006 - R0002 - Seminar/Study - (52.18 SQM)	Office (13)	
B006 - R0003 - Senior Seminar - (16.27 SQM)	Office (4)	
B006 - R0006 - Laboratory L.S. - (92.22 SQM) - Teaching Space: 1	Student Space (42)	
B006 - R0010 - General Learning Space - (53.13 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R0011 - Preparation - (25.95 SQM)	Not Applicable	Circulation or storage space.
B007 - R0002 - Interview - (18.42 SQM)	Office (4)	
B007 - R0003 - Movement - (11.05 SQM)	Not Applicable	Circulation or storage space.
B007 - R0004 - Staff Room Annexe - (7.3 SQM)	Office (1)	
B007 - R0005 - Public Entry - (15.68 SQM)	Not Applicable	Circulation or storage space.
B007 - R0008 - Movement - (10.07 SQM)	Not Applicable	Circulation or storage space.
B007 - R0011 - Clerical Office - (20.09 SQM)	Office (5)	
B007 - R0012 - Principal - (15.1 SQM)	Office (3)	
B007 - R0014 - Clerical Office - (15.46 SQM)	Office (3)	
B007 - R0016 - Sick Bay - (9.05 SQM)	Student Space (4)	
B007 - R0017 - Interview - (7.01 SQM)	Office (1)	
B008 - R0005 - Movement - (20.93 SQM)	Not Applicable	Circulation or storage space.
B010 - R0003 - Materials Technology L.S. - (108.37 SQM) - Teaching Space: 1	Student Space (50)	
B010 - R0004 - Welding Area - (8.64 SQM)	Not Applicable	Circulation or storage space.
B010 - R0007 - Wood Technology Bay - (18.83 SQM)	Not Applicable	Circulation or storage space.
B010 - R0008 - Metal Technology Bay - (20.53 SQM)	Not Applicable	Circulation or storage space.
B010 - R0009 - Workshop Area - (57.81 SQM)	Student Space (26)	
B010 - R0011 - Welding Area - (10.33 SQM)	Not Applicable	Circulation or storage space.
B016 - R0004 - Canteen - (29.2 SQM)	Not Applicable	Circulation or storage space.