


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Toukley Public School (3250)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wyong</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

3250 - Toukley Public School  
Site Plan (12880)



1:1,310

Printed: 29-Apr-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Entry Vestibule - (10.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Deputy Principal - (11.96 SQM)	Office (2)	
B00A - R0017 - Interview - (9.07 SQM)	Office (2)	
B00A - R0018 - Principal - (18.22 SQM)	Office (4)	
B00A - R0019 - Duplicating Workroom - (19.12 SQM)	Office (4)	
B00A - R0020 - Clerical Office - (32.45 SQM)	Office (8)	
B00A - R0021 - Sick Bay - (11.42 SQM)	Student Space (5)	
B00A - R0022 - Interview - (12.38 SQM)	Office (3)	
B00A - R0023 - Movement - (14.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Reading Area - (41.97 SQM)	Student Space (19)	
B00B - R0005 - Movement - (11.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Reading Area - (179.68 SQM)	Student Space (83)	
B00C - R0004 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Communal Space - (186.21 SQM)	Student Space (86)	
B00C - R0018 - Canteen - (43.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Raised Platform - (52.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Staff Room - (61.74 SQM)	Office (15)	
B00D - R0012 - Home Base - (61.27 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0014 - Practical Activities - 1hb - (11.46 SQM)	Student Space (5)	
B00E - R0001 - Practical Activities - 1hb - (42.59 SQM)	Student Space (19)	
B00E - R0006 - Home Base - (60 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0008 - Withdrawal Space - 1hb - (12.57 SQM)	Student Space (5)	
B00E - R0009 - Home Base - (60 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0004 - Home Base - (60 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0005 - Movement - (20.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Withdrawal Space - 1hb - (12.57 SQM)	Student Space (5)	
B00F - R0008 - Home Base - (60 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0010 - Practical Activities - 1hb - (43.32 SQM)	Student Space (20)	
B00G - R0004 - Home Base - (59.52 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0005 - Home Base - (83.59 SQM) - Teaching Space: 1	Student Space (38)	
B00I - R0002 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00I - R0004 - Home Base - (59.23 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00I - R0006 - Home Base - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.42 SQM)	Student Space (9)	
B00J - R0001 - Withdrawal Space - 1hb - (16.3 SQM)	Student Space (7)	
B00J - R0002 - Withdrawal Space - 1hb - (11.11 SQM)	Student Space (5)	
B00J - R0004 - Movement - (16.32 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Home Base - (56.57 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0015 - Home Base - (56.33 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0016 - Home Base - (85.05 SQM) - Teaching Space: 1	Student Space (39)	
B00K - R0002 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00K - R0004 - Home Base - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0005 - Withdrawal Space - 2hb - (11.37 SQM)	Student Space (5)	
B00K - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0008 - Practical Activities - 1hb - (19.42 SQM)	Student Space (9)	
B00N - R0001 - Practical Activities - 1hb - (56.68 SQM)	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Q - R0016 - Staff Kitchen - (7.58 SQM)	Office (1)	
B00Q - R0017 - Special Programs Room - (44.4 SQM)	Student Space (20)	
B00R - R0004 - Practical Activities - Pre - (18.49 SQM)	Student Space (8)	
B00R - R0010 - Clerical Office - (10.03 SQM)	Office (2)	
B00R - R0011 - Movement - (9.75 SQM)	Not Applicable	Circulation or storage space.
B00R - R0013 - Home Base - (53.87 SQM) - Teaching Space: 1	Student Space (24)	
B00R - R0014 - Practical Activities - (34.96 SQM)	Student Space (16)	
B00S - R0004 - Practical Activities - 1hb - (18.99 SQM)	Student Space (8)	
B00S - R0005 - Home Base - (60.32 SQM) - Teaching Space: 1	Student Space (27)	
B00S - R0007 - Withdrawal Space - 2hb - (11.48 SQM)	Student Space (5)	
B00S - R0008 - Practical Activities - 1hb - (18.05 SQM)	Student Space (8)	
B00S - R0009 - Home Base - (60.32 SQM) - Teaching Space: 1	Student Space (27)	
B00S - R0012 - Practical Activities - 1hb - (18.79 SQM)	Student Space (8)	
B00S - R0013 - Withdrawal Space - 1hb - (8.85 SQM)	Student Space (4)	
B00S - R0015 - Home Base - (59.13 SQM) - Teaching Space: 1	Student Space (27)	
B00S - R0017 - Special Programs Room - (37.07 SQM)	Student Space (17)	
B00S - R1003 - Practical Activities - 1hb - (19.01 SQM)	Student Space (8)	
B00S - R1004 - Home Base - (60.17 SQM) - Teaching Space: 1	Student Space (27)	
B00S - R1006 - Withdrawal Space - 2hb - (11.51 SQM)	Student Space (5)	
B00S - R1007 - Practical Activities - 1hb - (19 SQM)	Student Space (8)	
B00S - R1008 - Home Base - (60.17 SQM) - Teaching Space: 1	Student Space (27)	
B00S - R1011 - Practical Activities - 1hb - (18.91 SQM)	Student Space (8)	
B00S - R1012 - Withdrawal Space - 1hb - (9.17 SQM)	Student Space (4)	
B00S - R1014 - Home Base - (59.05 SQM) - Teaching Space: 1	Student Space (27)	
OS 601 13008 - OS 601 13008 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 11195 - OS 602 11195 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11762 - OS 602 11762 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14913 - OS 602 14913 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 606 19797 - OS 606 19797 - Learning Unit - Standard With P.A.A A/C - ( SQM)	Student Space ( )	