

VENTILATION AUDIT REPORT

| | |
|-------------------------------|--|
| SCHOOL: | Tower Street Public School (4151) |
| AMU REGION: | South Western Sydney |
| STATE ELECTORATE: | East Hills |
| LOCAL GOVERNMENT AREA: | Canterbury-Bankstown |

4151 - Tower Street Public School
Site Plan (11345)



1:1,127

Printed: 21-Mar-2020

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0002 - Movement - (17.11 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0005 - Reading Area - (42.64 SQM) | ● Student Space (19) | |
| B00A - R0008 - Reading Area - (56.4 SQM) | ● Student Space (26) | |
| B00A - R0009 - Reading Area - (56.48 SQM) | ● Student Space (26) | |
| B00A - R0015 - Movement - (81.26 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0002 - Movement - (7.49 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0003 - Home Base - (56.88 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00B - R0005 - Home Base - (57.21 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00B - R0008 - Movement - (6.46 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0011 - Home Base - (57.13 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00B - R0013 - Home Base - (57.13 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00B - R0015 - Movement - (6.08 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R9003 - Movement - (12.14 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R9007 - Canteen - (23.27 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0002 - Movement - (7.22 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0004 - Duplicating Workroom - (15.69 SQM) | ● Office (3) | |
| B00C - R0005 - Entry Vestibule - (11.22 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0006 - Movement - (9.22 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0007 - Clerical Office - (18.34 SQM) | ● Office (4) | |
| B00C - R0009 - Principal - (23.19 SQM) | ● Office (5) | |
| B00C - R0011 - Staff Room - (56.88 SQM) | ● Office (14) | |
| B00C - R0013 - Sick Bay - (10.91 SQM) | ● Student Space (5) | |
| B00C - R0015 - Deputy Principal - (15.75 SQM) | ● Office (3) | |
| B00C - R0017 - Movement - (6.46 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0001 - Movement - (8.17 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0002 - Movement - (7.39 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0003 - Home Base - (65.87 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00D - R0007 - Home Base - (66.14 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00D - R0009 - Movement - (59.03 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0001 - Outdoor Learning Area - (59.12 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0002 - Movement - (9.1 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0004 - Staff Kitchen - (20.64 SQM) | ● Office (5) | |
| B00E - R0006 - Home Base - (66 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00E - R0007 - Home Base - (66.09 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00E - R0009 - Movement - (9.67 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0013 - Home Base - (91.97 SQM) - Teaching Space: 1 | ● Student Space (42) | |
| B00E - R0014 - Home Base - (66 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00E - R0017 - Movement - (12.16 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0019 - Duplicating Workroom - (17.21 SQM) | ● Office (4) | |
| B00E - R0022 - Outdoor Learning Area - (127.68 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0023 - Outdoor Learning Area - (54.23 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0001 - Communal Space - (145.31 SQM) | ● Student Space (67) | |
| B00K - R0002 - Raised Platform - (60.08 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0016 - Movement - (6.17 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0017 - Movement - (13 SQM) | Not Applicable | Circulation or storage space. |