


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Tregeagle Public School (3255)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lismore</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lismore</b>

3255 - Tregeagle Public School  
Site Plan (11460)



1:1,087

Printed: 24-Sep-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office - (11.04 SQM)	Office (2)	
B00A - R0004 - Principal - (11.28 SQM)	Office (2)	
B00A - R0007 - Home Base - (69.68 SQM) - Teaching Space: 1	Student Space (32)	
B00A - R0008 - Special Programs Room - (42.31 SQM)	Student Space (19)	
B00A - R0009 - Special Programs Room - (19.39 SQM)	Student Space (8)	
B00A - R0010 - Entry Vestibule - (5.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Clerical Office/Workroom - (6.73 SQM)	Office (1)	
B00C - R0001 - Canteen - (10.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (10.13 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (27.77 SQM)	Student Space (12)	
B00E - R0003 - Withdrawal Space - 1hb - (10.97 SQM)	Student Space (5)	
B00E - R0004 - Home Base - (46.18 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0001 - Home Base - (57.67 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0002 - Practical Activities - 1hb - (24.29 SQM)	Student Space (11)	
B00F - R0004 - Withdrawal Space - 1hb - (8.82 SQM)	Student Space (4)	
B00F - R0005 - Reading Area - (81.64 SQM)	Student Space (37)	
B00F - R0008 - Staff Room Annexe - (19.37 SQM)	Office (4)	
B00I - R0002 - Practical Activities - 1hb - (19.36 SQM)	Student Space (8)	
B00I - R0004 - Home Base - (58.76 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	Student Space (4)	
B00I - R0006 - Home Base - (58.67 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.36 SQM)	Student Space (8)	
OS 522 16828 - OS 522 16828 - Staff Study - (38 SQM)	Office (9)	