


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Tuggerah Lakes Secondary College Berkeley Vale (8563)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>The Entrance</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

8563 - Tuggerah Lakes Secondary College Berkeley Vale  
Site Plan (10875)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Deputy Principal Office - (16.41 SQM)	Office (4)	
B00A - R0003 - Administration - Clerical - (36.45 SQM)	Office (9)	
B00A - R0006 - Principal Office - (21.68 SQM)	Office (5)	
B00A - R0007 - Deputy Principal Office - (15.97 SQM)	Office (3)	
B00A - R0010 - Staff Kitchen - (12.65 SQM)	Office (3)	
B00A - R0013 - Clinic - (12.33 SQM)	Office (3)	
B00A - R0015 - Administration - Clerical - (12.15 SQM)	Office (3)	
B00A - R0016 - Administration - Clerical - (12.5 SQM)	Office (3)	
B00A - R0017 - Interview/Meeting - (12.25 SQM)	Office (3)	
B00A - R0018 - Public Reception - (15.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (80.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Student Waiting - (8.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Art Learning Space - (60.3 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0006 - Art Learning Space - (60.53 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0007 - Art Learning Space - (47.42 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0009 - Art Learning Space - (60 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0010 - Multi Media Workshop - (18.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Staff Study - (23.31 SQM)	Office (5)	
B00B - R0014 - Movement - (77.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Ancillary Staff - (21.66 SQM)	Office (5)	
B00C - R0003 - Metal Technology L.S. - (91.51 SQM) - Teaching Space: 1	Student Space (42)	
B00C - R0015 - Wood Technology Bay - (31.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Metal Technology Bay - (39.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Metal Technology L.S. - (91.41 SQM) - Teaching Space: 1	Student Space (42)	
B00C - R0026 - Materials Workshop - Type 2 - (77.12 SQM)	Student Space (35)	
B00C - R0028 - Movement - (69.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0029 - Wood Technology L.S. - (88.48 SQM) - Teaching Space: 1	Student Space (41)	
B00C - R0031 - Wood Technology L.S. - (88.35 SQM) - Teaching Space: 1	Student Space (40)	
B00D - R0003 - Design L.S. - (70.68 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R0004 - Food Technology L.S. - (105.14 SQM) - Teaching Space: 1	Student Space (48)	
B00D - R0006 - Preparation - Materials - (15.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Food Technology L.S. - (104.9 SQM) - Teaching Space: 1	Student Space (48)	
B00D - R0008 - Design L.S. - (70.58 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R0010 - Movement - (40.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Movement - (9.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Dark Room - (14.56 SQM)	Office (3)	
B00D - R0023 - Staff Study - (24.68 SQM)	Office (6)	
B00D - R1002 - General Learning Space - (56.12 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1004 - Computer Learning Space - (56.2 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1008 - Staff Study - (24.74 SQM)	Office (6)	
B00E - R0001 - General Learning Space - (48.98 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0002 - General Learning Space - (39.6 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R0003 - General Learning Space - (40.06 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R0004 - General Learning Space - (49.12 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0006 - General Learning Space - (49.46 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0011 - Leading Teacher - (16.01 SQM)	Office (4)	
B00E - R0012 - Interview/Office - Type 1 - (16.18 SQM)	Office (4)	
B00E - R0013 - Movement - (187.13 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Interview/Meeting - (37.02 SQM)	Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1001 - Staff Study - (26.13 SQM)	Office (6)	
B00E - R1002 - General Learning Space - (49.22 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1003 - General Learning Space - (41.03 SQM) - Teaching Space: 1	Student Space (19)	
B00E - R1004 - General Learning Space - (40.9 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R1005 - General Learning Space - (49.28 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1007 - General Learning Space - (49.45 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1008 - General Learning Space - (49.83 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1011 - General Learning Space - (49.2 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1012 - Movement - (131.68 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Tiered Learning Area - (63.95 SQM)	Student Space (29)	
B00F - R0015 - Main Entry - (26.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Seminar - (12.64 SQM)	Office (3)	
B00F - R0021 - Seminar - (12.52 SQM)	Office (3)	
B00F - R0022 - Seminar - (13.27 SQM)	Office (3)	
B00F - R0024 - Main Area - (417.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R1007 - Movement - (87.62 SQM)	Not Applicable	Circulation or storage space.
B00F - R1008 - Staff Study - (103.77 SQM)	Office (25)	
B00F - R1010 - Commonroom - (89.99 SQM)	Office (22)	
B00F - R1011 - Staff Kitchen - (7.9 SQM)	Office (1)	
B00G - R0001 - General Learning Space - (49.14 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R0002 - General Learning Space - (40.64 SQM) - Teaching Space: 1	Student Space (18)	
B00G - R0003 - General Learning Space - (40.63 SQM) - Teaching Space: 1	Student Space (18)	
B00G - R0004 - General Learning Space - (49.28 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R0005 - Interview/Office - Type 1 - (16.4 SQM)	Office (4)	
B00G - R0012 - Interview/Meeting - (21.09 SQM)	Office (5)	
B00G - R0013 - Movement - (183.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Staff Study - (87.66 SQM)	Office (21)	
B00G - R1001 - General Learning Space - (49.34 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R1002 - General Learning Space - (41.03 SQM) - Teaching Space: 1	Student Space (19)	
B00G - R1006 - General Learning Space - (49.08 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R1008 - Computer Learning Space - (48.19 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R1010 - General Learning Space - (49.95 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R1011 - General Learning Space - (49.51 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R1013 - Movement - (133.4 SQM)	Not Applicable	Circulation or storage space.
B00G - R1015 - Staff Study - (34.59 SQM)	Office (8)	
B00I - R0002 - Interview/Meeting - (16.55 SQM)	Office (4)	
B00I - R0004 - General Learning Space - (59.02 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0005 - General Learning Space - (58.48 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0006 - Movement - (34.51 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - General Learning Space - (58.96 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0008 - General Learning Space - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0016 - Fitness Laboratory - (104.55 SQM)	Student Space (48)	
B00I - R1001 - Performance Workshop - (114 SQM)	Student Space (52)	
B00I - R1003 - General Learning Space - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R1004 - General Learning Space - (58.85 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R1005 - Movement - (34.74 SQM)	Not Applicable	Circulation or storage space.
B00I - R1006 - General Learning Space - (58.87 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R1007 - Computer Learning Space - (58.82 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0001 - Student Canteen - (61.3 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Movement - (26.77 SQM)	Not Applicable	Circulation or storage space.
B00L - R0008 - Movement - (26.79 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Staff Study - (23.08 SQM)	● Office (5)	
B00L - R0024 - Multi-Purpose Space - (476.68 SQM)	● Student Space (221)	
B00L - R0026 - Stage - (95.88 SQM)	Not Applicable	Circulation or storage space.
B00L - R0035 - Staff Study - (12.5 SQM)	● Office (3)	
B00M - R0001 - Music Learning Space - (63.98 SQM) - Teaching Space: 1	● Student Space (29)	
B00M - R0002 - Practice/Seminar - (25.94 SQM)	Not Applicable	Circulation or storage space.
B00M - R0008 - Practice/Seminar - (31.08 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Music Learning Space - (85.39 SQM) - Teaching Space: 1	● Student Space (39)	
B00M - R0019 - Movement - (98.69 SQM)	Not Applicable	Circulation or storage space.
B00M - R0021 - General Assistants - (18.78 SQM)	● Office (4)	
B00M - R0023 - Staff Study - (18.85 SQM)	● Office (4)	
B00M - R0025 - Tea Room - (11.98 SQM)	Not Applicable	Circulation or storage space.
B00M - R1001 - Laboratory L.S. - (84.02 SQM) - Teaching Space: 1	● Student Space (38)	
B00M - R1002 - Preparation - Science - (33.17 SQM)	Not Applicable	Circulation or storage space.
B00M - R1003 - Laboratory L.S. - (79.26 SQM) - Teaching Space: 1	● Student Space (36)	
B00M - R1005 - Laboratory L.S. - (80.6 SQM) - Teaching Space: 1	● Student Space (37)	
B00M - R1010 - Laboratory L.S. - (80.69 SQM) - Teaching Space: 1	● Student Space (37)	
B00M - R1012 - Laboratory L.S. - (84.47 SQM) - Teaching Space: 1	● Student Space (39)	
B00M - R1013 - Movement - (104.62 SQM)	Not Applicable	Circulation or storage space.
B00M - R1021 - Staff Study - (36.47 SQM)	● Office (9)	
B00N - R0002 - Growing/Breeding - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00P - R0004 - Movement - (29.24 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0004 - Movement - (29.55 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Movement - (14.49 SQM)	Not Applicable	Circulation or storage space.
B00R - R0003 - Growing/Breeding - (20.3 SQM)	Not Applicable	Circulation or storage space.
B00R - R0004 - Growing/Breeding - (20.3 SQM)	Not Applicable	Circulation or storage space.
B00R - R0005 - Growing/Breeding - (21.52 SQM)	Not Applicable	Circulation or storage space.
NS 220 13194 - NS 220 13194 - Science Learning/Preparation Space - (95 SQM)	Not Applicable	Circulation or storage space.