


VENTILATION AUDIT REPORT

SCHOOL:	Tuggerah Lakes Secondary College Tumby Umbi (8274)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	The Entrance
LOCAL GOVERNMENT AREA:	Central Coast

8274 - Tuggerah Lakes Secondary College Tumby Umbi
Site Plan (13306)



1:1,599

Printed: 11-Apr-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Commonroom - (96.37 SQM)	Office (24)	
B00A - R0002 - Movement - (205.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Deputy Principal Office - (16.11 SQM)	Office (4)	
B00A - R0010 - Pupil Entry - (9.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Administration - Clerical - (35.25 SQM)	Office (8)	
B00A - R0012 - Public Entry - (13.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Duplicating Workroom - (27.97 SQM)	Office (6)	
B00A - R0014 - Interview/Office - Type 1 - (12.96 SQM)	Office (3)	
B00A - R0015 - Movement - (55.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Interview/Office - Type 1 - (12.84 SQM)	Office (3)	
B00A - R0017 - Principal Office - (19.66 SQM)	Office (4)	
B00A - R0018 - Clinic - Boys - (14.09 SQM)	Office (3)	
B00A - R0021 - Clinic - Girls - (14.02 SQM)	Office (3)	
B00A - R0022 - Interview/Office - Type 1 - (12.85 SQM)	Office (3)	
B00A - R0023 - Interview/Office - Type 1 - (12.73 SQM)	Office (3)	
B00A - R1001 - Computer Learning Space - (74.02 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R1004 - Movement - (122.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Seminar - (15.73 SQM)	Office (3)	
B00A - R1010 - Workroom - (33.74 SQM)	Office (8)	
B00A - R1012 - Entry - (21.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Main Area - (328 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Audio Visual Workroom - (30.7 SQM)	Student Space (14)	
B00B - R0001 - General Learning Space - (46.99 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0002 - Movement - (201.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - General Learning Space - (46.7 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0009 - General Learning Space - (47.11 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0010 - General Learning Space - (45.76 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0012 - General Learning Space - (45.7 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0013 - General Learning Space - (47.05 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0015 - General Learning Space - Type 1 - (45.11 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0022 - Computer Learning Space - (64.3 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0023 - General Learning Space - Type 10 - (44.97 SQM) - Teaching Space: 0.5	Student Space (20)	
B00B - R0024 - Practical Activity Area - (14.42 SQM)	Student Space (6)	
B00B - R0025 - Practical Activity Area - (14.42 SQM)	Student Space (6)	
B00B - R1001 - General Learning Space - (46.7 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1007 - Movement - (163.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - General Learning Space - (46.42 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1009 - General Learning Space - (46.77 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1010 - General Learning Space - (46.43 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1012 - General Learning Space - (46.44 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1013 - General Learning Space - (46.85 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1015 - General Learning Space - Type 1 - (59.6 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1017 - Seminar - (18.97 SQM)	Office (4)	
B00B - R1020 - Computer Learning Space - (59.96 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1021 - General Learning Space - Type 1 - (59.53 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1022 - Movement - (60.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (212.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Laboratory L.S. - (91.65 SQM) - Teaching Space: 1	Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0003 - Laboratory L.S. - (90.55 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0004 - Growing/Breeding - (20.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Movement - (41.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Preparation - (64.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Serviced Learning Space - (51 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0012 - Movement - (17.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Interview/Office - Type 1 - (12.93 SQM)	● Office (3)	
B00C - R0017 - Laboratory L.S. - (91.75 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0018 - Laboratory L.S. - (91.77 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0019 - Laboratory L.S. - (91.85 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0001 - Movement - (73.44 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Commonroom - (139.83 SQM)	● Office (34)	
B00D - R0004 - Commonroom - (47.06 SQM)	● Office (11)	
B00D - R0005 - General Learning Space - (46.99 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0006 - General Learning Space - (46.29 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0001 - Movement - (53.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (92.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - General Assistants - (9.74 SQM)	● Office (2)	
B00E - R0005 - Performance Workspace - (153.41 SQM) - Teaching Space: 1	● Student Space (71)	
B00E - R0007 - Movement - (37.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (22.52 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Student Canteen - (52.29 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Movement - (11.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R1002 - Movement - (10.11 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (120.83 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Special Learning Space - (47.96 SQM) - Teaching Space: 1	● Student Space (22)	
B00H - R0003 - Special Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0006 - Practice/Seminar - (24.8 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Music Learning Space - (58.5 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0009 - Music Learning Space - (76.88 SQM) - Teaching Space: 1	● Student Space (35)	
B00H - R0010 - Interview/Office - Type 1 - (13.47 SQM)	● Office (3)	
B00H - R0011 - Interview/Office - Type 1 - (13.44 SQM)	● Office (3)	
B00I - R0001 - Movement - (161.05 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Interview/Office - Type 1 - (13.32 SQM)	● Office (3)	
B00I - R0003 - Interview/Office - Type 1 - (13.41 SQM)	● Office (3)	
B00I - R0005 - Art Learning Space - (60.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0006 - Art Learning Space - (60.99 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0007 - Workshop - (51.34 SQM)	● Student Space (23)	
B00I - R0009 - Art Learning Space - (60.99 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0014 - Darkroom Space - (30.85 SQM)	● Office (7)	
B00I - R0017 - Commonroom - (174.16 SQM)	● Office (43)	
B00I - R0021 - Staff Study - (13.58 SQM)	● Office (3)	
B00I - R0022 - Staff Study - (13.32 SQM)	● Office (3)	
B00I - R0024 - Movement - (20.94 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - General Learning Space - (48.17 SQM) - Teaching Space: 1	● Student Space (22)	
B00J - R0009 - Materials Technology L.S. - (174.32 SQM) - Teaching Space: 1	● Student Space (80)	
B00J - R0010 - Metal Technology Bay - (41.27 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Wood Technology Bay - (66.41 SQM)	Not Applicable	Circulation or storage space.
B00J - R0014 - Wood Technology Bay - (12.29 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Workshop Area - (35.59 SQM)	● Student Space (16)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0018 - Design L.S. - (96.27 SQM) - Teaching Space: 1	● Student Space (44)	
B00J - R0020 - Serviced Learning Space - (76.96 SQM) - Teaching Space: 1	● Student Space (35)	
B00J - R0033 - Metal Technology L.S. - (117.24 SQM) - Teaching Space: 1	● Student Space (54)	
B00J - R0035 - Seminar - (19.82 SQM)	● Office (4)	
B00J - R0036 - Movement - (390.42 SQM)	Not Applicable	Circulation or storage space.
B00J - R1004 - Senior Study - (60.8 SQM)	● Office (15)	
B00J - R1005 - General Learning Space - (51.22 SQM) - Teaching Space: 1	● Student Space (23)	
B00J - R1007 - General Learning Space - (47.31 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R1008 - General Learning Space - (50.29 SQM) - Teaching Space: 1	● Student Space (23)	
B00J - R1010 - Design L.S. - (81.34 SQM) - Teaching Space: 1	● Student Space (37)	
B00J - R1011 - Serviced Learning Space - (81.76 SQM) - Teaching Space: 1	● Student Space (37)	
B00J - R1015 - Serviced Learning Space - (61.88 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R1016 - Food/Research Space - (39.15 SQM)	Not Applicable	Circulation or storage space.
B00J - R1017 - Food Technology L.S. - (76.32 SQM) - Teaching Space: 1	● Student Space (35)	
B00J - R1025 - Movement - (311.81 SQM)	Not Applicable	Circulation or storage space.
B00J - R1029 - Food/Research Space - (27.71 SQM)	Not Applicable	Circulation or storage space.
B00J - R1030 - Food Technology L.S. - (101.07 SQM) - Teaching Space: 1	● Student Space (46)	
B00J - R1031 - General Learning Space - (64.72 SQM) - Teaching Space: 1	● Student Space (30)	
B00J - R1034 - Senior Study - (43.87 SQM)	● Office (10)	
B00K - R0001 - Gymnasium - (465.33 SQM)	● Student Space (215)	
B00K - R0008 - Movement - (124.78 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Gymnasium - (53.32 SQM)	● Student Space (24)	
OS 601 12330 - OS 601 12330 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19437 - OS 601 19437 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19480 - OS 601 19480 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19489 - OS 601 19489 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	