

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Tuggerawong Public School (4097)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wyong</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

4097 - Tuggerawong Public School  
Site Plan (11351)



1:930

Printed: 08-Sep-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Interview - (12.5 SQM)	Office (3)	
B00A - R0006 - Deputy Principal - (13 SQM)	Office (3)	
B00A - R0007 - Principal - (16.96 SQM)	Office (4)	
B00A - R0008 - Entry Vestibule - (9.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Clerical Office - (12.29 SQM)	Office (3)	
B00A - R0010 - Sick Bay - (8.6 SQM)	Student Space (3)	
B00A - R0014 - Duplicating Workroom - (20.17 SQM)	Office (5)	
B00A - R0018 - Staff Room - (39.52 SQM)	Office (9)	
B00A - R0022 - Movement - (39.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (39.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (40.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Interview - (13.98 SQM)	Office (3)	
B00B - R0001 - Movement - (11.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Practical Activities - 1hb - (41.98 SQM)	Student Space (19)	
B00B - R0005 - Movement - (11.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (62.18 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0009 - Movement - (7.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Withdrawal Space - 1hb - (11.36 SQM)	Student Space (5)	
B00B - R0014 - Movement - (7.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Home Base - (62.18 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0001 - Withdrawal Space - 1hb - (29.19 SQM)	Student Space (13)	
B00E - R0001 - Withdrawal Space - 1hb - (5.49 SQM)	Student Space (2)	
B00E - R0002 - Practical Activities - 1hb - (10.96 SQM)	Student Space (5)	
B00E - R0004 - Home Base - (53.69 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0005 - Home Base - (53.54 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0006 - Movement - (31.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (38.51 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00F - R0004 - Home Base - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00F - R0006 - Home Base - (59.23 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0008 - Practical Activities - 1hb - (19.42 SQM)	Student Space (9)	
B00H - R0002 - Movement - (13.52 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Withdrawal Space - 1hb - (11.68 SQM)	Student Space (5)	
B00H - R0004 - Movement - (13.51 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Home Base - (61.72 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0007 - Practical Activities - 1hb - (16.56 SQM)	Student Space (7)	
B00H - R0008 - Home Base - (61.71 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0009 - Practical Activities - 1hb - (16.57 SQM)	Student Space (7)	
B00H - R0010 - Movement - (35.66 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Reading Area - (169.99 SQM)	Student Space (78)	
B00J - R0008 - Movement - (30.71 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Communal Space - (132.51 SQM)	Student Space (61)	
B00N - R0002 - Raised Platform - (70.58 SQM)	Not Applicable	Circulation or storage space.
B00N - R0015 - Movement - (15.1 SQM)	Not Applicable	Circulation or storage space.
B00N - R0017 - Movement - (7.3 SQM)	Not Applicable	Circulation or storage space.
B00O - R0002 - Computer Room - (18.34 SQM)	Student Space (8)	
OS 602 11274 - OS 602 11274 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13559 - OS 602 13559 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 801 15102 - OS 801 15102 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.

