

VENTILATION AUDIT REPORT

SCHOOL:	Tullibigeal Central School (3272)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Lachlan

3272 - Tullibigeal Central School
Site Plan (11509)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Interview - (8.95 SQM)	Office (2)	
B00A - R0002 - Movement - (6.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Movement - (9.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Clinic-Waiting - (5.95 SQM)	Office (1)	
B00A - R0014 - Sick Bay - (8.47 SQM)	Student Space (3)	
B00A - R0016 - Clerical Office - (37.06 SQM)	Office (9)	
B00A - R0017 - Movement - (10.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (47.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Interview - (12.82 SQM)	Office (3)	
B00A - R0020 - Deputy Principal - (12.85 SQM)	Office (3)	
B00A - R0022 - Principal - (12.78 SQM)	Office (3)	
B00A - R0024 - Staff Room - (32.49 SQM)	Office (8)	
B00A - R0025 - Staff Room Annexe - (20.6 SQM)	Office (5)	
B00B - R0001 - Movement - (33.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Practical Activities - 1hb - (35.11 SQM)	Student Space (16)	
B00B - R0006 - Withdrawal Space - 1hb - (8.79 SQM)	Student Space (4)	
B00B - R0008 - Seminar - Type 1 - (19.38 SQM)	Office (4)	
B00B - R0009 - Seminar Space - (18.86 SQM)	Office (4)	
B00B - R0010 - Canteen - (30.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (26.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (59.06 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0005 - Movement - (14.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (14.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Withdrawal Space - 1hb - (6.56 SQM)	Student Space (3)	
B00C - R0008 - Home Base - (59.04 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0013 - Practical Activities - 1hb - (44.56 SQM)	Student Space (20)	
B00D - R0002 - Movement - (55.44 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (67.51 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0007 - Senior Study - (31.61 SQM)	Office (7)	
B00E - R0001 - Practical Activities - 1hb - (19.2 SQM)	Student Space (8)	
B00E - R0002 - General Learning Space - (34.8 SQM) - Teaching Space: 1	Student Space (16)	
B00E - R0004 - Movement - (5.37 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Welding Area - (5.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Materials Technology L.S. - (78.68 SQM) - Teaching Space: 1	Student Space (36)	
B00F - R0010 - Preparation - (9.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Food Technology L.S. - (58.1 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0013 - Movement - (33.37 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - General Learning Space - (58.13 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0019 - Metal Technology Bay - (52.8 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Metal Technology Bay - (112.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Communal Space - (46.33 SQM)	Student Space (21)	
B00G - R0014 - Movement - (35.55 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Reading Area - (59.9 SQM)	Student Space (27)	
OS 600 12309 - OS 600 12309 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 720 15777 - OS 720 15777 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 751 14487 - OS 751 14487 - Learning Unit - ESL - (76 SQM)	Student Space (35)	
OS 801 10856 - OS 801 10856 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.